
Subject: Inspection of Regional Water Infrastructure

Report to: Public Works Committee

Report date: Tuesday, April 5, 2022

1. That staff **BE DIRECTED** to consult with the area municipalities to review options for reinstating a water loss committee to collectively review strategies for targeted investigation and reduction of water loss, with a goal of providing an update to the 2007 Regional Water Loss report; and
2. That this Report **BE CIRCULATED** to the Local Area Municipalities.

Key Facts

- In 2021, Niagara Region delivered 56,065 ML of treated water through six water treatment plants and 313 km of watermain across 11 municipalities.
- Operations staff monitor variations in flow and pressure throughout the system, and immediately report suspected main breaks to Regional and Area Municipal staff as observations warrant. Breaks on transmission mains are repaired immediately.
- Distribution flow is monitored using 25 flow meters across Niagara, which are verified and calibrated on a semi-annual basis by a third party contractor. These flows are used not only for billing calculations, but also long-term planning associated with servicing, development planning and capital project design.
- Between 2004 and 2007 a Water Loss Reduction Task Force comprised of Regional and Area Municipal representatives was formed to share experiences regarding water loss levels and strategies for reduction.
- Niagara's water transmission system is comprised of large diameter water mains of various pipe material. Approximately 89 per cent of these transmission mains are non-metallic, which is not favourable to acoustic leak detection. Leak detection involving invasive technologies or system shutdowns will potentially impact thousands of customers and may not be feasible on trunk systems.

Financial Considerations

Watermains are designed for a useful service life greater than 80 years and appurtenances such as valves are designed for a useful service life of 25 years. Access chambers are designed for a useful service life of 50 to 100 years. Asset service life and condition are influenced by various factors such as material, quality, location, use, and

the environment that it is installed in. As thresholds for these criteria are met, watermains are selected for replacement through Capital funds.

The annual cost of calibration, for flow meters used for billing, is approximately \$18,000. A breakdown of these costs is provided in Table 2 below (Analysis: Calibration and Verification).

A comprehensive review of water loss along all of Niagara Region's transmission mains would be approximately \$3,000 to \$25,000 per km of main depending on the diameter of main and the water loss technology used. This estimate is based on the Region's previous work regarding water loss strategies, and is contingent on watermain material, location and configuration of the transmission system. A summary of leak detection strategies is presented in the Analysis section below.

Analysis

Niagara Region owns and maintains 313 km of watermain and 973 underground enclosures across 11 municipalities. Appendix 1 contains a detailed summary by municipality.

Table 1 below identifies the total length of pipe in the Regional network, by pipe material.

Table 1: KM of Watermain by Pipe Material

Material	KMs of Watermain	Percent of System	Life Expectancy (Years)	Average Age (Years)
Concrete Pressure Pipe	137	44	70-80	43
PVC Plastic Pipe	108	35	75	17
Asbestos Cement Pipe	32	10	60-70	49
Ductile Iron	14	4	60-70	29
Cast Iron	10	3	60-70	58
Other	11	4	60-70	37

Operational Monitoring and Break Response

Niagara operates six (6) water treatment plants. Operators at these facilities monitor variations in flow and pressure throughout the system and immediately report suspected main breaks to Regional and Area Municipal staff as observations warrant. As breaks

are suspected, Niagara Region initiates the resources to investigate. Region staff often support Area Municipalities in locating and confirming breaks on Local infrastructure. To troubleshoot these events, Regional staff rely on trends from a variety of online instruments which measure flow, pressure, level etc. In the event that a failure is on Region infrastructure, Niagara Region maintenance staff use contractors for immediate repair of the main from a preapproved list of external parties detailed in the Water and Wastewater Emergency Response Procedure.

Inspection and Maintenance

Underground enclosures (valve chambers) are routinely inspected by internal maintenance personnel through routine preventative maintenance programs, such as the valve turning program. As required, maintenance personnel inspect and report on valve chamber condition and general operation to support troubleshooting of operational or distribution issues. For example, in January 2022, maintenance personnel inspected chambers along transmission watermain in the City of Port Colborne to provide feedback to the City on concerns related to main breaks in the local distribution system. At the time of inspection, all visible piping and valves were in good working order.

Investigations Completed to Date

Through Capital Project scoping and design, many studies and condition assessments have been completed to evaluate the integrity of transmission mains, valves and appurtenances. In addition to these studies, the following specific water loss investigations have occurred:

2004 to 2007: Water Loss Reduction Task Force and Regional Water Loss Assessment Project

In 2004 the “Water Loss Reduction Task Force” comprised of Regional and Area Municipal representatives was formed. The purpose of this group was to share experiences regarding water loss levels and strategies for reduction. Through the “Water Loss Assessment Project” water balances were completed based on the data provided by the Region and Area Municipalities. The study was completed by Veritec Consulting Inc. and was finalized in 2007. The Regional Water Loss Assessment Project report is included in Appendix 2.

2011 - 2015: City of Port Colborne – Integration of Water Loss Analysis Tools into a SCADA System

Between 2011 and 2014 a study was developed and conducted in the City of Port Colborne to develop off-line and real time tools to integrate the City's water usage data with flow data from four district metered areas (DMAs). Niagara Region provided in-kind (SCADA) support for this project, which was also funded through the Showcasing Water Innovation Program. The goal of this project was to provide the City with flow monitoring to aid in locating and remediating unaccounted for water.

2020: Niagara Region Billing Meter Verification Demonstration to Town of Fort Erie

In response to questions from the Town of Fort Erie, the Region invited Town staff to witness a third party calibration process at the Rosehill Water Treatment Plant for the billing meters impacting the Town. Following this demonstration, Niagara Region shared verification certificates with Town staff.

2021 – 2022; Niagara Region – Water and Wastewater Billing Flowmeter Audit

This project is currently underway to review, confirm and make recommendations for improvements for all processes that contribute to the volumes used for billing. This work includes an audit of the accuracy and suitability of the Region's billing flow meters and a comparison of current methods, including meter type and installation against best practices.

Calibration and Verification

Water meters are essential for process automation and are calibrated on a semi-annual basis. The cost for these calibrations is shown in Table 2 below.

Table 2: Calibration of Flow Meters

Program Name	Frequency	Cost
Calibration of Non Mechanical Flow Meters	Semi-annual	≈ \$15,200
Calibration of Mechanical Flow Meters	Semi-annual	≈ \$2,200

When establishing the frequency of calibration required, Niagara Region takes into account whether or not the meter is used to meet legal requirements, industry standards for calibration, manufacturer recommendations and the conditions of use such as importance of collected data for use in other processes such as billing. There are 25 water meters used for billing, all of which are calibrated on a semi-annual frequency.

Water QMS Risk Assessment

An internal risk assessment is required every 36 months for each of Niagara Region's water systems, with complementary risk assessment reviews to be completed at 12 and 24 months between the assessments. A full risk assessment for the Water QMS was completed in 2021, with reviews to follow in 2022 and 2023.

Through the risk assessment exercise, the Water-Wastewater Asset Management group assesses risk associated with watermains using the risk scoring criteria outlined in the Corporate Asset Management Risk Assessment (CAMRA) model. Criteria for consideration includes factors such as; likelihood of failure, impact on users and the environment, financial risks and risks associated with compliance or social reputation of Niagara Region. There were no high-scoring risks identified during the 2021 full risk assessment. Any previously identified high-scoring risks have been mitigated through capital projects, operational adjustments, or through continual improvement initiatives.

Leak Detection Technologies for Transmission Mains

The three (3) most common methods of leak detection for transmission systems are in-line acoustic monitoring, non invasive acoustic monitoring and district metering. Costs associated with these methods vary depending on diameter and type of technology used and are detailed under the Financial Considerations section of this report.

For both in-line and non invasive acoustic monitoring, sensors discern the acoustic activity associated with leaks by sending acoustic pulses to receivers attached to pipe appurtenances. Leak location is estimated by the arrival time of the pulses. When in-line acoustic monitoring is used, condition and configuration of the pipe i.e. tubercles, valves, bends and pipe appurtenances may obstruct equipment, and terrain changes may make installation and removal of equipment difficult. In-line monitoring can be disruptive to operations. While non-invasive installations pose less disruption to service and flow, this type of installation is sensitive to interferences. With increasing pipe diameter, there is less accuracy of the sensors to detect leakage. All acoustic leak detection is sensitive to pipe material and diameter. Acoustic methods work best with

smaller diameter metallic pipes, and are less accurate with large diameter transmission mains. Approximately 89 per cent of Niagara Region's transmission mains are non-metallic, and all are large diameter.

District metering is an audit of the meters within a portion of the distribution system. Meters are installed to measure flow into and throughout a defined portion of the system, and flows are monitored to determine if leakage may be an issue. The installation of meters that detect bidirectional flow can also aid in locating leaks.

Due to the size and configuration of Niagara Region watermain it may not be economically feasible to conduct a complete inspection of the entire transmission system. Regional infrastructure valves for shutting down sections of main are often located a considerable distance apart, and isolation and draining of sections at a time can put a significant number of residents and businesses out of service. In addition to these concerns, pressure transients caused by putting a main back into service could cause breaks within the Area Municipal system.

Currently staff focus on areas where mains are known to be aged, have a higher occurrence of failure or the pipe material is most conducive to water loss investigation. Both infrastructure age and failure are well documented through the QMS Risk Assessment Process.

Alternatives Reviewed

The alternatives to reinstating a water loss committee to collectively review strategies for targeted investigation and reduction of water loss are:

1. Do nothing. Niagara Region could continue with current practices but this may be less effective in addressing the opportunities to further reduce any water loss.
2. Council could direct staff to procure external resources to undertake a comprehensive water loss assessment. This is not recommended without first re-establishing the water loss committee with Local Area Municipal staff participation to ensure that any assessment is comprehensive and has access to all available information.

Relationship to Council Strategic Priorities

Recommendations presented in this report relate directly to Council's Strategic Priority 4.1 of committing to "high quality, efficient and coordinated core services". Through coordinated efforts, the Region and Area Municipalities can collaborate on water loss reduction strategies.

Prepared by:

Erin Shisler
Water Process Specialist
W-WW Services

Recommended by:

Bruce Zvaniga P.Eng.
Commissioner of Public Works (Interim)
Public Works Department

Submitted by:

Ron Tripp, P.Eng.
Chief Administrative Officer

This report was prepared in consultation with John Brunet, Associate Director, Water Operations and Maintenance, and reviewed by Joe Tonellato, Director, W-WW Services.

Appendices

- | | |
|------------|---|
| Appendix 1 | Niagara Region – Watermain Statistics |
| Appendix 2 | 2007 Regional Water Loss Assessment Project |

PW 14-2022 Appendix 1 - Niagara Region Water Main Statistics

Water	FE	NOTL	Grimsby	NF	STC	PC	Welland	Thorold	Lincoln	West Lincoln	Pelham	Total
No. of connections to local infrastructure	79	109	26	97	144	25	117	50	54	3	35	739
Average age of infrastructure (water mains)	29.26	25.36	30.80	44.00	34.00	26.00	44.50	24.60	28.74	20.04	40.50	34
Km of Local water main	275.79	200.06	135.03	483.26	593.77	111.57	273.47	117.74	112.00	34.84	85.34	2423
KM of Regional water main	50.90	43.14	20.46	47.13	53.90	7.80	29.22	20.28	18.38	12.58	9.56	313
KM of water mains replaced over the past 10 years (2011)	5.50	0.06	2.50	0.08	12.77	1.41	0.74	2.57	0.06	0.52	0.00	26
KM of mains to be replaced over next 10 years	10.44	3.51	1.70	0.00	0.03	1.62	0.00	0.00	3.53	7.42	0.00	28
No. of Regional Underground Enclosures	129	98	76	133	180	30	149	74	57	32	15	973
No. of LAM Underground Enclosures	0	0	854	0	101	7	0	1	11	0	1	975

Region of Niagara

Regional Water Loss Assessment Project



JUNE 2007

FINAL REPORT



Executive Summary

With increasing regulatory requirements dealing with water quality, water takings, and full cost recovery the need to understand the performance of water systems has never been more prevalent. Efficient management (and operational control) of water distribution system includes managing real *and* apparent water losses. In November 2004, representatives from both the Region and its area municipalities attended a two day workshop on current industry best practices for dealing with water loss assessment, validation, measurement and control. The group identified that a proper assessment (and validation) of the water loss levels within each AM's water system should be initiated.

The Region contracted Veritec Consulting Inc. to complete water balances for each of the area municipalities. This report highlights the results of the water balances completed for each participating area municipality.

Balances were completed using PIFastCalc for Canada, a licensed software tool incorporating the standard water balance procedure and terminology adopted by both the AWWA and Canadian InfraGuide. PIFastCalc also calculates many benchmarking Performance Indicators (PIs). With respect to validation PIFastCalc for Canada incorporates confidence intervals that highlight data quality.

Non-Revenue Water (NRW) is a “Basic” financial PI. Excluding demands in the City of Welland, the project identifies that collectively, the percentage of NRW in the Region is approximately 14% (i.e, 86% of water sold by the Region is accounted for by billed consumption in the area municipalities). The components of NRW are:

- ✓ Unbilled, Authorized Consumption,
- ✓ Apparent Losses, and
- ✓ Real Losses

Individually the percentage of NRW in the area municipalities ranges from 0% to 37%. Percentages of NRW, however, should not be used to compare and contrast the performance of one system versus another.

The Infrastructure Leakage Index (ILI) is a ratio of the volumes of Current Annual Real Losses (CARL) to Unavoidable Annual Real Losses (UARL). Unavoidable losses vary from system to system based on their characteristics (e.g. kilometers of water main, average system pressures, etc.). Calculated values of ILIs may facilitate the comparison of systems with respect to others as well as benchmark individual performance for annual comparisons.

The World Bank Institute and AWWA have developed general descriptions, guidelines, and recommendations based on the Infrastructure Leakage Index and these may be reviewed by each municipality based on its calculated ILI.

Table of Contents

<i>Executive Summary</i>	i
<i>Table of Contents</i>	ii
1.0 Introduction	1
2.0 Project Methodology	2
3.0 Results: Phase I – Data Collection	
3.1.0 Water Supplied	4
3.2.0 Billed, Authorized Consumption Metered	6
3.3.0 Billed, Authorized Consumption Un-metered	8
3.4.0 Unbilled, Authorized Consumption Metered	8
3.5.0 Unbilled, Authorized Consumption Un-metered	8
3.6.0 Unauthorized Consumption	8
3.7.0 Apparent Loss – meter under-registration	9
3.8.0 Apparent Loss – customer meter data handling errors	10
3.9.0 Mains Length	10
3.10.0 Number of Hydrants	11
3.11.0 Number of Separately Billed Properties	11
3.12.0 Number of Unbilled Service Connections	11
3.13.0 Average pipe length, property line to billing meter	11
3.14.0 Average pressure when system pressurized	12
3.15.0 Assessed Marginal Costs	
3.15.1 Assessed Marginal Costs of UACM	13
3.15.2 Assessed Marginal Costs of UACU	13
3.15.3 Assessed Marginal Costs of UC	13
3.15.4 Assessed Marginal Costs of ALMUR	13
3.15.5 Assessed Marginal Costs of ALDCD	13
3.15.7 Assessed Marginal Costs of RL	13
3.16.0 Costs of Operating the System	14
4.0 Results: Phase II – Water Balances	
4.1.0 Financial Performance Indicators	
4.1.1 Non-Revenue Water as % of System Input by Volume	14
4.1.2 Non-Revenue Water as % of System Input by Value	16
4.2.0 Operational Performance Indicators	
4.2.1 Apparent Losses as a % of System Input	16
4.2.2 Real Losses in litres/service connections/day	17
4.2.3 Real Losses as Infrastructure Leakage Index (ILI)	18
5.0 Discussion	
5.1.0 World Bank Institute Target Matrix	20
5.2.0 AWWA Guidelines	20
6.0 Recommendations	22

Table of Contents (con't)

Appendices

Appendix A	IWA Terminology
Appendix B	Supply Meter Accuracy Reports
Appendix C	Draft Report on Meter Accuracy in Niagara Region
Appendix D	NRW Trends
Appendix E	Component Analysis to Calculate Unavoidable Annual Real Loss
Appendix F	PIFastCalc Results – Fort Erie
Appendix G	PIFastCalc Results – Grimsby
Appendix H	PIFastCalc Results – Lincoln
Appendix I	PIFastCalc Results – Niagara Falls
Appendix J	PIFastCalc Results – Niagara-on-the-Lake
Appendix K	PIFastCalc Results – Pelham
Appendix L	PIFastCalc Results – Port Colborne
Appendix M	PIFastCalc Results – St. Catharines
Appendix N	PIFastCalc Results – Thorold
Appendix O	PIFastCalc Results – West Lincoln

1.0 INTRODUCTION

With increasing regulatory requirements dealing with water quality, water takings, and full cost recovery the need to understand the performance of water systems has never been more prevalent. Efficient water system(s) management and operational control includes managing real *and* apparent water losses. The now defunct term “unaccounted-for-water” undermined efficiency in so far as the term “unaccounted-for” failed to identify causes or solutions. The term non-revenue water underlines inefficiencies and highlights the real cost(s) of water losses.

Recognizing both costs and regulatory requirements, successful water loss programs must be two-fold; firstly, establishing the level of water losses and secondly, establishing programs to control and/or reduce these losses. The former justifies the investment in water loss reduction and control programs and may be used to track and report on project successes as well as identify program short-comings.

In 2004, the Regional Municipality of Niagara created a working group consisting of Regional staff and representatives of its twelve area municipalities (AMs). The purpose of the “*Water Loss Reduction Task Force*” is to share experiences regarding water loss levels and strategies. In November 2004, a two day workshop on current industry best practices for dealing with water loss assessment, validation, measurement and control was sponsored by the Region.

The task force identified that a proper assessment and validation of the water loss levels within each AM’s water system should be initiated. The AWWA and the Canadian InfraGuide have both adopted the International Water Association’s (IWA) Standard Water Balance.

Using PIFastCalc for Canada V1, a licensed software package purchased by the Region on behalf of its area municipalities, water balances were completed based on the data provided by the area municipalities themselves.

The following report summarizes the data collected as well as the results of the water balances with respect to the benchmarking performance indicators calculated within the software package. Individual copies of the PIFastCalc outputs are included in the appendices.

2.0 PROJECT METHODOLOGY

The goal of the Water Loss Assessment Project is to provide an appreciation of the components of water loss across the region and to identify areas in which losses can be addressed and ultimately reduced. Traditionally many distribution systems describe water losses as the percentage of unaccounted-for-water based on the simple calculation illustrated below:

$$\% \text{ of Unaccounted-For-Water} = \frac{\text{Billed Consumption}}{\text{Water Purchased}}$$

The IWA/AWWA Standard Water Balance (Figure 1) accounts for the total volume of water supplied by identifying the various components¹ of both consumption as well as water losses using either measured or estimated quantities

Own Sources	System Input	Water Exported	Authorised Consumption	Billed Authorised Consumption	Revenue Water	Billed Water Exported
		Water Supplied				Billed Metered Consumption
Water Imported				(allow for known errors)	Water Losses	Unbilled Authorised Consumption
	Apparent Losses	Unbilled Metered Consumption				
	Real Losses	Unbilled Unmetered Consumption				
		Unauthorised Consumption				
		Customer Metering Inaccuracies				
		Leakage on Mains				
		Leakage and Overflows at Storages				
Leakage on Service Connections up to point of Customer Metering						

Figure 1: Overview of the Components of the IWA/AWWA Standard Water Balance

PIFastCalcs is a licensed software package, purchased by the Region on behalf of its area municipalities, underlying the water loss assessment program. As evidenced in Figure 2 on the following page the standard water balance methodology is incorporated into the software. Based on the water balance, PIFastCalcs automatically calculates “Performance Indicators” (PIs) to assess both real and apparent water losses. And these performance indicators benchmark current losses allowing each area municipality to compare its own performance year-to-year as well as with other systems (locally and internationally).

Tools (e.g., process reliability bands and 95 % confidence limits) highlight the potential need to further evaluate and/or verify data as well as track the overall effect of uncertainty regarding the data used to derive the water balance.

¹ Appendix A includes the standard terminology of each of the balance’s components as included in PIFastCalcs.

Figure 2: Copy of the “Water Balance & PIs” worksheet from PIFastCalc V1a

3.0 RESULTS: PHASE I – DATA COLLECTION

The following section summarizes the data collected with respect to the various components of the standard water balance.

3.1.0 Water Supply

The Regional Municipality of Niagara itself is responsible for bulk water supply, treatment, transmission, and storage. Therefore the Region directly provided a monthly summary of metered volumes for each of its thirty-three billing meters. Based on the billing equations provided (Table 1) the data was used to derive the total volume of water supplied to each area municipality per month.

Figure 3 illustrates the breakdown of nearly 74.5 million cubic meters sold in 2005.




Figure 3: Water Supply in Niagara Region

The Region also provided copies of the meter calibration tests completed in 2005 (Appendix B)². Meters for accuracy reports were provided are highlighted in Table 1.

Table 1
Regional Billing Equations

Area Municipality	Billing Equation (Accuracy Reports provided for highlighted meters)
Fort Erie	2T1+2T2-2S
Grimsby	6T1-6D1- 6D2
Lincoln	5D7+5D8+6D1
Niagara Falls	1T1+1T2- 1D1-1D2-1D3-1D4
Niagara-on-the-Lake	5D5+5D6+ 1D1+1D2+1D3 +5D9
Pelham	3D1+3D2
Port Colborne	4T1+4T2
St. Catharines	(5T1+5T2+5T3+5T4+5T5)- 5D1-5D2-5D3-5D4-5D5-5D6-5D7-5D8-5D9
Thorold	1D4+ 5D1-5D2+5D3 +5D4
Welland	3T1+3T2+3T3-3D1-3D2
West Lincoln	6D2

² Veritec distinguished between calibration reports for the meter vs. loop calibration reports.

Table 2 summarizes the results of the meter accuracy tests. Each meter is tested at several flow rates. The range of accuracies recorded for each individual flow rate was between 96.5 and 101.6 percent³. Based on this data, and that meter accuracy reports for all the meters were not available, the confidence interval used in the PIFastCalcs software for the Region's meters is +/- 3%.

Table 2
Summary of Supply Meter Accuracy Results

Meter ID	Date Tested	% Accuracy					
		As Found			As Left		
		Avg.	Min.	Max.	Avg.	Min.	Max.
6D2	5/24/2005	99.7	97.0	101.0			
1D1	5/4/2005	97.0	94.3	101.0	99.3	96.5	101.0
	10/13/2005	99.7	99.7	101.0			
1D2	5/4/2005	99.8	97.0	100.6			
1D3	5/20/2005	101	100.8	101.3			
1D4	5/4/2005	49.8	9.8	101.3	100.2	98.2	101.1
	10/13/2005	0.0	0.0	0.0	100.4	99.9	100.9
5D1	5/20/2005	100.1	99.7	100.6			
5D2	5/20/2005	99.4	98.8	100.0			
5D3	5/24/2005	100.7	99.3	101.6			
5D5	5/20/2005	100.0	99.7	100.4			
5D6	5/20/2005	99.4	97.5	101.0			
OVERALL ⁴		70.5 (100.0)	0.0 (97.0)	101.6 (101.6)	100.0	96.5	101.1

Accuracy reports did highlight problems with the Mewburn Road meter. This meter records flows out of the Niagara Falls system and into the Niagara-on-the-Lake system. Figure 4 suggests that the meter was failing to record demands in N-O-T-L prior to being calibrated in May '05 and that it began failing again within weeks of the calibration. The failure of this meter may lead to overestimating supply to Niagara Falls and underestimating supply to N-O-T-L⁵.




Figure 4: Monthly Volumes from Mewburn Rd.

³ Excludes meters that required calibration.

⁴ Overall results for the "As Found" are summarized both with (and without) the meters requiring calibration.

⁵ Based on the original billing equations provided it also appears that flows recorded at 1D4 were subtracted from Niagara Falls but were not added to Niagara-on-the-Lake. It is likely that issues

Data for the remainder of the balances were collected from the individual area municipalities. Table No. 3 on the following page summarizes, based on the input parameters of the PIFastCalc software, which area municipalities provided supporting data for each of these parameters.

3.2.0 Billed, Authorized Consumption – Metered (BACM)

All municipalities provided at least partial data with respect to BACM⁶. The information provided ranged from complete billing databases to a single figure identified as the annual volume of water sold.

With respect to establishing the water balances, errors introduced into the value of BACM may include the following:

- ✓ Meter Accuracy,
- ✓ Data Handling,
- ✓ Estimated Readings, and
- ✓ Meter Lag Times

Meter accuracy and data handling errors are specifically addressed within the framework of the IWA Standard Water Balance and therefore are not evaluated with respect to the defining confidence in the value of BACM.

Estimated readings and meter lag times may be used to indicate confidence in the value of BACM. The percentage of estimated reads reported by the AMs ranged from none (or, at least, no data was provided) to 16.4 % in St. Catharines. Municipal methods for estimating ranged from using the previous month, an average of the previous six months, or even doubling the previous bill (to get the customer's attention). It is impossible to quantify or address errors due to estimated reads without copies of the billing database.

Meter lag times introduce a difference between *when* water is consumed and *when* it is billed. As an example, in an analysis of the Niagara Falls billing approximately 7.6 % of billing in 2004 relates to water consumed prior to the start of the year, and similarly, 7.3 % of 2004's consumption is derived based on meter readings recorded in 2005 (assuming that water is consumed equally throughout the period between meter readings). On an annual basis, it is often assumed these values will counter balance each other. Where possible, based on the datasets provided, meter lag times were addressed.

surrounding this meter account for N-O-T-L reporting more water sold within the municipality than purchased from Region.

⁶ Billing data for Welland contained a limited number of accounts (~530). Much of Welland remains un-metered and customers are billed a flat rate. There was not deemed enough data to complete a water balance for Welland.

Table 3
Summary of Data Collected by PIFastCalc Input Parameters

Input Parameters for PIFastCalc (refer to Appendix A for Definition of Terminology)		Fort Erie	Grimsby	Lincoln	Niagara Falls	N-O-T-L	Pelham	Port Colborne	St. Catharines	Thorold	Wainfleet	Welland	West Lincoln
WOS	Volume from Own Sources	All water supplied via the Regional Municipality of Niagara											
WI	Water Imported	√	√	√	√	√	√	√	√	√	√	√	√
BACE	Billed, Authorized Consumption Exported	√	√	√	√	√	√	√	√	√	√	√	√
Assessed marginal cost of RL		√	√	√	√	√	√	√	√	√	√	√	√
BACM	Billed, Authorized Consumption Metered	√	√	√	'04	P	P	√	'04	P			√
BACU	Billed, Authorized Consumption Un-metered	-	√										-
UACM	Unbilled, Authorized Consumption Metered												
UACU	Unbilled, Authorized Consumption Un-metered	√	√					√					
UC	Unauthorized Consumption	√	√					√		-			√
ALMUR	Apparent Loss – meter under-registration		√			√		√					
ALDCD	Apparent Loss – customer meter data handling errors												
Lm	Mains Length	√	√	√	√	√	√	√	√	√		√	√
Nh	Number of Hydrants	√	√	√	√	√	√	√	√	?			√
Nb	Number of Separately Billed Properties	√	√	√	√	√	√	√	√	√		√	√
R	Ratio of billed Service Connections to Billed Properties												
Nu	Number of Unbilled Service Connections	√					√			√			√
Lp	Average pipe length, property line to billing meter	√	√		√	√			√	√			√
P	Average pressure when system pressurized	√	√		√	√		√	√				√
Retail Cost / m ³ (excluding base rate)	Assessed marginal cost of UACM	√	√				√	√		√			
	Assessed marginal cost of UACU												
	Assessed marginal cost of UC												
	Assessed marginal cost of ALMUR												
	Assessed marginal cost of ALDCD												
Costs of Running system over period (excluding capital projects)			√	√		√				√		√	√

3.3.0 Billed, Authorized Consumption – Un-metered (BACU)

With the exception of identifying 179 flat rate customers in one specific municipality no details were provided with respect to what the flat rate was or what the estimated consumption was equal to. The remaining AMs provided no details regarding the volume of BACU. There are several flat rate customers in Welland.

3.4.0 Unbilled, Authorized Consumption – Metered (UACM)

The Town of Grimsby identified street sweeping and sewer flushing as components of UACM. Assumedly the town provides a mobile hydrant meter but does not invoice the contractors who would be working for the Town.

3.5.0 Unbilled, Authorized Consumption – Unmetered (UACU)

Identified sources of Unbilled, Authorized Consumption – Unmetered primarily relate to hydrant usage for the following:

- ✓ Water Main Construction and Repairs (e.g. dewatering & flushing),
- ✓ Water Service Repairs,
- ✓ Fire Fighting & Training, and
- ✓ Street Cleaning & Sewer Flushing (i.e., re-filling equipment)

Figure 3 illustrates calculated estimates provided by Grimsby.

Components of Authorised Consumption	Components in MI				Total	Additional information on sources of data and basis of estimates	
	Billed Metered	Billed Unmetered	Unbilled Metered	Unbilled Unmetered		E = estimated	
						R = Based on recordings	
Hydrant Usage (mobile meter)			2.12		2.12	R = Based on recordings, less Avertex	
New Construction/Rehab				2.45	2.45	E = estimated: 6 jobs x 3/job x 500 gpm x 1 hr.	
Fire/Training				13.64	13.64	E = estimated: 1 fire/yr. 2,000 Imp. Gal; Training 68 hrs/yr @ 1,000 gpm = 3,000,000 Imp. Gal	
Hydrant Flushing				18.18	18.18	E = estimated: dead-end 20 locations x 6/yr. x 3,000 Imp Gal + 3,000,000 Imp. Gal	
Hydroguard				2.95	2.95	E = estimated: 20 gpm x 6-4 hrs/day (50% of this in winter)	
Recreation				0.47	0.47	E = estimated: 3 parks approx. 6 gpm x 2 hrs/day x 5 months	

Figure 3: Portion of the “Consumption” worksheet extracted from Grimsby’s Balance

Table 4 on the following page illustrates that Grimsby and Port Colborne provided breakdowns of their estimates that equate to 1.17% and 6.7 % of Water Supply, respectively. Thorold, Niagara-on-the-Lake, and Fort Erie identified relevant sources of UACU in their system and the latter provided an overall estimate equal to 5 % of Water Supply. The default estimate in PIFastCalcs is equal to 1.25% of Water Supplied.

In the absence of estimates made by the municipality themselves the balances accept the default estimate. The 95 % confidence limits of +/- 100 % and process reliability band of “D” highlight the uncertainty with regards to this component.

3.6.0 Unauthorized Consumption (UC)

Common components of unauthorized consumption are by-pass tampering, unauthorized use of fire services, and unauthorized use of hydrants.

The default estimate in PIFastCalcs is equal to 0.25 % of Water Supply (+/- 100%). Both Grimsby and Fort Erie estimated 1 % whereas West Lincoln estimated 0.02 %. Port

Colborne suggests approximately 5 household per year tamper with the meter by-pass but did not estimate the amount of loss. In the absence of a provided estimate the default value is accepted.

Table 4
Summary of Data Collected Pertaining to UACU

	Estimates in ML/year √ indicates the AM recognizes this as a use but did not provide an estimate									
	Fort Erie	Grimsby	Lincoln	Niagara Falls	N-O-T-L	Pelham	Port Colborne	St. Catharine	Thorold	West Lincoln
Water Main Construction & Repairs		7.8					1.8			
Water Service Repairs							94.2			
Water Quality	√						86.4		√	
Hydrant Flushing	√	18.4					13.1			
Blow-offs					√				√	
Fire Fighting / Training	√	13.6			√		44.4		√	
Sewer Flushing	√						14.6		√	
Street Cleaning	√								√	
Recreation		0.6					6.4			
TOTAL	197	40.4	-	-	-		260.9	-	-	-

3.7.0 Apparent Losses – Meter Under-Registration (ALMUR)

As meters deteriorate with age and usage they are more likely to under-register water use. Because of the relative small number of meter accuracy reports provided an aggregated analysis of the tests provided by Grimsby, Niagara-on-the-Lake, and Port Colborne (Appendix C) was completed. The results of this analysis are summarized below.

Table 5
Calculated Values of Meter Under-Registration & 95% Confidence Limits

	% Under Registration	95 % Confidence Limits
Meters < 1"	0.5	7
Meters > 1"	1.0	7

Most municipalities provided a breakdown of consumption based on accounts for which meters are read based on cycles (e.g., 3 or 4 times per year) and those that are read monthly. In these cases the former group was associated with meters smaller than one inch and the latter with meters larger than one inch. If no breakdown was provided a 70/30 ratio was estimated and an overall value of 0.6% under-registration was assumed (with 95% confidence limits equal to +/- 7 %).

3.8.0 Apparent Losses – Customer Data Handling (ALDCD)

Across the Region, numerous methods are employed to retrieve and manage meter readings. Meter reads are collected using customer reading cards, physical meter reads, roll dial remotes, touchpads, and radio-reads. Billing software packages include: Easyroute, USTI Water System, Vadium, Vailtech, and AS400. Niagara Falls maintains a customized database.

Sources of customer data handling errors are numerous and may collectively introduce significant error. Specifically, examples of the data handling errors which were identified included:

- ✓ In Niagara Falls approximately 2% of records in the raw database were duplicates.
- ✓ In Grimsby the summary spreadsheets of 2004 and 2005 contained inconsistent data pertaining to periods where meter reads bridged the calendar year; representing a potential error of approximately 1%.
- ✓ In West Lincoln the original data submitted mismatched data billed monthly in 2004 with data billed quarterly in 2005. The 2005 summary provided included regional billing data from 2004.
- ✓ Simple errors in arithmetic or difference in numbers, depending on the source used

These examples are of errors that have been identified and corrected within the balance but undoubtedly there are errors that remain undetected – either because they are inherent in the data provided or because not all the data was provided

3.9.0 Length of Water Mains (Lm)

The total length of water mains in the reporting AMs is equal to approximately 2,000 kilometers.

Age and material are not specifically required in the water balance. Nonetheless most municipalities provided data on materials and Figure 4 provides an overall breakdown of the mains across the Region.

It is assumed that the inventory of water mains is most likely accurate to within +/- 2 %.




Figure No. 4 – Water Main Materials

Some inaccuracies may be as a result of some AM including Regional water mains while others may not. Additionally, databases may be out of date with regards to new construction.

3.10.0 Number of Hydrants (Nh)

There are approximately 10,500 hydrants in total. All of the AMs provided this data.

3.11.0 Number of Separately Billed Properties (Nb)

PIFastCalc uses two values, the Number of Separately Billed Properties and the Ratio of Service Connections to Billed Properties (R) to calculate the Number of Billed Service Connections (Ns). Most AMs provided the number of billed services directly and a ratio of 1:1 is used. The total number of separately billed properties is equal to 113,228 – equivalent to the number of meters.

3.12.0 Number of Unbilled Service Connections (Nu)

Unbilled service connections may include the following:

- ✓ Fire connections, and
- ✓ Un-metered municipal connections

Most AM did not provide any data with regards to the number of unbilled service connections. Table 6 summarizes the data that was provided.

Table 6
Summary of Reported Unbilled Service Connections

Area Municipality	Number of Unbilled Service Connections (Nu)
Fort Erie	100
Port Colborne	28
Thorold	25
West Lincoln	6

3.13.0 Average Pipe Length – Property Line to Meter (Lp)

Private service pipe length is an important consideration in the calculation of the performance indicators assessing real losses. This is because it is generally accepted that the majority of leaks occur on service connections. Table 7 summarizes the reported data.

Table 7
Summary of Reported Lengths (in meters) – Property Line to Meter (Lp)

Area Municipality	Lp	Area Municipality	Lp
Fort Erie	10	St. Catharines	7
Grimsby	10	Thorold	10
Niagara Falls	18	West Lincoln	9
N-O-T-L	8.5		

3.14.0 Average System Pressure (P)

The average system pressure entered in PIFastCalc should be a weighted average determined, for example, based on a list of static hydrant pressures many AM record during hydrant inspections. Table 8 summarizes the data provided which in some cases was simply a range of pressures.

Table 8
Summary of Reported Pressures (in PSI)

	Pressure(s)
Fort Erie	75
Grimsby	75
Lincoln	-
Port Colborne	58
Niagara Falls	94
Niagara-on-the-Lake	
<i>Zone 1</i>	44 – 69
<i>Zone 2</i>	56 – 97
<i>Zone 3</i>	45 – 102
<i>Zone 4</i>	66 – 92
St. Catharines	
<i>Zone 1</i>	50 – 100
<i>Zones 2 & 3</i>	50 – 80
Thorold	62
West Lincoln	62

3.15.0 Assessed Marginal Costs

Within PIFastCalc several marginal costs are used to attempt to more accurately reflect the actual costs of various components of NRW.

Unbilled, authorized consumption is typically valued at the cost which the AM purchases the water from the Region. Justification of this is that the AM, by not billing the customer, is assuming the costs. The costs of apparent losses is equal to the rate which the AM charges customers because this water is in fact being consumed by customers (sewer surcharges may also be applicable). Unauthorized consumption such as theft may be valued at a rate equal to the retail costs of water without the applicable sewer

surcharge. Real losses are valued at the wholesale costs of water because this water is not consumed or used by anyone – eliminating the real losses eliminates the demand!

Many AM may have never considered assessed marginal costs based on the components of the IWA Water Audit and therefore could not identify costs according to this breakdown.

3.15.1 Assessed Marginal Costs of UACM

The rate(s) at which the individual AMs re-sell water vary. If base rates apply it may be difficult to directly distinguish the marginal costs of UACM. Table 9 summarizes the data collected.

Table 9
Summary of Reported Water Rates

	Rate(s)
Grimsby	\$0.73/m ³
Port Colborne	\$0.756/m ³
Thorold	\$47.76 for the first 27 m ³ (\$1.769/m ³)
	\$0.742/m ³ in excess
West Lincoln	\$1.109/m ³

3.15.2 Assessed Marginal Costs of UACU

In most cases the assessed marginal cost of unbilled, authorized consumption will be the same regardless of whether it is metered or un-metered. Possible exceptions may include considerations of sewer surcharges related to water consumption.

3.15.3 Assessed Marginal Costs of UC

No data.

3.15.4 Assessed Marginal Costs of ULMUR

No data.

3.15.5 Assessed Marginal Costs of ALDCD

No data.

3.15.6 Assessed Marginal Costs of RL

The assessed marginal cost of real losses is equal to the wholesale water rate at which the AM purchase water from the Region. This rate was equal to \$0.40/m³ and \$0.446/m³ in 2004 and 2005, respectively.

3.16.0 Costs of Running the System Over the Period of the Balance

The costs of running the system should be determined based on the operational costs plus the internal manpower costs minus the capitalized costs of self-constructed assets. Reported costs are summarized in Table 10 on the following page.

Table 10
Summary of Reported Costs (\$) of Running Water System(s)

	Reported Costs
Grimsby	\$3,166,740
Lincoln	\$3,505,747
Thorold	\$2,648,400
West Lincoln	\$ 372,750

4.0 RESULTS: PHASE II – WATER BALANCES

The following sections highlight the results of the individual water balances included in Appendices F through O.

4.1.0 Financial Performance Indicators

4.1.1 Non-Revenue Water as a Percentage of System Input Volume

Percentage of Non-Revenue Water by Volume is considered a “Basic Level” Financial Performance Indicator. NRW may be particularly misleading with regards to comparing one system to another.

Region wide the combined volume of BACM reported accounts for approximately 85% of the water purchased from the region by the reporting area municipalities. Individually the percentage of NRW within the area municipalities ranges from -1.3 % to 36.8 %.




Figure 5: Percentage of Aggregated NRW in Participating Area Municipalities

Figure 6 illustrates the values of NRW in each area municipality. Confidence intervals are derived based on the confidence attributed to both the Region’s billing and the billing meters. The negative value calculated for Niagara-on-the-Lake may be accounted-for in part due to meter error discussed on page 5 of this report.





Figure 6: Non – Revenue Water as a Percentage of System Input Volume

Insofar as trends in NRW may be more telling than an annual volume, a monthly analysis was completed for those municipalities that provided sufficient data (Appendix D). Figures 7a & 7b illustrate two examples of monthly variations in NRW which suggest different potential causes.



Figures 7a & b – Trends in Non-Revenue Based on Monthly Volumes Purchased & BACM

Figure 7a (Grimsby) suggests excessive unbilled water use in the summer period accounting for approximately 5 % of Water Supplied annually. Use of estimated reads, based on average annual consumption, may also account for Grimsby's trend. Figure 7b (Port Colborne) suggests unbilled water use underlying billed consumption throughout the year. This underlying water use may be attributable to several factors including leakage.

4.1.2 Non-Revenue Water as % of System Input by Value

As identified any Section 3.16 of this report many municipalities did not provide the costs of running the system during the period of the balance. Table 11 summarizes the results.

Table 11
Non-Revenue Water as % of System Input by Value

	% of Non-Revenue Water as % of System Input by Value
Fort Erie	8.4 % (+/- 25.2 %)
Grimsby	3.6 % (+/- 35.6 %)
Lincoln	14.7 % (+/- 12.8 %)
Thorold	13.1 % (+/- 25.0 %)

4.2.0 Operational Performance Indicators

4.2.1 Apparent Losses as a % of Water Supply

The recommended Performance Indicator for Apparent Losses is the % of Apparent Losses relative to Water Supply. Apparent losses include meter under-registration, errors in customer data handling, and unauthorized consumption. The values calculated for each of the municipalities are identified below.

Table 12
Summary of Apparent Losses by Area Municipality

	% of Apparent Losses	95 % Confidence Limits
Fort Erie	1.4	35.1%
Grimsby	2.1	36.6%
Lincoln	0.8	31.9%
Niagara Falls	0.7	36.6%
Niagara-on-the-Lake	0.9	30.0%
Pelham	0.8	33.6%
Port Colborne	0.7	18.7%
St. Catharines	0.8	33.5%
Thorold	0.7	34.1%
West Lincoln	0.6	6.0%

Differences in apparent losses primarily reflect the estimated percentages of unauthorized consumption (page 9). Values of meter-under registration were assumed equal in all the

municipalities and no municipalities provided any estimates regarding data handling errors. Therefore, because Fort Erie and Grimsby estimated unauthorized consumption to be higher than the default value their apparent losses are greater.

4.2.2 Current Annual Real Losses in litres/service connection/day

Figure 8a illustrates the Current Annual Real Losses (CARL) in each of the area municipalities. CARL are calculated by subtracting authorized consumption and apparent losses from the total volume of water supplied. The recommended Performance Indicator for Real Losses (Figure 8b) expresses the value of CARL in litres/service connection/day, when the system is pressurized⁷.




Figure 8a & b: Comparative, calculated values of Current Annual Real Losses expressed in (a) ML/yr, and (b) litres/service connection/day when pressurized

As illustrated in Figures 8a and b the volume of real losses in itself may be misleading in comparing area municipalities because it fails to account for the relative size of the

⁷ In the case of all these audits the systems are pressurized 100% of the time.

distribution systems. By expressing losses in terms of litres/connection per day when the system is pressurized the volume of losses is put into context. Nonetheless the expression of CARL in these terms is considered a Level 1 (or basic) performance indicator because it does not account for differences in system pressure which significantly influence water losses due to leakage.

4.2.3 Infrastructure Leakage Index (ILI)

The advanced (Level 3) operational performance indicator for real losses is the Infrastructure Leakage Index (ILI). The ILI is a ratio of the CARL to Unavoidable Annual Real Losses.

Unavoidable Annual Real Losses (UARL)

Some “measure” of water loss due to leakage is unavoidable in all water distribution systems. Background leakage, including small leaks and weeps, is unavoidable in that individual sources are either undetectable and/or the cost-to-benefit does not justify repair/replacement. In addition there are unavoidable losses due to reported/unreported leakage. These losses relate to the time between when leak(s) occurs and is repaired.

Unavoidable losses are controllable through various best-management-practices (e.g., speed and quality of repairs, active leakage control). The calculated values of UARL assume best-management-practices. Appendix E provides a summary of the component analysis for calculating UARL.

Based on the assumptions described in Appendix E, the value of UARL in each area municipality is calculated based on the following:

- total length of water mains
- total number of service connections
- total length of customer supply pipe, and
- the average system pressure

Figure 9, on the following page, illustrates the components of CARL in each of the area municipalities. Potentially recoverable losses represent the difference between CARL and UARL.

The Infrastructure Leakage Index (ILI) provides guidance as to how well real losses are being managed (in terms of repairs, active leakage control and infrastructure management) at the current operating pressure⁸.

⁸ The ILI does not imply that pressure management in a system is optimal, or economic. If system pressures are excessive, or subject to surges, then pressure management may result in additional benefits for real losses management - in particular, a reduction in new burst frequency and annual repair costs, and a reduction in flow rates of existing leaks. So even if a low ILI is being achieved, there may still be opportunities to reduce annual real losses by improved pressure management.




Figure 9: Illustration of the components making up the Current Annual Real Losses (CARL)




Figure 10: Illustration of Calculated ILI for each area municipality

An ILI equal to 2, for example, suggest Current Annual Real Losses (CARL) are two-times greater than the Unavoidable Annual Real Losses (UARL) if best-management-practices were followed. Figure 10 on the preceding page illustrates the calculated ILIs of each of the participating area municipalities.

Based on the calculated ILIs and on the guidelines provided by both the World Bank Institute and the AWWA the following section provides some general discussion of the real losses in the area municipalities.

5.0 DISCUSSION

5.1.0 World Bank Institute Target Matrix / Banding

PIFastCalc identifies where the calculated ILI fits into a target matrix developed by the World Bank Institute and incorporated into its NRW training modules. These guidelines are included in the individual reports in Appendices F through O and summarized in the following table. In the WBI's target matrix, general descriptions are made which describe a system's performance in real loss management based on its calculated ILI.

Table 13
General Description of Real Loss Management Performance

ILI Range	Band	Area Municipality	ILI	General description of Real Loss Management Performance
< 2	A	Niagara-on-the-Lake	-0.6	Further loss reduction may be uneconomic unless there are shortages; careful analysis needed to identify cost-effective improvement
		Grimsby	1.3	
		Lincoln	1.6	
2 to 4	B	Niagara Falls	2.2	Potential for marked improvements; consider pressure management, better active leakage control practices, and better network maintenance
		St. Catharines	2.3	
		Pelham	2.4	
		West Lincoln	2.5	
		Fort Erie	2.7	
4 to 8	C	Thorold	5.6	Poor leakage record; tolerable only if water is plentiful and cheap; even then, analyze level and nature of leakage and intensify leakage reduction efforts
>8	D	Port Colborne	8.7	Very inefficient use of resources; leakage reduction programs imperative and high priority

5.2.0 AWWA General Guidelines

Table 14, on the following page, summarizes the general guidelines developed by AWWA's Water Loss Committee which again categorize system based on the calculated ILI.

Table 14
AWWA General Guidelines Pertaining to Infrastructure Leakage Index

ILI Range	Band	Area Municipality	ILI	Water Resource Considerations	Operational Considerations	Financial Considerations
< 2	A	Niagara-on-the-Lake	-0.6	Available resources are greatly limited and are very difficult / environmentally unsound to develop	Operating with system leakage above this level would require expansion of existing infrastructure and/or additional water resources to meet demand	Water resources are costly to develop or purchase; ability to increase revenues via water rates is greatly limited because of regulation or low ratepayer affordability
		Grimsby	1.3			
		Lincoln	1.6			
2 to 4	B	Niagara Falls	2.2	Water resources are believed to be sufficient to meet long-term needs, but demand management interventions (leakage management, water conservation) are included in long-term planning	Existing water supply infrastructure capability is sufficient to meet long-term demand as long as reasonable leakage management controls are in place	Water resources can be developed or purchased at reasonable expense; periodic water rate increases can be feasibly imposed and are tolerated by the customer population
		St. Catharines	2.3			
		Pelham	2.4			
		West Lincoln	2.5			
		Fort Erie	2.7			
4 to 8	C	Thorold	5.6	Water resources are plentiful, reliable, and easily abstracted	Superior reliability, capacity and integrity of the supply infrastructure make it relatively immune to shortages	Cost to purchase or obtain/treat water is low, as are rates charged to customers
>8	D	Port Colborne	8.7	Although operational and financial considerations may allow a long-term ILI greater than 8.0, such a level of leakage is not an effective utilization of water as a resource. Setting a target level greater than as an incremental goal to a smaller long-term target – is discouraged		

6.0 RECOMMENDATIONS

The water balances have been completed based on the data provided. In all cases it is advisable to update and complete the data.

With regards to managing real losses (leakage and overflows from systems up to the point of customer metering or consumption) best management practices recognize the following:

- ✓ Pressure Management
- ✓ Speed and Quality of Repairs
- ✓ Active Leakage Control, and
- ✓ Pipeline and Assets Management

PIFastCalc's recommendations are based on the World Bank Institute's ILI Bands. Individual municipalities are grouped in these bands in Tables 13 and 14. Table 15 is reproduced from the ILI Guidelines worksheet within the software.

Table 15
WBI Recommendations

WBI Recommendations for BANDS	A	B	C	D
Investigate pressure management options	Yes	Yes	Yes	
Investigate speed and quality of repairs	Yes	Yes	Yes	
Check economic intervention frequency	Yes	Yes		
Introduce/improve active leakage control		Yes	Yes	
Identify options for improved maintenance		Yes	Yes	
Assess Economic Leakage Level	Yes	Yes		
Review break frequencies		Yes	Yes	
Review asset management policy		Yes	Yes	Yes
Deal with deficiencies in manpower, training and communications			Yes	Yes
5-year plan to achieve next lowest band			Yes	Yes
Fundamental peer review of all activities				Yes

Appendix A

IWA Water Balance Terminology

Volume from Own Sources:	The volume of water input to a system from the Water Supplier's own sources
Water Imported or Exported:	The volume(s) of bulk transfers across operational boundaries
System Input Volume:	The volume input to that part of the water supply system to which the water balance calculation relates, corrected for known errors. Equal to VOLUME FROM OWN SOURCES plus WATER IMPORTED
Water Supplied:	Equal to the SYSTEM INPUT VOLUME minus WATER EXPORTED
Authorized Consumption:	Volume of metered and/or un-metered water taken by registered customers, the water supplier and others who are implicitly or explicitly authorized to do so by the water supplier, for residential, commercial and industrial purposes. Authorized consumption may include items such as fire fighting and training, flushing of mains and sewers, street cleaning, watering of municipal gardens, public fountains, frost protection, building water, etc. These may be billed or unbilled, metered or un-metered.
Water Losses:	The difference between SYSTEM INPUT and AUTHORISED CONSUMPTION . Water losses can be considered as a total volume for the whole system, or for partial systems such as raw water mains, transmission or distribution systems, or individual zones. In the above definition of Water Losses, 'Authorized Consumption' includes bulk exports of water across operational boundaries. When doing the Water Balance calculation, a convenient alternative method of calculating Water Losses is 'Water Supplied - (Authorized Consumption - Water Exported)'
Apparent Losses:	Includes all types of inaccuracies associated with customer metering, plus unauthorized consumption (theft or illegal use). Over-registration of customer meters, leads to under-estimation of REAL LOSSES . Under-registration of customer meters, leads to over-estimation of REAL LOSSES .
Real Losses:	Physical water losses from the pressurized system, up to the point of measurement of customer use. The annual volume lost through all types of leaks, breaks and overflows depends on frequencies, flow rates, and average duration of individual leaks, breaks and overflows. Although physical losses after the point of customer flow measurement or assumed consumption are excluded from the assessment of REAL LOSSES ,

	this does not necessarily mean that they are not significant or worthy of attention for demand management purposes.
Revenue Water:	Those components of SYSTEM INPUT which are billed and produce revenue (also known as BILLED AUTHORISED CONSUMPTION). Equal to BILLED WATER EXPORTED, BILLED METERED CONSUMPTION and BILLED UNMETERED CONSUMPTION
Non- Revenue Water:	Those components of SYSTEM INPUT which are not billed and do not produce revenue. Equal to UNBILLED AUTHORISED CONSUMPTION, APPARENT LOSSES and REAL LOSSES
Unbilled, Authorized Consumption:	Those components of AUTHORISED CONSUMPTION which are not billed and do not produce revenue. Equal to UNBILLED METERED CONSUMPTION and UNBILLED UNMETERED CONSUMPTION

Appendix B

Supply Meter Accuracy Test Reports

Coulter Water Meter Service Inc.

P.O. Box 216, Strathroy, Ontario N7G 3J2 (519) 245-5860

Service Order/Report

New P.O. 301678 Old P.O. 30513 Invoice No 28792 REGNIA Service Date 5/24/2005

Invoiced To REG. MUNICIPALITY OF NIAGARA
2201 ST. DAVIDS ROAD
P.O. BOX 1042
THOROLD ONTARIO
L2V 4T7 CANADA

Job Address PARK ROAD @ MUD STREET
Acct No METER #15
Occupant AREA #3
Contact PAUL COLEMAN 905-684-5353
Cust Contact TONY ACCETTOLA

Service Provided By: J. OSTROWALKER

Meter Mfg INVENSYS Location MODULE TESTED IN-SHOP
Size Type 4" W-1000 Test Fittings MODULE EXCHANGE
Reg Unit D/R 1M3 Chamber N Job Completed ☒
Serial No 1243994

Meter Running On Arrival ☐

Meter Sealed On Arrival ☐

Bypass Sealed On Arrival ☐

If NO, Was It Open ☐

Mtr Running On Departure ☐

tr Valves Sealed On Departure ☐

Broken Valves Tagged ☐

Meter Reading

As Found

After Service

HF OUT

HF IN

LF OUT

LF IN

932213	932222

Static PSI 0 Residual PSI 0 At 0 Rate Of Flow 0 At

As Found

TEST RESULTS

After Service

R.O.F.	QTY	HIGH	LOW	TOTAL	%	R.O.F.	QTY	HIGH	LOW	TOTAL	%
500 GPM	4110.00	4105.00	0.00	4105.00	99.88		0.00	0.00	0.00	0.00	#Num!
150 GPM	2004.50	2020.00	0.00	2020.00	100.77		0.00	0.00	0.00	0.00	#Num!
50 GPM	1010.00	1020.00	0.00	1020.00	100.99		0.00	0.00	0.00	0.00	#Num!
10 GPM	1010.00	980.00	0.00	980.00	97.03		0.00	0.00	0.00	0.00	#Num!

Meter Runs At Min. Flow ☐

Meter Runs At Min. Flow ☐

Comments METER PRETESTED WITHIN AWWA SPECIFICATION C701 FOR CLASS II TURBINE METERS.

SERVICING: \$247.00

Coulter Water Meter Service Inc.

P.O. Box 216, Strathroy, Ontario N7G 3J2 (519) 245-5860

Service Order/Report

New P.O. 301743 Old P.O. 303511 Invoice No 28793 REGNIA Service Date 5/4/2005

Invoiced To REG. MUNICIPALITY OF NIAGARA
2201 ST. DAVIDS ROAD
P.O. BOX 1042
THOROLD ONTARIO
L2V 4T7 CANADA

Job Address BEVAN HEIGHTS
Acct No METER #3
Occupant AREA #1
Contact HERB MARACLE 905-295-4831
Cust Contact TONY ACCETTOLA

Service Provided By: S. PATE / D. JONES

Meter Mfg INVENSYS

Location CORNER OF BEVAN & MELROSE

Size Type 6" F/S

Test Fittings 2" TEST PORT

Reg Unit ECR 5M3

Chamber Y

Job Completed ☒

Serial No 16436770

Meter Running On Arrival ☒

Meter Sealed On Arrival ☒

Bypass Sealed On Arrival ☒

If NO, Was It Open ☐

Mtr Running On Departure ☒

Mtr Valves Sealed On Departure ☒

Broken Valves Tagged ☐

Meter Reading

As Found

After Service

As Found	After Service
000825	000834
056290	256296

HF OUT

HF IN

LF OUT

LF IN

Static PSI 100 Residual PSI 20 At 200 Rate Of Flow 8 At 12:00 PM

As Found

TEST RESULTS

After Service

R.O.F.	QTY	HIGH	LOW	TOTAL	%	R.O.F.	QTY	HIGH	LOW	TOTAL	%
8 GPM	1000.00	0.00	1010.00	1010.00	101.00	8 GPM	1000.00	0.00	1010.00	1010.00	101.00
200 GPM	3000.00	2049.00	780.00	2829.00	94.30	200 GPM	3000.00	2140.00	830.00	2970.00	99.00
100 GPM	1000.00	431.00	535.00	966.00	96.60	100 GPM	1000.00	485.00	520.00	1005.00	100.50
60 GPM	1000.00	200.00	760.00	960.00	96.00	60 GPM	1000.00	240.00	725.00	965.00	96.50

Meter Runs At Min. Flow ☒

Meter Runs At Min. Flow ☒

Comments PRETESTED AND CALIBRATED METER TO WITHIN AWWA SPECIFICATION C703 FOR FIRE SERVICE TYPE METERS.

SERVICING: \$420.00

Coulter Water Meter Service Inc.

P.O. Box 216, Strathroy, Ontario N7G 3J2 (519) 245-5860

Service Order/Report

New P.O. 303511 Old P.O. 303511 Invoice No 29175 REGNIA Service Date 10/13/2005

Invoiced To REG. MUNICIPALITY OF NIAGARA
2201 ST. DAVIDS ROAD
P.O. BOX 1042
THOROLD ONTARIO
L2V 4T7 CANADA

Job Address BEVAN HEIGHTS
Acct No METER #3
Occupant AREA #1
Contact HERB MARACLE 905-295-4831
Cust Contact TONY ACCETTOLA

Service Provided By: PARSONS / OSTROWALKER

Meter Mfg INVENSYS

Location CORNER OF BEVAN & MELROSE

Size Type 6" F/S

Test Fittings 2" TEST PORT

Reg Unit ECR 5M3

Chamber Y

Job Completed ☒

Serial No 16436770

Meter Running On Arrival ☒

Meter Sealed On Arrival ☒

Bypass Sealed On Arrival ☒

If NO, Was It Open ☐

Mtr Running On Departure ☒

Tr Valves Sealed On Departure ☒

Broken Valves Tagged ☐

Meter Reading

As Found

After Service

As Found	After Service
001065	001070
073001	073004

HF OUT

HF IN

LF OUT

LF IN

Static PSI 100 Residual PSI 20 At 443 Rate Of Flow 40 At 1:15 PM

As Found

TEST RESULTS

After Service

R.O.F.	QTY	HIGH	LOW	TOTAL	%	R.O.F.	QTY	HIGH	LOW	TOTAL	%
.51 LPS	1000.40	0.00	1010.00	1010.00	100.96		0.00	0.00	0.00	0.00	#Num!
28 LPS	4210.00	3560.00	600.00	4160.00	98.81		0.00	0.00	0.00	0.00	#Num!
12.6 LPS	2007.00	1400.00	590.00	1990.00	99.15		0.00	0.00	0.00	0.00	#Num!
2.8 LPS	1003.00	40.00	960.00	1000.00	99.70		0.00	0.00	0.00	0.00	#Num!

Meter Runs At Min. Flow ☒

Meter Runs At Min. Flow ☐

Comments METER PRETESTED WITHIN SPECIFICATIONS,

SERVICING: \$420.00

Coulter Water Meter Service Inc.

P.O. Box 216, Strathroy, Ontario N7G 3J2 (519) 245-5860

Service Order/Report

New P.O. 301743 Old P.O. 303511 Invoice No 28793 REGNIA Service Date 5/4/2005

Invoiced To REG. MUNICIPALITY OF NIAGARA
2201 ST. DAVIDS ROAD
P.O. BOX 1042
THOROLD ONTARIO
L2V 4T7 CANADA

Job Address PORT ROBINSON TRANSFER STATION
Acct No METER #2
Occupant AREA #1
Contact HERB MARACLE 905-295-4831
Cust Contact TONY ACCETTOLA

Service Provided By: S. PATE / D. JONES

Meter Mfg INVENSYS Location 1795 THOROLD TOWN LINE
Size Type 6" F/S Test Fittings 2" TEST PORT
Reg Unit HSPU 1M3 Chamber Y Job Completed ☒
Serial No 1413619

Meter Running On Arrival ☒

Meter Sealed On Arrival ☒

Bypass Sealed On Arrival ☒

If NO, Was It Open ☐

Mtr Running On Departure ☒

Mtr Valves Sealed On Departure ☒

Broken Valves Tagged ☐

Meter Reading

As Found

After Service

As Found	After Service
061815	061825
20612.3	20615.0

HF OUT

HF IN

LF OUT

LF IN

Static PSI 100 Residual PSI 30 At 450 Rate Of Flow 40 At 5:30 PM

As Found

TEST RESULTS

After Service

R.O.F.	QTY	HIGH	LOW	TOTAL	%	R.O.F.	QTY	HIGH	LOW	TOTAL	%
8 GPM	100.00	0.00	100.50	100.50	100.50		0.00	0.00	0.00	0.00	#Num!
450 GPM	5000.00	4415.00	638.00	5053.00	101.06		0.00	0.00	0.00	0.00	#Num!
200 GPM	3000.00	2220.00	798.00	3018.00	100.60		0.00	0.00	0.00	0.00	#Num!
55 GPM	1000.00	275.00	695.00	970.00	97.00		0.00	0.00	0.00	0.00	#Num!

Meter Runs At Min. Flow



Meter Runs At Min. Flow



Comments METER PRETESTED WITHIN AWWA SPECIFICATION C703 FOR FIRE SERVICE TYPE METERS.

SERVICING: \$420.00

Coulter Water Meter Service Inc.

P.O. Box 216, Strathroy, Ontario N7G 3J2 (519) 245-5860

Service Order/Report

New P.O. 303511 Old P.O. 303511 Invoice No 29175 REGNIA Service Date 10/13/2005

Invoiced To REG. MUNICIPALITY OF NIAGARA
2201 ST. DAVIDS ROAD
P.O. BOX 1042
THOROLD ONTARIO
L2V 4T7 CANADA

Job Address PORT ROBINSON TRANSFER STATION
Acct No METER #2
Occupant AREA #1
Contact HERB MARACLE 905-295-4831
Cust Contact TONY ACCETTOLA

Service Provided By: PARSONS / OSTROWALKER

Meter Mfg INVENSYS Location 1795 THOROLD TOWN LINE
Size Type 6" F/S Test Fittings 2" TEST PORT
Reg Unit HSPU 1M3 Chamber Y Job Completed ☒
Serial No 1413619

Meter Running On Arrival ☒
Meter Sealed On Arrival ☒
Bypass Sealed On Arrival ☒
If NO, Was It Open ☐
Mtr Running On Departure ☒
r Valves Sealed On Departure ☒
Broken Valves Tagged ☐

HF OUT
HF IN
LF OUT
LF IN

Meter Reading

As Found	After Service
072485	72491
17476.1	17478.7

Static PSI 100 Residual PSI 25 At 570 Rate Of Flow 65 At 11:15 PM

As Found

TEST RESULTS

After Service

R.O.F.	QTY	HIGH	LOW	TOTAL	%	R.O.F.	QTY	HIGH	LOW	TOTAL	%
.32 LPS	100.20	0.00	99.00	99.00	98.80		0.00	0.00	0.00	0.00	#Num!
36 LPS	5503.00	4875.00	642.50	5517.50	100.26		0.00	0.00	0.00	0.00	#Num!
12.6 LPS	2625.00	1875.00	780.50	2655.50	101.16		0.00	0.00	0.00	0.00	#Num!
2.8 LPS	1005.00	35.00	963.50	998.50	99.35		0.00	0.00	0.00	0.00	#Num!

Meter Runs At Min. Flow ☒

Meter Runs At Min. Flow ☐

Comments METER PRETESTED WITHIN SPECIFICATIONS.

SERVICING: \$420.00

Coulter Water Meter Service Inc.

P.O. Box 216, Strathroy, Ontario N7G 3J2 (519) 245-5860

Service Order/Report

New P.O. 301678 Old P.O. 303511 Invoice No 28793 REGNIA Service Date 5/4/2005

Invoiced To REG. MUNICIPALITY OF NIAGARA
2201 ST. DAVIDS ROAD
P.O. BOX 1042
THOROLD ONTARIO
L2V 4T7 CANADA

Job Address MEWBURN ROAD
Acct No METER #4
Occupant AREA #1
Contact HERB MARACLE 905-295-4831
Cust Contact TONY ACCETTOLA

Service Provided By: S. PATE / D. JONES

Meter Mfg INVENSYS
Size Type 4" SRH
Reg Unit ECR 5M3
Serial No 1502170

Location MEWBURN RD SOUTH OF QEW
Test Fittings 2" TEST PORT

Chamber Y

Job Completed ☒

Meter Running On Arrival ☒

Meter Sealed On Arrival ☒

Bypass Sealed On Arrival ☒

If NO, Was It Open ☐

Mtr Running On Departure ☒

Mtr Valves Sealed On Departure ☒

Broken Valves Tagged ☐

Meter Reading

As Found

After Service

HF OUT

HF IN

LF OUT

LF IN

130104	130113

Static PSI 100 Residual PSI 80 At 100 Rate Of Flow 30 At 2:30 PM

As Found

TEST RESULTS

After Service

R.O.F.	QTY	HIGH	LOW	TOTAL	%	R.O.F.	QTY	HIGH	LOW	TOTAL	%
4 GPM	100.00	0.00	78.00	78.00	78.00	4 GPM	100.00	0.00	101.00	101.00	101.00
100 GPM	1000.00	101.00	0.00	101.00	10.10	100 GPM	1000.00	1005.00	0.00	1005.00	100.50
50 GPM	1000.00	1013.00	0.00	1013.00	101.30	50 GPM	1000.00	1011.00	0.00	1011.00	101.10
24 GPM	1000.00	98.00	0.00	98.00	9.80	24 GPM	1000.00	982.00	0.00	982.00	98.20

Meter Runs At Min. Flow



Meter Runs At Min. Flow



Comments PRETESTED, REPAIRED AND CALIBRATED METER TO WITHIN AWWA SPECIFICATION C702 FOR COMPOUND METERS. SMALL SIDE COORDINATOR GEAR CLUSTER WORN. REPLACED COORDINATOR.

PARTS AND REPAIR TIME TO BE INVOICED SEPARATE.

SERVICING: \$394.00

Coulter Water Meter Service Inc.

P.O. Box 216, Strathroy, Ontario N7G 3J2 (519) 245-5860

Service Order/Report

New P.O. 303511 Old P.O. 303511 Invoice No 29175 REGNIA Service Date 10/13/2005

Invoiced To REG. MUNICIPALITY OF NIAGARA
2201 ST. DAVIDS ROAD
P.O. BOX 1042
THOROLD ONTARIO
L2V 4T7 CANADA

Job Address MEWBURN ROAD
Acct No METER #4
Occupant AREA #1
Contact HERB MARACLE 905-295-4831
Cust Contact TONY ACCETTOLA

Service Provided By: PARSONS / OSTROWALKER

Meter Mfg INVENSYS
Size Type 4" SRH
Reg Unit ECR 5M3
Serial No 1502170

Location MEWBURN RD SOUTH OF QEW
Test Fittings 2" TEST PORT

Chamber Y

Job Completed ☒

Meter Running On Arrival ☐

Meter Sealed On Arrival ☒

Bypass Sealed On Arrival ☒

If NO, Was It Open ☐

Mtr Running On Departure ☒

r Valves Sealed On Departure ☒

Broken Valves Tagged ☐

Meter Reading

As Found

After Service

146765	146770
146767	146770

HF OUT

HF IN

LF OUT

LF IN

Static PSI 110 Residual PSI 100 At 100 Rate Of Flow 65 At 3:15 PM

As Found

TEST RESULTS

After Service

R.O.F.	QTY	HIGH	LOW	TOTAL	%	R.O.F.	QTY	HIGH	LOW	TOTAL	%
.25 LPS	100.00	0.00	0.00	0.00	0.00	.25 LPS	100.30	0.00	100.70	100.70	100.40
6.3 LPS	1000.00	0.00	0.00	0.00	0.00	6.3 LPS	1001.00	1000.00	0.00	1000.00	99.90
3.2 LPS	1000.00	0.00	0.00	0.00	0.00	3.2 LPS	1001.00	1010.00	0.00	1010.00	100.90
1.3 LPS	1000.00	0.00	0.00	0.00	0.00	1.3 LPS	1005.00	1010.00	0.00	1010.00	100.50

Meter Runs At Min. Flow



Meter Runs At Min. Flow



Comments PRETESTED, REPAIRED AND CALIBRATED METER TO WITHIN SPECIFICATIONS.

SEE SEPARATE INVOICE FOR PARTS AND REPAIR TIME.

SERVICING: \$394.00

Coulter Water Meter Service Inc.

P.O. Box 216, Strathroy, Ontario N7G 3J2 (519) 245-5860

Service Order/Report

New P.O. 302638 Old P.O. 30513 Invoice No 28792 REGNIA Service Date 5/20/2005

Invoiced To REG. MUNICIPALITY OF NIAGARA
2201 ST. DAVIDS ROAD
P.O. BOX 1042
THOROLD ONTARIO
L2V 4T7 CANADA

Job Address SCHMON PKWY @ ST. DAVIDS ROAD
Acct No METER #10
Occupant AREA #3
Contact PAUL COLEMAN 905-684-5353
Cust Contact TONY ACCETTOLA

Service Provided By: J. OSTROWALKER

Meter Mfg INVENSYS
Size Type 10" W-5500
Reg Unit HSPU 10M3
Serial No 1194818

Location MODULE TESTED IN SHOP
Test Fittings MODULE EXCHANGE

Chamber N Job Completed ☒

Meter Running On Arrival ☐

Meter Sealed On Arrival ☐

Bypass Sealed On Arrival ☐

If NO, Was It Open ☐

Mtr Running On Departure ☐

tr Valves Sealed On Departure ☐

Broken Valves Tagged ☐

Meter Reading

As Found After Service

663420X	663424X

Static PSI 0 Residual PSI 0 At 0 Rate Of Flow 0 At

As Found

TEST RESULTS

After Service

R.O.F.	QTY	HIGH	LOW	TOTAL	%	R.O.F.	QTY	HIGH	LOW	TOTAL	%
600 GPM	10128.00	10150.00	0.00	10150.00	100.22		0.00	0.00	0.00	0.00	#Num!
200 GPM	10039.00	10010.00	0.00	10010.00	99.71		0.00	0.00	0.00	0.00	#Num!
100 GPM	10981.00	11050.00	0.00	11050.00	100.63		0.00	0.00	0.00	0.00	#Num!
50 GPM	5003.00	5000.00	0.00	5000.00	99.94		0.00	0.00	0.00	0.00	#Num!

Meter Runs At Min. Flow ☐

Meter Runs At Min. Flow ☐

Comments METER PRETESTED WITHIN AWWA SPECIFICATION C701 FOR CLASS II TURBINE METERS.

SERVICING: \$341.00

Coulter Water Meter Service Inc.

P.O. Box 216, Strathroy, Ontario N7G 3J2 (519) 245-5860

Service Order/Report

New P.O. 301678 Old P.O. 30513 Invoice No 28792 REGNIA Service Date 5/20/2005

Invoiced To REG. MUNICIPALITY OF NIAGARA
2201 ST. DAVIDS ROAD
P.O. BOX 1042
THOROLD ONTARIO
L2V 4T7 CANADA

Job Address TUPPER DRIVE REVERSE
Acct No METER #10
Occupant AREA #3
Contact PAUL COLEMAN
Cust Contact TONY ACCETTOLA

Service Provided By: J. OSTROWALKER

Meter Mfg INVENSYS Location MODULE TESTED IN-SHOP
Size Type 10" W-5500 Test Fittings MODULE EXCHANGE
Reg Unit HSPU 10M3 Chamber N Job Completed ☒
Serial No 1111559

Meter Running On Arrival ☐

Meter Sealed On Arrival ☐

Bypass Sealed On Arrival ☐

If NO, Was It Open ☐

Mtr Running On Departure ☐

tr Valves Sealed On Departure ☐

Broken Valves Tagged ☐

Meter Reading

As Found

After Service

008335X	008338X

Static PSI 0 Residual PSI 0 At 0 Rate Of Flow 0 At

As Found

TEST RESULTS

After Service

R.O.F.	QTY	HIGH	LOW	TOTAL	%	R.O.F.	QTY	HIGH	LOW	TOTAL	%
600 GPM	12199.00	12050.00	0.00	12050.00	98.78		0.00	0.00	0.00	0.00	#Num!
200 GPM	10003.00	10000.00	0.00	10000.00	99.97		0.00	0.00	0.00	0.00	#Num!
100 GPM	10402.00	10300.00	0.00	10300.00	99.02		0.00	0.00	0.00	0.00	#Num!
50 GPM	5001.00	5000.00	0.00	5000.00	99.98		0.00	0.00	0.00	0.00	#Num!

Meter Runs At Min. Flow ☐

Meter Runs At Min. Flow ☐

Comments METER PRETESTED WITHIN AWWA SPECIFICATION C701 FOR CLASS II TURBINE METERS.

SERVICING: \$341.00

Coulter Water Meter Service Inc.

P.O. Box 216, Strathroy, Ontario N7G 3J2 (519) 245-5860

Service Order/Report

New P.O. 301678 Old P.O. 30513 Invoice No 28792 REGNIA Service Date 5/24/2005

Invoiced To REG. MUNICIPALITY OF NIAGARA
2201 ST. DAVIDS ROAD
P.O. BOX 1042
THOROLD ONTARIO
L2V 4T7 CANADA

Job Address FRONT ST THOROLD FLUORIDE
Acct No METER #9
Occupant AREA #3
Contact PAUL COLEMAN 905-684-5353
Cust Contact TONY ACCETTOLA

Service Provided By: J. OSTROWALKER

Meter Mfg INVENSYS
Size Type 6" W-2000
Reg Unit HSPU 1M3
Serial No 28871662

Location MODULE TESTED IN-SHOP
Test Fittings MODULE EXCHANGE

Chamber N

Job Completed ☒

Meter Running On Arrival ☐

Meter Sealed On Arrival ☐

Bypass Sealed On Arrival ☐

If NO, Was It Open ☐

Mtr Running On Departure ☐

tr Valves Sealed On Departure ☐

Broken Valves Tagged ☐

Meter Reading

As Found

After Service

HF OUT

HF IN

LF OUT

LF IN

507107	507127

Static PSI 0 Residual PSI 0 At 0 Rate Of Flow 0 At

As Found

TEST RESULTS

After Service

R.O.F.	QTY	HIGH	LOW	TOTAL	%	R.O.F.	QTY	HIGH	LOW	TOTAL	%
600 GPM	5053.00	5135.00	0.00	5135.00	101.62	600 GPM	5042.00	5105.00	0.00	5105.00	101.25
200 GPM	2133.00	2155.00	0.00	2155.00	101.03	200 GPM	2024.00	2035.00	0.00	2035.00	100.54
100 GPM	1008.00	1015.00	0.00	1015.00	100.69	100 GPM	1007.00	1010.00	0.00	1010.00	100.30
20 GPM	1002.00	995.00	0.00	995.00	99.30	20 GPM	1001.00	985.00	0.00	985.00	98.40

Meter Runs At Min. Flow ☐

Meter Runs At Min. Flow ☐

Comments PRETESTED AND CALIBRATED METER TO WITHIN AWWA SPECIFICATION C701 FOR CLASS II TURBINE METERS.

SERVICING: \$341.00

Coulter Water Meter Service Inc.

P.O. Box 216, Strathroy, Ontario N7G 3J2 (519) 245-5860

Service Order/Report

New P.O. 302638 Old P.O. 30513 Invoice No 28792 REGNIA Service Date 5/20/2005

Invoiced To REG. MUNICIPALITY OF NIAGARA
2201 ST. DAVIDS ROAD
P.O. BOX 1042
THOROLD ONTARIO
L2V 4T7 CANADA

Job Address GLENDALE AVENUE @ COON ROAD
Acct No METER #7
Occupant AREA #3
Contact PAUL COLEMAN 905-684-5353
Cust Contact TONY ACCETTOLA

Service Provided By: J. OSTROWALKER

Meter Mfg INVENSYS
Size Type 10" W-5500
Reg Unit HSPU 10M3
Serial No 1182334

Location MODULE TESTED IN-SHOP
Test Fittings MODULE EXCHANGE

Chamber N Job Completed ☒

Meter Running On Arrival ☐

Meter Sealed On Arrival ☐

Bypass Sealed On Arrival ☐

If NO, Was It Open ☐

Mtr Running On Departure ☐

tr Valves Sealed On Departure ☐

Broken Valves Tagged ☐

Meter Reading

As Found After Service

939682X	939686X

Static PSI 0 Residual PSI 0 At 0 Rate Of Flow 0 At

As Found

TEST RESULTS

After Service

R.O.F.	QTY	HIGH	LOW	TOTAL	%	R.O.F.	QTY	HIGH	LOW	TOTAL	%
600 GPM	10125.00	10100.00	0.00	10100.00	99.75		0.00	0.00	0.00	0.00	#Num!
200 GPM	10006.00	10000.00	0.00	10000.00	99.94		0.00	0.00	0.00	0.00	#Num!
100 GPM	10006.00	10050.00	0.00	10050.00	100.44		0.00	0.00	0.00	0.00	#Num!
50 GPM	5820.00	5800.00	0.00	5800.00	99.66		0.00	0.00	0.00	0.00	#Num!

Meter Runs At Min. Flow ☐

Meter Runs At Min. Flow ☐

Comments METER PRETESTED WITHIN AWWA SPECIFICATION C701 FOR CLASS II TURBINE METERS.

SERVICING: \$341.00

Coulter Water Meter Service Inc.

P.O. Box 216, Strathroy, Ontario N7G 3J2 (519) 245-5860

Service Order/Report

New P.O. 301678 Old P.O. 30513 Invoice No 28792 REGNIA Service Date 5/20/2005

Invoiced To REG. MUNICIPALITY OF NIAGARA
2201 ST. DAVIDS ROAD
P.O. BOX 1042
THOROLD ONTARIO
L2V 4T7 CANADA

Job Address SUNNY'S GAS BAR
Acct No METER #8
Occupant AREA #3
Contact PAUL COLEMAN 905-684-5353
Cust Contact TONY ACCETTOLA

Service Provided By: J. OSTROWLAKER

Meter Mfg NEPTUNE Location FULL METER TESTED IN-SHOP
Size Type 2" T10 Test Fittings FULL METER EXCHANGE
Reg Unit D/R IG Chamber N Job Completed ☒
Serial No 4745830

Meter Running On Arrival ☐

Meter Sealed On Arrival ☐

Bypass Sealed On Arrival ☐

If NO, Was It Open ☐

Mtr Running On Departure ☐

tr Valves Sealed On Departure ☐

Broken Valves Tagged ☐

Meter Reading

As Found

After Service

HF OUT

HF IN

LF OUT

LF IN

000888	000893

Static PSI 0 Residual PSI 0 At 0 Rate Of Flow 0 At

As Found

TEST RESULTS

After Service

R.O.F.	QTY	HIGH	LOW	TOTAL	%	R.O.F.	QTY	HIGH	LOW	TOTAL	%
100 GPM	1000.00	990.00	0.00	990.00	99.00		0.00	0.00	0.00	0.00	#Num!
50 GPM	1000.00	1010.00	0.00	1010.00	101.00		0.00	0.00	0.00	0.00	#Num!
25 GPM	1000.00	1000.00	0.00	1000.00	100.00		0.00	0.00	0.00	0.00	#Num!
2 GPM	1000.00	975.00	0.00	975.00	97.50		0.00	0.00	0.00	0.00	#Num!

Meter Runs At Min. Flow ☐

Meter Runs At Min. Flow ☐

Comments METER PRETESTED WITHIN AWWA SPECIFICATION C700 FOR DISPLACEMENT TYPE METERS.

SERVICING: \$105.00

Appendix C

Draft Customer Meter Accuracy Report

Analysis background

Customer meters are the cash register of the utility and are responsible for ensuring an equitable distribution of water volume and income throughout various different customer classes within a utility and as such it is extremely important to analyze the accuracy of the meters on a regular basis and where necessary make repairs or replace groups of meters. In addition to being the cash register meters are responsible for a large amount of consumption data which can be used for other engineering functions such as hydraulic models and in this case the annual water balance which is used to disaggregate components of consumption, apparent loss and real loss in order to identify appropriate and efficient intervention programs for each loss type and volume.

Using AWWA test flows and volumetric participation to identify weighted average accuracy for water balance purposes

Data has been imported into our analysis programs and analyzed using the volume weighted percentages suggested in AWWA manual M36 table 2-7 for small meters and table 2-10 for large meters. It should be noted that further improvements to this analysis could be made by data logging samples of meter consumption profiles and applying them to the weighted average calculations as opposed to using the suggested values in M36¹ and M6².

AWWARF Project No. 418 Residential Water Use Patterns of 1993 states; *"Standards for domestic 5/8in. and 3/4in. water meters are based on a flow range of 0.25gpm to 20gpm. The range is assumed to be typical of the average domestic consumer. However, limited surveys of these domestic water use rates have not, until now, adequately substantiated this range."* Although the project concluded that *"overall patterns of water use across the range of hours and flow rates were remarkably stable across geographic regions"*

Based on AWWA published data the following weighted % volumes have been used for the 5/8 inch and 3/4 inch meter weighted accuracy calculations. There were no 1 inch meters in the test sample so these have not been considered. In order to check if the volumes used in the M36 report are representative Veritec has undertaken a detailed analysis of 1200 data logged residential consumption profiles consisting of meters 5/8 to 1 inch in diameter, which were undertaken as part of the national AWWARF REUWS study in 1999³.

¹ *"Water audits and leak detection" American water works association (AWWA) manual of water supply practices M36 second edition 1999 page 20 table 2-7 (5/8 inch meters)*

² *"Water meters-selection installation testing and maintenance" AWWA manual of water supply practices M6 fourth edition 1999 page 60*

³ *"Residential end uses of water" American Water Works Association Research Foundation 1999*

Percent of Time	Range		Average	Percent of Volume
	(gpm)		(gpm)	
15%	Low	0.50 to 1	0.75	2%
70%	Medium	1 to 10	5.00	63.8%
15%	High	10 to 15	12.50	34.2%

Table 1 percent of volume calculations used for small meters taken from AWWA M6 and M36 table 2-7

The results shown below in *Table 2* clearly indicate that the M36 results are in the right order of magnitude and that the volumes actually passed at the flow rates used to generate the low flow test results are very small compared to those volumes which pass at the medium and high test flow rates. It is important to note that this data set included 100 profiles from an Eastern Ontario utility.

Flow range GPM	Volume	%
0 – 0.25	4,978.79	0.05
0.26 – 0.50	63,756.66	0.59
0.51 – 0.75	121,274.58	1.13
0.76 – 1.0	192,455.03	1.79
1.01 – 10.0	7,835,760.04	72.77
> 10	2,549,331.51	23.68
<i>Total</i>	10,767,556.61	100.00

Table 2 volumes consumed at different flow ranges from AWWARF REUS

The percent of volume at each flow rate changes for larger meter sizes and based on the same AWWA publication material available the following percent of volume were used for the estimations of weighted meter accuracy for large meters;

- ◆ Low 10%
- ◆ Medium 65%
- ◆ High 25%

It should be noted that larger customer meters are generally subject to a wider variation of flow profile as the nature of demand can differ – Veritec therefore reiterates the need to check a sample of flow profiles for the larger meter class.

Statistics of the sample set and the meter population

Customer meter test data ranging from 5/8 inch to 6 inch was made available from 3 cities within the Niagara Region as shown below:

- ◆ Town of Grimsby
- ◆ Niagara on the Lake
- ◆ Port Colborne

No information was provided as to whether or not the test samples were representative of random samples so for Veritec analysis we have assumed they are. Veritec recommends stratified random sampling of various meter sizes for future more detailed analysis of economic meter maintenance.

Data supplied broken into small and large meter classes was as follows:

- Small meters are classed as 1 inch and less – 11 samples
- Large meters classed as 1.5 inch and more – 26 samples

The total meter population for the Niagara Region is as follows:

- Small meters - 104,848
- Large meters - 8,380

Results

The tables below show the first look at the weighted meter accuracy by volume for small meters in *Table 3* and for large meters *Table 4*.

Both sets of meters have an overall meter accuracy which is within the AWWA recommended range. However upon review of the low flow accuracy it can be seen that on average it is significantly below the recommended AWWA range however using the volume weighted % contribution the lower flows have little impact on the overall average.

Test Flow Rate	Test High	Test Medium	Test Low
No. of Test Results	11	11	11
Average Accuracy	98.46%	99.84%	84.28%
Variance	0.001	0.000	0.089
Standard Dev	2.47%	1.80%	29.78%
95% Confidence	1.46%	1.06%	17.60%

Average Meter Error at each flow rate	-1.54%	-0.16%	-15.72%
% of Consumption Volume Passed at Test Flow	34.2%	63.8%	2.0%
Contribution to Overall Average Meter Error	-0.53%	-0.10%	-0.31%

Overall Meter Error	-0.94%
Overall Meter Accuracy	99.06%

Table 3 First look meter accuracy for small meters

Veritec would suggest that the cities continue to review meter accuracy using this component based approach paying particular attention to the medium flow range which has most impact on the overall meter accuracy.

Once this starts to deteriorate then it is time to consider meter replacement in the case of the smaller meters and meter replacement or repair in the case of the larger meters.

Test Flow Rate	Test High	Test Medium	Test Low
No. of Test Results	26	26	26
Average Accuracy	100.10%	99.50%	92.54%
Variance	0.001	0.001	0.035
Standard Dev	2.25%	2.47%	18.59%
95% Confidence	0.87%	0.95%	7.15%

Average Meter Error at each flow rate	0.10%	-0.50%	-7.46%
% of Consumption Volume Passed at Test Flow	25.0%	65.0%	10.0%
Contribution to Overall Average Meter Error	0.03%	-0.32%	-0.75%

Overall Meter Error	-1.04%
Overall Meter Accuracy	98.96%

Table 4 First look meter accuracy for large meters

Confidence

Confidence in the test results has been calculated first for each of the test flow rates used in this analysis and then secondly confidence in the overall meter accuracy has been calculated for use in the annual water balance.

Both small and large meter tests sets display a small variance around the mean for the medium and high flow rates and a larger variance around the mean for the low flow results.

The small meter test sample has one stuck meter at the low flow rate which makes a big difference to the small test set. *Table 5* below shows the difference in confidence if this meter is removed from the sample.

Test Flow Rate	Test High	Test Med	Test Low
No. of Test Results	10	10	10
Average Accuracy	98.48%	100.24%	92.71%
Variance	0.001	0.000	0.012
Standard Dev	2.60%	1.31%	10.83%
95% Confidence	1.61%	0.81%	6.71%

Average Meter Error at each flow rate	-1.52%	0.24%	-7.30%
% of Consumption Volume Passed at Test Flow Rate	34.2%	63.8%	2.0%
Contribution to Overall Average Meter Error	-0.52%	0.15%	-0.15%

Overall Meter Error	-0.51%
Overall Meter Accuracy	99.49%

Table 5 Confidence is increased in low flow tests if the stuck meter is removed

Confidence in that range of tests improves from 17.6% as shown in *Table 3* to 6.7% as shown in *Table 5*.

This example indicates the influence that one stuck meter can have on a sample test set, particularly when the test sample is small. Veritec would recommend that a larger set of data is used for future more detailed analysis and that stuck meters are removed from the test sets and the issue of stuck meters is dealt with as a separate component of the water balance. Further details can be supplied upon request.

Analysis by percentage meter error	
Total pop (N)	104,848
Sample count (n)	10
Average registration % (AWWA method)	99.49%
Average meter error %	0.51%
Sample variance off % under-reg	0.0126
N-n	104,838
n-1	9
Var(Ybar)	0.001396929
Sqrt(Var(Ybar))	0.037375507
Zstat for 95%	1.96
CI limits +/- of meter error %	7.33%

Table 6 Confidence in overall meter accuracy for small meters for annual water balance

As there has been no analysis of stuck meter frequency or response time to replace stuck meters the stuck meter has been removed from the test set and overall confidence increases from +/-17 to +/-7.3%. However this is still a large range and could be improved by a larger test sample.

Analysis by percentage meter error	
Total pop (N)	8,380
Sample count (n)	26
Average registration % (AWWA method)	98.96%
Average meter error %	1.04%
Sample variance off % under-reg	0.0357
N-n	8,354
n-1	25
Var(Ybar)	0.001423053
Sqrt(Var(Ybar))	0.037723377
Zstat for 95%	1.96
CI limits +/- of meter error %	7.39%

Table 7 Confidence in overall meter accuracy for large meters for annual water balance

There were no stuck meters in the large meter test sample and therefore the overall average accuracy and the confidence have been taken at face value.

Recommendations

This analysis serves as a first look at the impact of weighted overall meter accuracy by small and large meter category and allows volumes of apparent loss to be calculated in the annual water balance along with the confidence in

those volumes. Should the Region wish to refine this analysis in order to improve confidence in the apparent loss volumes and also to build a stronger business case for the correct meter accuracy intervention plan then Veritec would suggest that ongoing analysis include the following tasks:

- ◆ Undertake flow profiling of key meter sizes and classes to determine weighted volume components for low, medium and high flow rates
- ◆ Undertake stratified random sampling and analysis of key meter sizes
- ◆ Increase sample size to in excess of 30 for each class to be analyzed
- ◆ Treat stuck meters separately and look at utility response time to change out to calculate volume for annual water balance

Appendix D

Non-Revenue Water Trends

Illustration of Non-Revenue Water in 2005 *, Fort Erie

(* All meters appear to be read monthly)




Illustration of Non-Revenue Water in 2005 *, Grimsby

(* Monthly Billing for Grimsby based on a combination of monthly reads and 3 times annually reads)




Illustration of Non-Revenue Water in 2005 *, Lincoln

(* All meters appear to be read monthly)




Illustration of Non-Revenue Water in 2004 *, Niagara Falls




Illustration of Non-Revenue Water in 2005 *, Niagara-on-the-Lake
(No metering data beyond annual value provided)




Illustration of Non-Revenue Water in 2005 *, Pelham

(* No metering data beyond annual value provided)




Illustration of Non-Revenue Water in 2005 *, Port Colborne

(* Monthly Billing for Port Colborne based on a combination of monthly reads and quarterly reads)




Illustration of Non-Revenue Water in 2004*, St. Catharines

(* Monthly Billing for West Lincoln based on a combination of monthly reads and quarterly reads)




Illustration of Non-Revenue Water in 2005 *, Thorold
(No metering data beyond annual value provided)




Illustration of Non-Revenue Water in 2005 *, Welland
(No data provided for 2005 / partial data for 2004)





Illustration of Non-Revenue Water in 2005 *, West Lincoln

(* Monthly Billing for West Lincoln based on a combination of monthly reads and quarterly reads)



Appendix E

Component Analysis to Calculate UARL

Appendix D: Component Analysis to Calculate Unavoidable Annual Real Losses

Mains: assumed new burst frequency 13/100 km mains/year at 50m pressure

- 95% of events reported, 5% unreported
- Reported mains leaks average 864 m³ loss each (12 m³/hr for 3 days, or equivalent)
- So loss/km/year from reported mains leaks = $864 \times 13 \times 0.95/100$ = 107 m³/km/year
- Unreported mains leaks average 7200 m³ loss each (6 m³/hr for 50 days, or equivalent)
- So loss/km/year from unreported mains leaks = $7200 \times 13 \times 0.05/100$ = 47 m³/km/year
- Background leakage: 20 l/km/hour for 365 days = 175 m³/km/year
- Total for mains at 50m pressure = 329 m³/km/year

Service Connections: assumed new leak frequency 5/1000 connections/year at 50m pressure

- Data split into 'main to property line' (3/1000 conns/year at 50m pressure) and 'after property line' (2/1000 conns/year, for 15m average length of unmetered underground private pipe)
- 75% of events reported, 25% unreported
- Assumed flow rate for all new leaks is 1.6 m³/hr at 50m pressure

Service Connections, Main to property line

- Reported leaks (main to property line) average 307 m³ loss each (1.6 m³/hr for 8 days)
- So loss/conn/year from these reported leaks = $(307 \times 3 \times 0.75)/1000$ = 0.7 m³/conn/year
- Unreported leaks (main to property line) average 3840 m³ loss each (1.6 m³/hr for 100 days)
- So loss/conn/year from these unreported leaks = $(3840 \times 3 \times 0.25)/1000$ = 2.9 m³/conn/year
- Background leakage (main to property line) = 1.25 l/conn/hr for 365 days = 11.0 m³/conn/year
- Total for service connections, main to property line = 14.6 m³/conn/year

Service Connections, private underground pipe between property line and meter

- Reported leaks (15m private pipe) average 346 m³ loss each (1.6 m³/hr for 9 days)
- So loss/conn/year from these reported leaks = $(346 \times 2 \times 0.75)/15$ = 35 m³/km/year
- Unreported leaks (15m private pipe) average 3878 m³ loss each (1.6 m³/hr for 101 days)
- So loss/conn/year from these unreported leaks = $(3878 \times 2 \times 0.25)/15$ = 129 m³/km/year
- Background leakage = 0.5 l/conn/hr for 15m/connection for 365 days = 292 m³/km/year
- Total for 15m private pipe, property line to customer meters = 456 m³/km/year

Table A1: Summary of Unavoidable Annual Real Losses Component Analysis at 50m pressure

Infrastructure Component	Background Leakage	Reported Leaks	Unreported Leaks	Total	Units
Mains	175	107	47	329	M ³ /km mains/yr
Service Connections, mains to property line	11.0	0.7	2.9	14.6	M3/service connection /yr
Underground pipe, where customer meter is located after property line	292	35	129	456	M3/km of pipe/year

In Table 4 of Lambert et al (1999), the above figures were multiplied by 1000 (to convert to litres), divided by 365 (to convert to average daily values) and divided by 50 metres (to present the figures 'per litre per day per metre of pressure', assuming a linear pressure:leakage relationship). These are shown Table A2 below.

Table A2: Summary of Unavoidable Annual Real Losses Components in AQUA Paper Format









Infrastructure Component	Background Leakage	Reported Leaks	Unreported Leaks	Total	Units
Mains	9.6	5.8	2.6	18.0	l/km mains/day/ metre of pressure
Service Connections, mains to property line	0.60	0.04	0.16	0.80	l/service conn/ day/m. pressure
Underground pipe, where customer meter is located after property line	16.0	1.9	7.1	25.0	l/km of pipe/ day/ metre of pressure

Appendix F

PIFastCalc Output Fort Erie

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE																
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'										Standard	Version 1a	2nd Dec 2005	Canada			
ANNUAL WATER BALANCE CALCULATION IN IWA STANDARD FORMAT, WITH 95% CONFIDENCE LIMITS										Data entry	Defaults	Calculated Values	From another Worksheet			
Note: Calculations should be based on a 12-month period for all aspects of the worksheet to function correctly										Currency =	\$C	Volume units =	MI and m ³			
Utility	Town of Fort Erie			Bulk supply (Bt) or Distribution System (Ds)?	DS	01/01/2005	to	01/01/2006	=	365	days					
System	Whole System			Do most customers have storage tanks?	No	Calculation by	Steve Genser		Date	4-Dec-06						
Process Reliability Band	WATER BALANCE CALCULATIONS					Volume in period	95% Confidence Limit as +/- %	Variance	FINANCIAL PERFORMANCE INDICATORS FOR NON-REVENUE WATER							
	IWA Terminology								% of System Input Volume	Calculated Value of NRW as % of System Running Costs in Period						
	COMPONENTS OF WATER BALANCE					MI										
	WOS: Volume from Own Sources (corrected for known systematic errors)							0	0.0%							
	A	WI: Water Imported (corrected for known systematic errors)				5218.8	3.0%	6391	100.0%							
	SIV: SYSTEM INPUT VOLUME					5218.8	3.0%	6391	100.0%							
	BACE: Water Exported							0	0.0%							
	WS: WATER SUPPLIED = SIV - BACE					5218.8	3.0%	6391	100.0%							
	A/B	BACM1: Billed Authorised Consumption: Metered Residential				3404.8	1.5%	679	65.2%							
	A	BACM2: Billed Authorised Consumption: Metered Large Commercial				538.3	1.5%	17	10.3%							
	BACM3: Billed Authorised Consumption: Metered							0	0.0%							
	BACU: Billed Authorised Consumption: Unmetered							0	0.0%							
	NRW: NON-REVENUE WATER					1275.7	12.9%	7077	24.4%	0.4771	608.7	0.0%				
	A	UACM: Unbilled Authorised Consumption: Metered				0.00%	of WS	0	0.0%	0.4460	0.0	0.0%				
	C/D	UACU: Unbilled Authorised Consumption: Unmetered: Estimated as 5.000%				of WS	260.9	50.0%	4431	5.0%	0.4460	116.4	0.0%			
WL WATER LOSSES					1014.7	20.7%	11508	19.4%	0.4851	492.3	0.0%					
C/D	UC: Unauthorised Consumption: Estimated as 1.000%				of WS	52.2	50.0%	177	1.0%	0.7300	38.1	0.0%				
B/C	ALMUR1: Apparent Loss - meter under-registration: Residential				0.50%	of BACM1	17.1	7.0%	0	0.3%	1.5500	26.5	0.0%			
B/C	ALMUR2: Apparent Loss - meter under-registration: Large Commercial				1.00%	of BACM2	5.4	7.0%	0	0.1%	1.5500	8.4	0.0%			
ALMUR3: Apparent Loss - meter under-registration:						of BACM3 and UACM	0.0		0	0.0%	1.5500	0.0	0.0%			
D	ALDCD: Customer meter data handling errors						0	0.0%	1.5500	0.0	0.0%					
AL: Sum of APPARENT LOSSES					74.7	35.0%	178	1.4%	0.9774	73.0	0.0%					
RL: REAL LOSSES					940.0	22.5%	11685	18.0%	0.4460	419.2	0.0%					
A	% of period system pressurised = 100.0%				365.0	days	Cost of running system in period = \$Cx1000									
CARL: CURRENT ANNUAL REAL LOSSES (when system is pressurised)					2.58	MU/day										
Process Reliability Band	SYSTEM INFRASTRUCTURE AND PRESSURE DATA					Valid for UARL & ILI calc?	95% CLs as +/- %	ASSESSMENT OF UNAVOIDABLE REAL LOSSES, AND VOLUME AND COST OF POTENTIALLY RECOVERABLE REAL LOSSES								
	A	Lm: Mains Length, km				303.10	Yes	1.0%	Notes: If Lm and Lp are in km and pressure P is in metres							
	A	Nn: Number of Fire Hydrants				1475		1.0%	UBL in litres/hour = (20 x Lm + 1.25 x Nn + 33 x Lp) x (P/50) ^{1.5}							
	A/B	Nb: Number of Separately Billed Properties				12098		2.0%	UARL in litres/day = (18 x Lm + 0.8 x Nn + 25 x Lp) x P							
	A/B	R: Ratio of billed Service Connections (Ns, main to property line) to Billed Props (Nb)				1.000		2.0%	COMPONENT OF REAL LOSSES							
	Ns: No. of Billed Service Connections					12098		2.8%	per day in period in period 95% CLs as +/- %							
	B	Nu: Number of Unbilled Service Connections				101		10.0%	UBL: UNAVOIDABLE BACKGROUND LEAKAGE							
	Nt: Total Number of Service Conns (= Ns + Nu), mains to property line					12199	Yes	2.8%	UARL: UNAVOIDABLE ANNUAL REAL LOSSES							
	DC: Density of Connections/ km of mains = Nn/Lm					40.2		3.0%	CARL: CURRENT ANNUAL REAL LOSSES							
	B	Lp: Average pipe length, property line to meter (m)				10.2		2.4%	POTENTIALLY RECOVERABLE REAL LOSSES = CARL - UARL							
	Lp: Total pipe length, property line to meter (km)					123.40		3.7%								
	B	P: Average pressure when system pressurised (psi)				75.0	Yes	5.0%								
	P: Average pressure when system pressurised (m)					53.0		5.0%								
	IWA BEST PRACTICE PERFORMANCE INDICATOR										UNITS OF PERFORMANCE INDICATOR		Best estimate	95% CLs as +/- %	Lowest Estimate	Highest Estimate
	Non Revenue Water Basic (IWA Level 1, Fin36)										% of System Input by Volume		24.4	13.3%	21.2	27.7
Non Revenue Water Basic (IWA Level 1, Fin37)										% of System Input by Value			13.3%			
Apparent Losses (IWA Op23)										% of Water Supplied (Distribution Systems)		1.4	35.1%	0.9	1.9	
Real Losses Basic (IWA Level 1, Op24)										% of System Input Volume (Bulk Supply Systems)		1.4	35.1%	0.9	1.9	
										Litres/service connection/day, when system pressurised		211	22.7%	163	259	
										m3/km of mains/day, when system pressurised		8.5	22.6%	6.6	10.4	
Real Losses Detailed (IWA Level 3, Op 25)										Infrastructure Leakage Index ILI (non-dimensional)		2.65	23.1%	2.04	3.27	
Comments:																
Region Billing Equation = 2T1 + 2T2 - 2S (Accuracy ranges between 97 and 101.6 percent)																
Process Reliability Bands:																
A - actual data																
B - calculated based on actual data																
C - calculated estimate																
D - no data / default																
Combinations, for example, B/C may be used to illustrate a calculated estimate based on partial data																
No costs for operating the system provided.																
Total length of watermain allow for 3 m per hydrant																

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'		Standard	Version 1a	2nd Dec 2005	Canada
Utility Town of Fort Erie		01/01/2005 to 01/01/2006	365	days	
System Whole System					



'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE						
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'						
PIFastCalcs	Standard	Version 1a	2nd Dec 2005	Canada	Master.0000	Enter Licensee's name when issuing software
THIS WORKSHEET COMPARES THE CALCULATED SYSTEM ILI WITH WORLD BANK INSTITUTE GUIDELINES						
World Bank Institute (WBI) Guidelines						
The World Bank Institute has recently introduced, into its NRW Training Modules, a target matrix for Real Losses management performance, based on real losses in volume/service connection/day for a range of average operating pressures, and classified into Bands A to D. The targets assume that customer meters are located at the property boundary, with an average connection density of around 40 per km mains. Bands A to D in the WBI target matrix can also be shown as an equivalent range of ILIs, which can be applied to a wider range of connection densities and customer meter locations, as shown below. Band limits in terms of ILIs, general descriptions of each Band, and appropriate recommended actions are as follows:						
Developing Countries	Developed Countries	BAND	Calculated ILI for this System	General description of Real Loss Management Performance Categories for Developed and Developing Countries		
ILI range	ILI range					
Less than 4	Less than 2	A		Further loss reduction may be uneconomic unless there are shortages; careful analysis needed to identify cost-effective improvement		
4 to < 8	2 to < 4	B	2.7	Potential for marked improvements; consider pressure management, better active leakage control practices, and better network maintenance		
8 to < 16	4 to < 8	C		Poor leakage record; tolerable only if water is plentiful and cheap; even then, analyze level and nature of leakage and intensify leakage reduction efforts		
16 or more	8 or more	D		Very inefficient use of resources; leakage reduction programs imperative and high priority		

System ILI compared with WBI Bands for developed countries

Relative probability

Infrastructure Leakage Index ILI

—●— System ILI — Upper Limit BAND A
— Upper Limit BAND B — Upper Limit BAND C

WBI Recommendations for BANDS	A	B	C	D
Investigate pressure management options	Yes	Yes	Yes	
Investigate speed and quality of repairs	Yes	Yes	Yes	
Check economic intervention frequency	Yes	Yes		
Introduce/improve active leakage control		Yes	Yes	
Identify options for improved maintenance		Yes	Yes	
Assess Economic Leakage Level	Yes	Yes		
Review break frequencies		Yes	Yes	
Review asset management policy		Yes	Yes	Yes
Deal with deficiencies in manpower, training and communications			Yes	Yes
5-year plan to achieve next lowest band			Yes	Yes
Fundamental peer review of all activities				Yes

GUIDELINE 2: The AWWA Water Loss Committee general guidelines for setting a target ILI (in lieu of having a determination of a system-specific economic level of leakage). Source of information: Table 7 in the AWWA Water Loss Committee Report in the AWWA Journal, August 2003

Note: since this table was published, simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalc software. This has allowed the development of the ELLCalc software to calculate short-term ELL for an active leakage control policy of regular survey. Data from England & Wales (where many Water Companies are recognised as having achieved ELL) suggests that in developed countries, the ELL (in terms of ILI) is unlikely to exceed 3.0, even where water is plentiful and inexpensive.

Target ILI Range	This System ILI	Water Resources Considerations	Operational Considerations	Financial Considerations
1.0 - 3.0	2.7	Available resources are greatly limited and are very difficult and/or environmentally unsound to develop	Operating with system leakage above this level would require expansion of existing infrastructure and/or additional water resources to meet the demand	Water resources are costly to develop or purchase; ability to increase revenues via water rates is greatly limited because of regulation or low ratepayer affordability
3.0 - 5.0		Water resources are believed to be sufficient to meet long-term needs, but demand management interventions (leakage management, water conservation) are included in the long-term planning	Existing water supply infrastructure capability is sufficient to meet long-term demand as long as reasonable leakage management controls are in place	Water resources can be developed or purchased at reasonable expense; periodic water rate increases can be feasibly imposed and are tolerated by the customer population
5.0 - 8.0		Water resources are plentiful, reliable, and easily abstracted	Superior reliability, capacity and integrity of the water supply infrastructure make it relatively immune to shortages	Cost to purchase or obtain/treat water is low, as are rates charged to customers
Greater than 8.0		Although operational and financial considerations may allow a long-term ILI greater than 8.0, such a level of leakage is not an effective utilization of water as a resource. Setting a target level greater than 8.0 - other than as an incremental goal to a smaller long-term target - is discouraged.		

Note: Simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalc Standard software. This has allowed the development of the ELLCalc standard software to calculate short-term Economic Leakage Level for an active leakage control policy of regular survey.

Important Footnote: the Infrastructure Leakage Index (ILI) provides guidance as to how well real losses are being managed (in terms of repairs, active leakage control and infrastructure management) at the current operating pressure. However, calculation of the ILI does not imply that pressure management in a system is optimal, or economic. If system pressures are excessive, or subject to surges, then pressure management may result in additional benefits for real losses management - in particular, a reduction in new burst frequency and annual repair costs, and a reduction in flow rates of existing leaks. So even if a low ILI is being achieved, there may still be opportunities to reduce annual real losses by improved pressure management. The PressCalcs Standard Software provides more detailed information on this topic.

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE						
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PiFastCalcs'			Standard	Version 1a	2nd Dec 2005	Canada Master.0000
OPTIONAL DATA ENTRY SHEET FOR ANNUAL SYSTEM RUNNING COSTS			Data entry	Calculated Values	From another Worksheet	
Utility	Town of Fort Erie	01/01/2005	to	1/1/2006	Number of Days in Period	365 days
System	Whole System	Calculation by		Steve Genser	Date of calculation = 7-Sep-06	
Total running costs as calculated below =		0.0	\$Cx1000	Transfer this figure to Cell L30 of 'WaterBalance&Pis' Worksheet		
Note: The following definitions of annual system running costs should be considered as guidelines only. They are based on the 'Financial Definitions' in pages 19 and 20 of the IWA 'Manual of Best Practice 'Performance Indicators for Water Supply Services', (Alegre H, Hirner W, Baptista J.M. and Parena R, July 2000, ISBN 1 900222 27 2, IWA Publishing; this report should be consulted for further guidance as necessary.						
Operational Costs		Sub-total \$Cx1000	Group total \$Cx1000	INCLUDES		
Imported water	Raw water		0.0	BULK SUPPLY IMPORTS: total payments for imported raw water		
	Treated water			BULK SUPPLY IMPORTS: total payments for imported treated water		
Energy	Raw water		0.0	POWER: all energy costs for water supply electricity and fuel for motive machinery		
	Treatment					
	Transmission					
	Distribution					
External services: Outsourcing	Outsourcing		0.0	Outsourcing of technical or administrative services, such as consultants, contractors undertaking operational tasks, meter reading and accounting fees		
	Software licences and IT support			Licence fees on computer software and technical support by software companies		
	Associated Companies			Costs of associated companies that are not included in other items		
	Third party services			Operating costs of providing water services to third parties (other than the regulated water supply function) that are not included in other items		
Leasing and Rentals	Premises		0.0	Payments for leasing or renting premises		
	Vehicles			Payments for leasing or renting vehicles		
	Mobile Plant			Payments for leasing or renting mobile plant		
	Fixed Plant			Payments for leasing or renting fixed plant		
Purchases	Equipment		0.0	Payments for leasing or renting equipment		
	Water treatment chemicals			All water treatment chemicals for water supply that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems		
	Other than chemicals and energy			All materials and consumables other than energy and water treatment chemicals for water supply, that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems		
Taxes, levies and fees	All kinds		0.0	Any operating licences paid to a Government or municipal authority, abstraction charges, local authority rates		
Exceptional earnings and losses	All kinds		0.0	Any exceptional income or expenditure from donations, investment subsidies, compensations or adjustments related to sales/writing off of fixed assets		
Other Operating Expenditures	Other direct costs		0.0	Any other operating costs (but excluding interest and taxation, on an aggregated basis)		
	General and support expenditures			The aggregate direct cost of GENERAL AND SUPPORT ACTIVITIES (Manpower costs excluded)		
	Customer services			Costs directly associated with customer services that are not included in previous items, related to customer accounting, reading of meters, debt recovery, costs of disconnections, customers'enquiries and complaints handling.		
	Scientific services			Costs directly associated with scientific and laboratory services and with the monitoring of quality that are not included in previous items		
	Other business activities			Costs directly associated with other business activities that are not included in previous items, except for cost depreciation		
	Doubtful debts			Charge/credit to the profit and loss account for bad and doubtful debts		
Sum of Operational Costs	All the above operational costs		0.0			
Internal manpower costs	Employment costs		0.0	The sum of the total manpower costs of permanent and temporary personnel, including employment-related social costs and benefits paid by the employer		
Capitalised cost of self-constructed assets	Negative allocation		0.0	The summation of the amounts in each of the above cost categories that have been incurred in the construction of new or rehabilitated assets		
Total Running Costs	Sum of Operational costs and Internal Manpower Costs, minus capitalised cost of self-constructed assets		0.0			
Comments:						

Appendix G

PIFastCalc Output Grimsby









'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE													
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PiFastCalcs'										Standard	Version 1a	2nd Dec 2005	Canada
ANNUAL WATER BALANCE CALCULATION IN IWA STANDARD FORMAT, WITH 95% CONFIDENCE LIMITS										Data entry	Defaults	Calculated Values	From another Worksheet
Note: Calculations should be based on a 12-month period for all aspects of the worksheet to function correctly										Currency =	\$C	Volume units =	MI and m ³
Utility	Town of Grimsby			Bulk supply (B5) or Distribution System (D5)?	DS	01/01/2005	to	01/01/2006	=	365	days		
System	Whole System			Do most customers have storage tanks?	No	Calculation by	Steve Genser		Date	4-Dec-06			
Process Reliability Band	WATER BALANCE CALCULATIONS					Volume in period	95% Confidence Limit as +/- %	Variance	FINANCIAL PERFORMANCE INDICATORS FOR NON-REVENUE WATER				
	IWA Terminology					MI			% of System Input Volume	Calculated Value of NRW as % of System Running Costs in Period			
	COMPONENTS OF WATER BALANCE												
	WQS: Volume from Own Sources (corrected for known systematic errors)							0	0.0%				
A	WI: Water Imported (corrected for known systematic errors)					3219.6	3.0%	2429	100.0%				
	SIV: SYSTEM INPUT VOLUME					3219.6	3.0%	2429	100.0%				
	BACE: Water Exported							0	0.0%				
	WS: WATER SUPPLIED = SIV - BACE					3219.6	3.0%	2429	100.0%				
A/B	BACM1: Billed Authorised Consumption: Metered		Residential		2092.2	1.5%	256	65.0%					
B	BACM2: Billed Authorised Consumption: Metered		ICI		735.1	1.5%	32	22.8%					
	BACM3: Billed Authorised Consumption: Metered						0	0.0%					
	BACU: Billed Authorised Consumption: Unmetered						0	0.0%					
	NRW: NON-REVENUE WATER					392.3	26.0%	2717	12.2%	0.6911	267.2	8.4%	
A	UACM: Unbilled Authorised Consumption: Metered		0.07% of WS		2.1		0	0.1%	0.4460	0.9	0.0%		
C	UACU: Unbilled Authorised Consumption: Unmetered: Estimated as		1.170% of WS		37.7	50.0%	92	1.2%	0.4460	16.8	0.5%		
	WL: WATER LOSSES					352.5	29.5%	2809	10.9%	0.7077	249.5	7.9%	
	UC: Unauthorised Consumption: Estimated as		1.500% of WS		48.3	50.0%	152	1.5%	1.6600	80.2	2.5%		
B	ALMUR1: Apparent Loss - meter under-registration:		Residential		10.5	7.0%	0	0.3%	2.3200	24.4	0.8%		
B	ALMUR2: Apparent Loss - meter under-registration:		ICI		7.4	7.0%	0	0.2%	2.3200	17.2	0.5%		
	ALMUR3: Apparent Loss - meter under-registration:				0.0		0	0.0%		0.0	0.0%		
D	ALDOD: Customer meter data handling errors							0	0.0%		0.0	0.0%	
	AL: Sum of APPARENT LOSSES					66.2	36.5%	152	2.1%	1.8388	121.8	3.8%	
	RL: REAL LOSSES					286.3	37.3%	2061	8.9%	0.4460	127.7	4.0%	
A	% of period system pressurized =					100.0%	365.0	days					
	CARL: CURRENT ANNUAL REAL LOSSES (when system is pressurized)					0.78	MI/day						
Process Reliability Band	SYSTEM INFRASTRUCTURE AND PRESSURE DATA					Valid for UARL & ILI calc?	95% CLs as +/- %	ASSESSMENT OF UNAVOIDABLE REAL LOSSES, AND VOLUME AND COST OF POTENTIALLY RECOVERABLE REAL LOSSES					
								Notes: If Lm and Lp are in km and pressure P is in metres					
A	Lm: Mains Length, km		128.30		Yes	1.0%	UBL in litres/hour = (20 x Lm + 1.25 x Nt + 33 x Lp) x (P/50) ^{1.5}						
A	Nh: Number of Fire Hydrants		841			1.0%	UARL in litres/day = (18 x Lm + 0.8 x Nt + 25 x Lp) x P						
B	Ns: Number of Separately Billed Properties		9449			2.0%	COMPONENT OF REAL LOSSES						
B	R: Ratio of Billed Service Connections (Ns, main to property line) to Billed Props (Nb)		1.000			2.0%	per day in period in period						
	Na: No. of billed Service Connections		9449			2.8%	UBL: UNAVOIDABLE BACKGROUND LEAKAGE						
C	Nu: Number of Unbilled Service Connections						UARL: UNAVOIDABLE ANNUAL REAL LOSSES						
	Nt: Total Number of Service Conns (= Ns + Nu), mains to property line		9449		Yes	2.8%	CARL: CURRENT ANNUAL REAL LOSSES						
	DC: Density of Connections/ km of mains = Ns/Lm		65.9			3.0%	POTENTIALLY RECOVERABLE REAL LOSSES = CARL - UARL						
B	Lp: Average pipe length, property line to meter (m)		10.2			2.4%	0.19 69 30.8 155.3%						
B	Lp: Total pipe length, property line to meter (km)		86.18			3.7%							
B	P: Average pressure when system pressurised (psi)		75.0		Yes	5.0%							
	P: Average pressure when system pressurised (m)		53.0			5.0%							
IWA BEST PRACTICE PERFORMANCE INDICATOR						UNITS OF PERFORMANCE INDICATOR							
Non Revenue Water Basic (IWA Level 1, Fin36)						Best estimate 95% CLs as +/- % Lowest Estimate Highest Estimate							
Non Revenue Water Basic (IWA Level 1, Fin37)						% of System Input by Volume 12.2 26.2% 9.0 15.4							
Apparent Losses (IWA Op23)						% of System Input by Value 8.4 26.2% 6.2 10.6							
Real Losses Basic (IWA Level 1, Op24)						% of Water Supplied (Distribution Systems) 2.1 36.6% 1.3 2.8							
Real Losses Detailed (IWA Level 3, Op 25)						% of System Input Volume (Bulk Supply Systems) 2.1 36.6% 1.3 2.8							
						Litres/service connection/day, when system pressurised 93 37.4% 59 128							
						m3/km of mains/day, when system pressurised 6.1 37.2% 3.8 8.4							
						Infrastructure Leakage Index ILI (non-dimensional) 1.32 37.6% 0.62 1.81							
Comments:													
Region supplied calculated based on three meters, i.e., 6T1 - 6D1 - 6D2 with meter calibration reports dated as follows:													
6T1 - August 15 and Nov. 2, 2005													
6D1 - no calibration provided													
6D2 - May 24, 2005													
Process Reliability Bands:													
A - actual data													
B - calculated based on actual data													
C - calculated estimate													
D - no data / default													
Water Rates: \$70.42 for the first 30.3 cubic meters; \$3.28 per 4.55 cubic meters in excess of 30.3 cubic meters													
Purchase water from the region at \$0.446 per cubic meter													
In 2004 ILI Survey quoted as \$1.54 per cubic meter applied to apparent losses therefore increase suggests \$1.67 per cubic meter.													
Total length of watermain allow for 3 m per hydrant (i.e., 841 hydrants x 3m = 2,523 km)													

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'

DETAILED CALCULATION OF COMPONENTS OF AUTHORISED AND UNAUTHORISED CONSUMPTION										From another Worksheet	
Utility/ Town of Grimsby System/ Whole System		01/01/2005 Calculation by		to Date		Data entry		Calculated Values		365 days	
		Steve Genser								04/12/2006	
Additional Information on sources of data and basis of estimates											
E = estimated											
R = Based on recordings											
Components of Authorised Consumption		Components in MI				Total					
	Billed Metered	Billed Unmetered	Unbilled Metered	Unbilled Unmetered							
Residential	2092.22				0.00	80% have remotes; 65% roll dial remote, 14 touch pad remote, 1% radio					
Commercial	320.53				0.00	20% old imp gall with no remote					
Industrial	109.80				0.00	7.44% of billing by cards					
Institutional	110.31				0.00	4.2% of bills estimated					
Irrigation	6.36				2092.22	R = Based on recordings					
Region	34.13				320.53	R = Based on recordings					
Town	22.78				109.80	R = Based on recordings					
Hamilton-Wentworth	45.91				110.31	R = Based on recordings					
via invoice	85.31				6.36	R = Based on recordings					
Hydrant Usage (mobile meter)			2.12		0.00	R = Based on recordings, less Avertex					
New Construction/Rehab				2.45	2.45	E = estimated; 6 jobs x 3/job x 500 gpm x 1 hr.					
Fire/Training				13.64	13.64	E = estimated; 1 fire/yr. 2,000 Imp. Gal; Training 68 hrs/yr @ 1,000 gpm = 3,000,000 Imp. Gal					
Hydrant Flushing				18.18	18.18	E = estimated; dead-end and 20 locations x 6/yr. x 3,000 Imp Gal + 3,000,000 Imp. Gal					
Hydroguard				2.95	2.95	E = estimated; 20 gpm x 6-4 hrs./day (50% of this in winter)					
Recreation				0.47	0.47	E = estimated; 3 parks approx. 6 gpm x 2 hrs/day x 5 months					
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						
					0.00						

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PiFastCalcs'				Standard	Version 1a	2nd Dec 2005	Canada
Utility Town of Grimsby				01/01/2005 to 01/01/2006	365	days	
System Whole System							



'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE						
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'						
PIFastCalcs	Standard	Version 1a	2nd Dec 2005	Canada	Master.0000	Town of Grimsby


THIS WORKSHEET COMPARES THE CALCULATED SYSTEM ILI WITH WORLD BANK INSTITUTE GUIDELINES

World Bank Institute (WBI) Guidelines

The World Bank Institute has recently introduced, into its NRW Training Modules, a target matrix for Real Losses management performance, based on real losses in volume/service connection/day for a range of average operating pressures, and classified into Bands A to D. The targets assume that customer meters are located at the property boundary, with an average connection density of around 40 per km mains. Bands A to D in the WBI target matrix can also be shown as an equivalent range of ILIs, which can be applied to a wider range of connection densities and customer meter locations, as shown below. Band limits in terms of ILIs, general descriptions of each Band, and appropriate recommended actions are as follows:

Developing Countries ILI range	Developed Countries ILI range	BAND	Calculated ILI for this System	General description of Real Loss Management Performance Categories for Developed and Developing Countries
Less than 4	Less than 2	A	1.3	Further loss reduction may be uneconomic unless there are shortages; careful analysis needed to identify cost-effective improvement
4 to < 8	2 to < 4	B		Potential for marked improvements; consider pressure management, better active leakage control practices, and better network maintenance
8 to < 16	4 to < 8	C		Poor leakage record; tolerable only if water is plentiful and cheap; even then, analyze level and nature of leakage and intensify leakage reduction efforts
16 or more	8 or more	D		Very inefficient use of resources; leakage reduction programs imperative and high priority

System ILI compared with WBI Bands for developed countries



WBI Recommendations for BANDS	A	B	C	D
Investigate pressure management options	Yes	Yes	Yes	
Investigate speed and quality of repairs	Yes	Yes	Yes	
Check economic intervention frequency	Yes	Yes		
Introduce/improve active leakage control		Yes	Yes	
Identify options for improved maintenance		Yes	Yes	
Assess Economic Leakage Level	Yes	Yes		
Review break frequencies		Yes	Yes	
Review asset management policy		Yes	Yes	Yes
Deal with deficiencies in manpower, training and communications			Yes	Yes
5-year plan to achieve next lowest band			Yes	Yes
Fundamental peer review of all activities				Yes

GUIDELINE 2: The AWWA Water Loss Committee general guidelines for setting a target ILI (in lieu of having a determination of a system-specific economic level of leakage). Source of information: Table 7 in the AWWA Water Loss Committee Report in the AWWA Journal, August 2003

Note: since this table was published, simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalcs software. This has allowed the development of the ELLCalcs software to calculate short-term ELL for an active leakage control policy of regular survey. Data from England & Wales (where many Water Companies are recognised as having achieved ELL) suggests that in developed countries, the ELL (in terms of ILI) is unlikely to exceed 3.0, even where water is plentiful and inexpensive.

Target ILI Range	This System ILI	Water Resources Considerations	Operational Considerations	Financial Considerations
1.0 - 3.0	1.3	Available resources are greatly limited and are very difficult and/or environmentally unsound to develop	Operating with system leakage above this level would require expansion of existing infrastructure and/or additional water resources to meet the demand	Water resources are costly to develop or purchase; ability to increase revenues via water rates is greatly limited because of regulation or low ratepayer affordability
3.0 - 5.0		Water resources are believed to be sufficient to meet long-term needs, but demand management interventions (leakage management, water conservation) are included in the long-term planning	Existing water supply infrastructure capability is sufficient to meet long-term demand as long as reasonable leakage management controls are in place	Water resources can be developed or purchased at reasonable expense; periodic water rate increases can be feasibly imposed and are tolerated by the customer population
5.0 - 8.0		Water resources are plentiful, reliable, and easily abstracted	Superior reliability, capacity and integrity of the water supply infrastructure make it relatively immune to shortages	Cost to purchase or obtain/treat water is low, as are rates charged to customers
Greater than 8.0		Although operational and financial considerations may allow a long-term ILI greater than 8.0, such a level of leakage is not an effective utilization of water as a resource. Setting a target level greater than 8.0 - other than as an incremental goal to a smaller long-term target - is discouraged.		

Note: Simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalcs Standard software. This has allowed the development of the ELLCalcs standard software to calculate short-term Economic Leakage Level for an active leakage control policy of regular survey.

Important Footnote: the Infrastructure Leakage Index (ILI) provides guidance as to how well real losses are being managed (in terms of repairs, active leakage control and infrastructure management) at the current operating pressure. However, calculation of the ILI does not imply that pressure management in a system is optimal, or economic. If system pressures are excessive, or subject to surges, then pressure management may result in additional benefits for real losses management - in particular, a reduction in new burst frequency and annual repair costs, and a reduction in flow rates of existing leaks. So even if a low ILI is being achieved, there may still be opportunities to reduce annual real losses by improved pressure management. The PressCalcs Standard Software provides more detailed information on this topic.

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE						
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'			Standard	Version 1a	2nd Dec 2005	Canada Master.0000
OPTIONAL DATA ENTRY SHEET FOR ANNUAL SYSTEM RUNNING COSTS			Data entry	Calculated Values	From another Worksheet	
Utility	Town of Grimsby	01/01/2005	to	1/1/2006	Number of Days in Period	365 days
System	Whole System	Calculation by		A.N. Other	Date of calculation =	

Total running costs as calculated below = 0.0 \$Cx1000 Transfer this figure to Cell L30 of 'WaterBalance&Pis' Worksheet

Note: The following definitions of annual system running costs should be considered as guidelines only. They are based on the 'Financial Definitions' in pages 19 and 20 of the IWA 'Manual of Best Practice 'Performance Indicators for Water Supply Services', (Alegre H, Hirner W, Baptista J.M. and Parena R, July 2000, ISBN 1 900222 27 2, IWA Publishing; this report should be consulted for further guidance as necessary.

Operational Costs		Sub-total \$Cx1000	Group total \$Cx1000	INCLUDES
Imported water	Raw water		0.0	BULK SUPPLY IMPORTS: total payments for imported raw water
	Treated water			BULK SUPPLY IMPORTS: total payments for imported treated water
Energy	Raw water		0.0	POWER: all energy costs for water supply electricity and fuel for motive machinery
	Treatment			
	Transmission			
	Distribution			
External services: Outsourcing	Outsourcing		0.0	Outsourcing of technical or administrative services, such as consultants, contractors undertaking operational tasks, meter reading and accounting fees
	Software licences and IT support			Licence fees on computer software and technical support by software companies
	Associated Companies			Costs of associated companies that are not included in other items
	Third party services			Operating costs of providing water services to third parties (other than the regulated water supply function) that are not included in other items
Leasing and Rentals	Premises		0.0	Payments for leasing or renting premises
	Vehicles			Payments for leasing or renting vehicles
	Mobile Plant			Payments for leasing or renting mobile plant
	Fixed Plant			Payments for leasing or renting fixed plant
Purchases	Equipment		0.0	Payments for leasing or renting equipment
	Water treatment chemicals			All water treatment chemicals for water supply that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems
	Other than chemicals and energy			All materials and consumables other than energy and water treatment chemicals for water supply, that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems
Taxes, levies and fees	All kinds		0.0	Any operating licences paid to a Government or municipal authority, abstraction charges, local authority rates
Exceptional earnings and losses	All kinds		0.0	Any exceptional income or expenditure from donations, investment subsidies, compensations or adjustments related to sales/writing off of fixed assets
Other Operating Expenditures	Other direct costs		0.0	Any other operating costs (but excluding interest and taxation, on an aggregated basis)
	General and support expenditures			The aggregate direct cost of GENERAL AND SUPPORT ACTIVITIES (Manpower costs excluded)
	Customer services			Costs directly associated with customer services that are not included in previous items, related to customer accounting, reading of meters, debt recovery, costs of disconnections, customers'enquiries and complaints handling.
	Scientific services			Costs directly associated with scientific and laboratory services and with the monitoring of quality that are not included in previous items
	Other business activities			Costs directly associated with other business activities that are not included in previous items, except for cost depreciation
	Doubtful debts			Charge/credit to the profit and loss account for bad and doubtful debts
Sum of Operational Costs	All the above operational costs		0.0	
Internal manpower costs	Employment costs		0.0	The sum of the total manpower costs of permanent and temporary personnel, including employment-related social costs and benefits paid by the employer
Capitalised cost of self-constructed assets	Negative allocation		0.0	The summation of the amounts in each of the above cost categories that have been incurred in the construction of new or rehabilitated assets
Total Running Costs	Sum of Operational costs and Internal Manpower Costs, minus capitalised cost of self-constructed assets		0.0	









Comments:

Appendix H

PIFastCalc Output Lincoln

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE																				
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'										Standard		Version 1a		2nd Dec 2005		Canada				
ANNUAL WATER BALANCE CALCULATION IN IWA STANDARD FORMAT, WITH 95% CONFIDENCE LIMITS										Data entry		Defaults		Calculated Values		From another Worksheet				
Note: Calculations should be based on a 12-month period for all aspects of the worksheet to function correctly																				
Utility		Town of Lincoln		Bulk supply (B) or Distribution System (D)?		DS		Currency =		\$C		Volume units =		MI		and m ³				
System		Whole System		Do most customers have storage tanks?		No		01/01/2005		to		01/01/2006		=		365 days				
Process Reliability Band				Calculation by		Steve Genser		Date		4-Dec-06										
Process Reliability Band	WATER BALANCE CALCULATIONS										Volume in period		95% Confidence Limit as +/- %		Variance		FINANCIAL PERFORMANCE INDICATORS FOR NON-REVENUE WATER			
	IWA Terminology										MI						% of System Input Volume		Calculated Value of NRW as % of System Running Costs in Period	
	COMPONENTS OF WATER BALANCE																			
	WOS: Volume from Own Sources (corrected for known systematic errors)												0		0.0%					
	A WI: Water Imported (corrected for known systematic errors)										2604.7		3.0%		1589		100.0%			
	SIV: SYSTEM INPUT VOLUME										2604.7		3.0%		1589		100.0%			
	BACE: Water Exported												0		0.0%					
	WS: WATER SUPPLIED = SIV - BACE										2604.7		3.0%		1589		100.0%			
	A/B BACM1: Billed Authorised Consumption: Metered										2362.9		1.5%		327		99.7%			
	BACM2: Billed Authorised Consumption: Metered												0		0.0%					
	BACM3: Billed Authorised Consumption: Metered												0		0.0%					
	BACU: Billed Authorised Consumption: Unmetered										0.0		0		0.0%					
	NRW: NON-REVENUE WATER										241.8		35.5%		1916		0.3%		\$C/m3 \$Cx1000 %	
	A UACM: Unbilled Authorised Consumption: Metered										0.00%		0		0.0%		0.5216		126.1 3.6%	
	D UACU: Unbilled Authorised Consumption: Unmetered: Estimated as 1.250% of WS										32.6		100.0%		276		1.3%		0.4460 0.0 0.0%	
WL WATER LOSSES										209.2		43.9%		2192		8.0%		0.5334 111.6 3.2%		
D UC: Unauthorised Consumption: Estimated as 0.250% of WS										6.5		100.0%		11		0.3%		1.3260 8.6 0.2%		
B/C ALMUR1: Apparent Loss - meter under-registration: Total 0.60% of BACM1										14.3		7.0%		0		0.5%		1.3260 18.9 0.5%		
ALMUR2: Apparent Loss - meter under-registration: of BACM2										0.0		0		0.0%		1.3260 0.0 0.0%				
ALMUR3: Apparent Loss - meter under-registration: of BACM3 and UACM										0.0		0		0.0%		1.3260 0.0 0.0%				
D ALDCD Customer meter data handling errors												0		0.0%		1.3260 0.0 0.0%				
AL: Sum of APPARENT LOSSES										20.8		31.7%		11		0.8%		1.3260 27.5 0.8%		
RL: REAL LOSSES										188.5		48.8%		2204		7.2%		0.4460 84.0 2.4%		
A % of period system pressurised = 100.0% 365.0 days																				
CARL: CURRENT ANNUAL REAL LOSSES (when system is pressurised)										0.52 MI/day								Cost of running system in period = 3505.7 \$Cx1000		
Process Reliability Band	SYSTEM INFRASTRUCTURE AND PRESSURE DATA										Valid for UARL & ILI calc?		95% CLs as +/- %		ASSESSMENT OF UNAVOIDABLE REAL LOSSES, AND VOLUME AND COST OF POTENTIALLY RECOVERABLE REAL LOSSES					
	A Lm: Mains Length, km 91.50 Yes 1.0%														Notes: If Lm and Lp are in km and pressure P is in metres					
	A Nh: Number of Fire Hydrants 532 1.0%														UBL in litres/hour = (20 x Lm + 1.25 x Nh + 33 x Lp) x (P/50) ^{1.5}					
	A/B Np: Number of Separately Billed Properties 5110 2.0%														UARL in litres/day = (18 x Lm + 0.8 x Nh + 25 x Lp) x P					
	A/B R: Ratio of billed Service Connections (Ns, main to property line) to Billed Props (Nb) 1.000 2.0%														COMPONENT OF REAL LOSSES					
	Ns: No. of billed Service Connections 5110 2.8%														per day in period in period 95% CLs as +/- %					
	C Nu: Number of Unbilled Service Connections 0 2.8%														UBL: UNAVOIDABLE BACKGROUND LEAKAGE 0.21 77 34.3 30.1%					
	Ni: Total Number of Service Conns (= Ns + Nu), mains to property line 5110 Yes 2.8%														UARL: UNAVOIDABLE ANNUAL REAL LOSSES 0.32 118 52.7 20.1%					
	DC: Density of Connections/ km of mains = Ns/Lm 55.8 3.0%														CARL: CURRENT ANNUAL REAL LOSSES 0.52 188 84.0 48.8%					
	B Lp: Average pipe length, property line to meter (m) 10.2 2.4%														POTENTIALLY RECOVERABLE REAL LOSSES = CARL - UARL 0.19 70 31.4 135.0%					
	Lp: Total pipe length, property line to meter (km) 52.12 3.7%																			
	C P: Average pressure when system pressurised (psi) 65.0 20.8%																			
	P: Average pressure when system pressurised (m) 46.0 20.0%																			
	IWA BEST PRACTICE PERFORMANCE INDICATOR										UNITS OF PERFORMANCE INDICATOR		Best estimate		95% CLs as +/- %		Lowest Estimate		Highest Estimate	
	Non Revenue Water Basic (IWA Level 1, Fin36)										% of System Input by Volume		9.3		35.6%		6.0		12.6	
Non Revenue Water Basic (IWA Level 1, Fin37)										% of System Input by Value		3.6		35.6%		2.3		4.9		
Apparent Losses (IWA Op23)										% of Water Supplied (Distribution Systems)		0.8		31.9%		0.5		1.1		
Real Losses Basic (IWA Level 1, Op24)										% of System Input Volume (Bulk Supply Systems)		0.8		31.9%		0.5		1.1		
Real Losses Detailed (IWA Level 3, Op 25)										Litres/service connection/day, when system pressurised		101		48.8%		52		150		
										m3/km of mains/day, when system pressurised		5.6		48.8%		2.9		8.4		
										Infrastructure Leakage Index ILI (non-dimensional)		1.60		52.8%		0.75		2.44		
Comments:																				
Supply via Regional Municipality of Niagara meters 5D7 (Vineland), 5D8 (Vineland Service), and 6D1 (Beamsville). Calibration reports dated:																				
5D7: August 15 / November 2, 2005																				
5D8: August 15 / November 2, 2005																				
6D1: no report																				
Process Reliability Bands:																				
A - actual data																				
B - calculated based on actual data																				
C - calculated estimate																				
D - no data / default																				
Combinations, for example, B/C may be used to illustrate a calculated estimate based on partial data																				
No breakdown of consumption provided by the Town of Lincoln, i.e., quoted single value of billed authorized consumption for the year. Confidence reflects lack of information and possibility of lag time, etc.																				
Total length of watermain allow for 3 m per hydrant																				

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'					Standard	Version 1a	2nd Dec 2005	Canada
Utility/Town of Lincoln					01/01/2005	to 01/01/2006	365	days
System/Whole System								











'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE									
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'				Standard	Version 1a	2nd Dec 2005	Canada	Master.0000	
OPTIONAL DATA ENTRY SHEET FOR ANNUAL SYSTEM RUNNING COSTS				Data entry		Calculated Values	From another Worksheet		
Utility	Town of Lincoln			01/01/2005 to 1/1/2006		Number of Days in Period	365	days	
System	Whole System			Calculation by		Steve Genser	Date of calculation =		12/4/2006
Total running costs as calculated below =				0.0		\$Cx1000 Transfer this figure to Cell L30 of 'WaterBalance&Pis' Worksheet			
Note: The following definitions of annual system running costs should be considered as guidelines only. They are based on the 'Financial Definitions' in pages 19 and 20 of the IWA 'Manual of Best Practice Performance Indicators for Water Supply Services', (Alegre H, Hirner W, Baptista J.M. and Parena R, July 2000, ISBN 1 900222 27 2. IWA Publishing; this report should be consulted for further guidance as necessary.									
		Sub-total \$Cx1000	Group total \$Cx1000	INCLUDES					
Operational Costs	Imported water		0.0	BULK SUPPLY IMPORTS: total payments for imported raw water					
	Treated water			BULK SUPPLY IMPORTS: total payments for imported treated water					
Energy	Raw water		0.0	POWER: all energy costs for water supply electricity and fuel for motive machinery					
	Treatment								
	Transmission								
	Distribution								
External services: Outsourcing	Outsourcing		0.0	Outsourcing of technical or administrative services, such as consultants, contractors undertaking operational tasks, meter reading and accounting fees					
	Software licences and IT support			Licence fees on computer software and technical support by software companies					
	Associated Companies			Costs of associated companies that are not included in other items					
	Third party services			Operating costs of providing water services to third parties (other than the regulated water supply function) that are not included in other items					
Leasing and Rentals	Premises		0.0	Payments for leasing or renting premises					
	Vehicles			Payments for leasing or renting vehicles					
	Mobile Plant			Payments for leasing or renting mobile plant					
	Fixed Plant			Payments for leasing or renting fixed plant					
Purchases	Equipment		0.0	Payments for leasing or renting equipment					
	Water treatment chemicals			All water treatment chemicals for water supply that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems					
	Other than chemicals and energy			All materials and consumables other than energy and water treatment chemicals for water supply, that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems					
Taxes, levies and fees	All kinds		0.0	Any operating licences paid to a Government or municipal authority, abstraction charges, local authority rates					
Exceptional earnings and losses	All kinds		0.0	Any exceptional income or expenditure from donations, investment subsidies, compensations or adjustments related to sales/writing off of fixed assets					
Other Operating Expenditures	Other direct costs		0.0	Any other operating costs (but excluding interest and taxation, on an aggregated basis)					
	General and support expenditures			The aggregate direct cost of GENERAL AND SUPPORT ACTIVITIES (Manpower costs excluded)					
	Customer services			Costs directly associated with customer services that are not included in previous items, related to customer accounting, reading of meters, debt recovery, costs of disconnections, customers'enquiries and complaints handling.					
	Scientific services			Costs directly associated with scientific and laboratory services and with the monitoring of quality that are not included in previous items					
	Other business activities			Costs directly associated with other business activities that are not included in previous items, except for cost depreciation					
	Doubtful debts			Charge/credit to the profit and loss account for bad and doubtful debts					
Sum of Operational Costs	All the above operational costs		0.0						
Internal manpower costs	Employment costs		0.0	The sum of the total manpower costs of permanent and temporary personnel, including employment-related social costs and benefits paid by the employer					
Capitalised cost of self-constructed assets	Negative allocation		0.0	The summation of the amounts in each of the above cost categories that have been incurred in the construction of new or rehabilitated assets					
Total Running Costs	Sum of Operational costs and Internal Manpower Costs, minus capitalised cost of self-constructed assets		0.0						
Comments:									

Appendix I

PIFastCalc Output Niagara Falls

LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE													
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PiFastCalcs'													
ANNUAL WATER BALANCE CALCULATION IN IWA STANDARD FORMAT, WITH 95% CONFIDENCE LIMITS													
Note: Calculations should be based on a 12-month period for all aspects of the worksheet to function correctly													
				Standard	Version 1a	2nd Dec 2005		Canada					
				Data entry	Defaults	Calculated Values		From another Worksheet					
				Currency =	\$C	Volume units =	MI	and	m ³				
Utility City of Niagara Falls				Bulk supply (BS) or Distribution System (DS)?	DS	01/01/2004	to	01/01/2005	=	365	days		
System Whole System				Do most customers have storage tanks?	No <th>Calculation by</th> <td colspan="2">Steve Genser</td> <td>Date</td> <td colspan="4">4-Dec-06</td>	Calculation by	Steve Genser		Date	4-Dec-06			
Process Reliability Band	WATER BALANCE CALCULATIONS												
	IWA Terminology												
	COMPONENTS OF WATER BALANCE												
	Volume in period												
	95% Confidence Limit as +/- %												
	Variance												
	FINANCIAL PERFORMANCE INDICATORS FOR NON-REVENUE WATER												
	% of System Input Volume												
	Calculated Value of NRW as % of System Running Costs in Period												
	Assessed marginal cost of individual components of Non-Revenue Water												
	Assessed Unit Value of individual components of Non Revenue Water												
	% of cost of running system												
	WOS: Volume from Own Sources (corrected for known systematic errors)												
	A Wi: Water Imported (corrected for known systematic errors)												
	SIV: SYSTEM INPUT VOLUME												
BACE: Water Exported													
WS: WATER SUPPLIED = SIV - BACE													
A/B BACM1: Billed Authorised Consumption: Metered													
BACM2: Billed Authorised Consumption: Metered													
BACM3: Billed Authorised Consumption: Metered													
A BACU: Billed Authorised Consumption: Unmetered													
NRW: NON-REVENUE WATER													
A UACM: Unbilled Authorised Consumption: Metered													
D UACU: Unbilled Authorised Consumption: Unmetered: Estimated as 1.250% of WS													
WL WATER LOSSES													
D UC: Unauthorised Consumption: Estimated as 0.250% of WS													
B/C ALMUR1: Apparent Loss - meter under-registration: Total 0.60% of BACM1													
ALMUR2: Apparent Loss - meter under-registration: 0.0% of BACM2													
ALMUR3: Apparent Loss - meter under-registration: 0.0% of BACM3 and UACM													
D ALDCD: Customer meter data handling errors													
AL: Sum of APPARENT LOSSES													
RL: REAL LOSSES													
A % of period system pressurized = 100.0% 365.0 days													
CARL: CURRENT ANNUAL REAL LOSSES (when system is pressurized)													
6.33 MI/day													
Process Reliability Band	SYSTEM INFRASTRUCTURE AND PRESSURE DATA												
	Valid for UARL & ILI calc?												
	95% CLs as +/- %												
	A Lm: Mains Length, km 498.00 Yes 1.0%												
	A Nh: Number of Fire Hydrants 2775 1.0%												
	A/B Nb: Number of Separately Billed Properties 27224 2.0%												
	A/B R: Ratio of billed Service Connections (Ns, main to property line) to Billed Props (Nb) 1.000 2.0%												
	Ns: No. of billed Service Connections 27224 2.8%												
	C Nu: Number of Unbilled Service Connections												
	Nt: Total Number of Service Conns (= Ns + Nu), mains to property line 27224 Yes 2.8%												
	DC: Density of Connections/ km of mains = Nu/Lm 54.7 3.0%												
	B/C Lp: Average pipe length, property line to meter (m) 18.0 50.0%												
	Lp: Total pipe length, property line to meter (km) 490.03 50.1%												
	B P: Average pressure when system pressurised (psi) 93.5 20.0%												
	P: Average pressure when system pressurised (m) 66.1 Yes 20.0%												
ASSESSMENT OF UNAVOIDABLE REAL LOSSES, AND VOLUME AND COST OF POTENTIALLY RECOVERABLE REAL LOSSES													
Notes: If Lm and Lp are in km and pressure P is in metres													
UBL In litres/hour = (20 x Lm + 1.25 x Nh + 33 x Lp) x (P/50) ^{1.5}													
UARL In litres/day = (18 x Lm + 0.8 x Nh + 25 x Lp) x P													
COMPONENT OF REAL LOSSES													
per day in period in period 95% CLs as +/- %													
UBL: UNAVOIDABLE BACKGROUND LEAKAGE 2.20 803 34.5%													
UARL: UNAVOIDABLE ANNUAL REAL LOSSES 2.84 1037 24.6%													
CARL: CURRENT ANNUAL REAL LOSSES 6.33 2311 24.0%													
POTENTIALLY RECOVERABLE REAL LOSSES = CARL - UARL 3.49 1274 47.9%													
IWA BEST PRACTICE PERFORMANCE INDICATOR													
UNITS OF PERFORMANCE INDICATOR													
Best estimate 95% CLs as +/- % Lowest Estimate Highest Estimate													
Non Revenue Water Basic (IWA Level 1, Fin36)													
% of System Input by Volume 16.6 19.9% 13.3 19.9													
Non Revenue Water Basic (IWA Level 1, Fin37)													
% of System Input by Value 19.9%													
Apparent Losses (IWA Op23)													
Best Op23 PI >													
% of Water Supplied (Distribution Systems) 0.8 33.6% 0.5 1.0													
% of System Input Volume (Bulk Supply Systems) 0.8 32.6% 0.5 1.0													
Real Losses Basic (IWA Level 1, Op24)													
Best Op24 PI >													
Litres/service connection/day, when system pressurised 233 24.1% 176 289													
m3/km of mains/day, when system pressurised 12.7 24.0% 9.7 15.8													
Real Losses Detailed (IWA Level 3, Op 25)													
Infrastructure Leakage Index ILI (non-dimensional) 2.23 24.4% 1.46 2.99													
Comments:													
Supply via Regional Municipality of Niagara meters 1T1, 1T2, 1D1, 1D2, 1D3, and 1D4.													
Accuracy reports provided for:													
1D1 - May 4, 2005 and October 13, 2005													
1D2 - May 4, 2005													
1D3 - May 20, 2005													
1D4 - May 4, 2005 tested and repaired: then replaced on October 13, 2005													
Process Reliability Bands:													
A - actual data													
B - calculated based on actual data													
C - calculated estimate													
D - no data / default													
Combinations, for example, B/C may be used to illustrate a calculated estimate based on partial data													
No costs for operating the system provided.													
Total length of watermain allow for 3 m per hydrant													

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PiFastCalcs'				
Utility City of Niagara Falls	Standard	Version 1a	2nd Dec 2005	Canada
System Whole System	01/01/2004 to 01/01/2005	365	days	



WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'

PIFastCalcs

Standard

Version 1a

2nd Dec 20

Canada

Master 0000

City of Niagara Falls


THIS WORKSHEET COMPARES THE CALCULATED SYSTEM ILI WITH WORLD BANK INSTITUTE GUIDELINES

World Bank Institute (WBI) Guidelines

The World Bank Institute has recently introduced, into its NRW Training Modules, a target matrix for Real Losses management performance, based on real losses in volume/service connection/day for a range of average operating pressures, and classified into Bands A to D. The targets assume that customer meters are located at the property boundary, with an average connection density of around 40 per km mains. Bands A to D in the WBI target matrix can also be shown as an equivalent range of ILIs, which can be applied to a wider range of connection densities and customer meter locations, as shown below. Band limits in terms of ILIs, general descriptions of each Band, and appropriate recommended actions are as follows:

Developing Countries	Developed Countries	BAND	Calculated ILI for this System	General description of Real Loss Management Performance Categories for Developed and Developing Countries
ILI range	ILI range			
Less than 4	Less than 2	A		Further loss reduction may be uneconomic unless there are shortages; careful analysis needed to identify cost-effective improvement
4 to < 8	2 to < 4	B	2.2	Potential for marked improvements; consider pressure management, better active leakage control practices, and better network maintenance
8 to < 16	4 to < 8	C		Poor leakage record; tolerable only if water is plentiful and cheap; even then, analyze level and nature of leakage and intensify leakage reduction efforts
16 or more	8 or more	D		Very inefficient use of resources; leakage reduction programs imperative and high priority

System ILI compared with WBI Bands for developed countries



WBI Recommendations for BANDS	A	B	C	D
Investigate pressure management options	Yes	Yes	Yes	
Investigate speed and quality of repairs	Yes	Yes	Yes	
Check economic intervention frequency	Yes	Yes		
Introduce/improve active leakage control		Yes	Yes	
Identify options for improved maintenance		Yes	Yes	
Assess Economic Leakage Level	Yes	Yes		
Review break frequencies		Yes	Yes	
Review asset management policy		Yes	Yes	Yes
Deal with deficiencies in manpower, training and communications			Yes	Yes
5-year plan to achieve next lowest band			Yes	Yes
Fundamental peer review of all activities				Yes

GUIDELINE 2: The AWWA Water Loss Committee general guidelines for setting a target ILI (in lieu of having a determination of a system-specific economic level of leakage). Source of information: Table 7 in the AWWA Water Loss Committee Report in the AWWA Journal, August 2003

Source of information: Table 7 in the AWWA Water Loss Committee Report in the AWWA Journal, August 2003

Note: since this table was published, simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalc software. This has allowed the development of the ELLCalc software to calculate short-term ELL for an active leakage control policy of regular survey. Data from England & Wales (where many Water Companies are recognised as having achieved ELL) suggests that in developed countries, the ELL (in terms of ILI) is unlikely to exceed 3.0, even where water is plentiful and inexpensive.

Target ILI Range	This System ILI	Water Resources Considerations	Operational Considerations	Financial Considerations	
1.0 - 3.0	2.2	Available resources are greatly limited and are very difficult and/or environmentally unsound to develop	Operating with system leakage above this level would require expansion of existing infrastructure and/or additional water resources to meet the demand	Water resources are costly to develop or purchase; ability to increase revenues via water rates is greatly limited because of regulation or low ratepayer affordability	
3.0 - 5.0		Water resources are believed to be sufficient to meet long-term needs, but demand management interventions (leakage management, water conservation) are included in the long-term planning	Existing water supply infrastructure capability is sufficient to meet long-term demand as long as reasonable leakage management controls are in place	Water resources can be developed or purchased at reasonable expense; periodic water rate increases can be feasibly imposed and are tolerated by the customer population	
5.0 - 8.0		Water resources are plentiful, reliable, and easily abstracted	Superior reliability, capacity and integrity of the water supply infrastructure make it relatively immune to shortages	Cost to purchase or obtain/treat water is low, as are rates charged to customers	
Greater than 8.0		Although operational and financial considerations may allow a long-term ILI greater than 8.0, such a level of leakage is not an effective utilization of water as a resource. Setting a target level greater than 8.0 - other than as an incremental goal to a smaller long-term target - is discouraged.			

Note: Simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the **ALCcaics** standard software. This has allowed the development of the **ELLCaics** standard software to calculate short-term Economic Leakage Level for an active leakage control policy of regular survey.

Important Footnote: the Infrastructure Leakage Index (ILI) provides guidance as to how well real losses are being managed (in terms of repairs, active leakage control and infrastructure management) at the current operating pressure. However, calculation of the ILI does not imply that pressure management in a system is optimal, or economic. If system pressures are excessive, or subject to surges, then pressure management may result in additional benefits for real losses management - in particular, a reduction in new burst frequency and annual repair costs, and a reduction in flow rates of existing leaks. So even if a low ILI is being achieved, there may still be opportunities to reduce annual real losses by improved pressure management. The **PressCalc** Standard Software provides more detailed information on this topic.









'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE									
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'									
OPTIONAL DATA ENTRY SHEET FOR ANNUAL SYSTEM RUNNING COSTS		Standard	Version 1a	2nd Dec 2005	Canada	Master.0000			
Utility	City of Niagara Falls	01/01/2004	to	1/1/2005	Calculated Values	From another Worksheet			
System	Whole System	Calculation by		Steve Genser	Number of Days in Period	365	days		
Total running costs as calculated below =		0.0		\$Cx1000	Transfer this figure to Cell L30 of 'WaterBalance&Pis' Worksheet				
Note: The following definitions of annual system running costs should be considered as guidelines only. They are based on the 'Financial Definitions' in pages 19 and 20 of the IWA 'Manual of Best Practice Performance Indicators for Water Supply Services', (Alegre H, Hirner W, Baptista J.M. and Parena R, July 2000, ISBN 1 900222 27 2, IWA Publishing; this report should be consulted for further guidance as necessary.									
		Sub-total \$Cx1000	Group total \$Cx1000	INCLUDES					
Operational Costs	Imported water		0.0	BULK SUPPLY IMPORTS: total payments for imported raw water					
	Treated water			BULK SUPPLY IMPORTS: total payments for imported treated water					
Energy	Raw water		0.0	POWER: all energy costs for water supply electricity and fuel for motive machinery					
	Treatment								
	Transmission								
	Distribution								
External services: Outsourcing	Outsourcing		0.0	Outsourcing of technical or administrative services, such as consultants, contractors undertaking operational tasks, meter reading and accounting fees					
	Software licences and IT support			Licence fees on computer software and technical support by software companies					
	Associated Companies			Costs of associated companies that are not included in other items					
	Third party services			Operating costs of providing water services to third parties (other than the regulated water supply function) that are not included in other items					
Leasing and Rentals	Premises		0.0	Payments for leasing or renting premises					
	Vehicles			Payments for leasing or renting vehicles					
	Mobile Plant			Payments for leasing or renting mobile plant					
	Fixed Plant			Payments for leasing or renting fixed plant					
	Equipment			Payments for leasing or renting equipment					
Purchases	Water treatment chemicals		0.0	All water treatment chemicals for water supply that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems					
	Other than chemicals and energy			All materials and consumables other than energy and water treatment chemicals for water supply, that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems					
Taxes, levies and fees	All kinds		0.0	Any operating licences paid to a Government or municipal authority, abstraction charges, local authority rates					
Exceptional earnings and losses	All kinds		0.0	Any exceptional income or expenditure from donations, investment subsidies, compensations or adjustments related to sales/writing off of fixed assets					
Other Operating Expenditures	Other direct costs		0.0	Any other operating costs (but excluding interest and taxation, on an aggregated basis)					
	General and support expenditures			The aggregate direct cost of GENERAL AND SUPPORT ACTIVITIES (Manpower costs excluded)					
	Customer services			Costs directly associated with customer services that are not included in previous items, related to customer accounting, reading of meters, debt recovery, costs of disconnections, customers'enquiries and complaints handling.					
	Scientific services			Costs directly associated with scientific and laboratory services and with the monitoring of quality that are not included in previous items					
	Other business activities			Costs directly associated with other business activities that are not included in previous items, except for cost depreciation					
	Doubtful debts			Charge/credit to the profit and loss account for bad and doubtful debts					
Sum of Operational Costs	All the above operational costs		0.0						
Internal manpower costs	Employment costs		0.0	The sum of the total manpower costs of permanent and temporary personnel, including employment-related social costs and benefits paid by the employer					
Capitalised cost of self-constructed assets	Negative allocation		0.0	The summation of the amounts in each of the above cost categories that have been incurred in the construction of new or rehabilitated assets					
Total Running Costs	Sum of Operational costs and Internal Manpower Costs, minus capitalised cost of self-constructed assets		0.0						
Comments:									

Appendix J

PIFastCalc Output Niagara-on-the-Lake

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE													
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PiFastCalcs'													
ANNUAL WATER BALANCE CALCULATION IN IWA STANDARD FORMAT, WITH 95% CONFIDENCE LIMITS													
Note: Calculations should be based on a 12-month period for all aspects of the worksheet to function correctly													
				Standard	Version 1a	2nd Dec 2005		Canada					
				Data entry	Defaults	Calculated Values		From another Worksheet					
				Currency =	\$C	Volume units =	MI	and	m ³				
				01/01/2005	to	01/01/2006	=	365	days				
				Calculation by	Steve Genser	Date	4-Dec-06						
Utility	Town of Niagara-on-the-Lake			Bulk supply (BS) or Distribution System (DS)?	DS								
System	Whole System			Do most customers have storage tanks?	No								
Process Reliability Band	WATER BALANCE CALCULATIONS				Volume in period	95% Confidence Limit as +/- %	Variance	FINANCIAL PERFORMANCE INDICATORS FOR NON-REVENUE WATER					
	IWA Terminology							% of System Input Volume	Calculated Value of NRW as % of System Running Costs in Period				
	COMPONENTS OF WATER BALANCE												
	WOS: Volume from Own Sources (corrected for known systematic errors)						0	0.0%					
	A	Wi: Water Imported (corrected for known systematic errors)			3183.6	6.0%	9498	100.0%					
	SIV: SYSTEM INPUT VOLUME				3183.6	6.0%	9498	100.0%					
	BACE: Water Exported						0	0.0%					
	WS: WATER SUPPLIED = SIV - BACE				3183.6	6.0%	9498	100.0%					
	B/C	BACM1: Billed Authorised Consumption: Metered			Total	3225.0	1.5%	609	101.3%				
	BACM2: Billed Authorised Consumption: Metered						0	0.0%					
BACM3: Billed Authorised Consumption: Metered						0	0.0%						
D	BACU: Billed Authorised Consumption: Unmetered					0	0.0%	\$C/m3	\$Cx1000	%			
NRW: NON-REVENUE WATER					-41.5	-475.2%	10107	-1.3%	0.0000	0.0	0.0%		
A	UACM: Unbilled Authorised Consumption: Metered			0.00%	of WS		0	0.0%		0.0	0.0%		
D	UACU: Unbilled Authorised Consumption: Unmetered: Estimated as			1.250%	of WS	39.8	100.0%	412	1.3%	0.0	0.0%		
WL WATER LOSSES					-91.3	-247.4%	10519	-2.6%	0.0000	0.0	0.0%		
D	UC: Unauthorised Consumption: Estimated as			0.250%	of WS	8.0	100.0%	16	0.3%	0.0	0.0%		
B/C	ALMUR1: Apparent Loss - meter under-registration:			Total	0.60%	of BACM1	19.5	7.0%	0	0.0%	0.0		
ALMUR2: Apparent Loss - meter under-registration:						0.0	0.0%	0	0.0%	0.0	0.0%		
ALMUR3: Apparent Loss - meter under-registration:						0.0	0.0%	0	0.0%	0.0	0.0%		
D	ALDCD: Customer meter data handling errors					0	0.0%		0.0	0.0%			
AL: Sum of APPARENT LOSSES					27.4	29.4%	17	0.9%	0.0000	0.0	0.0%		
RL: REAL LOSSES					-108.7	-185.1%	10536	-3.4%		0.0	0.0%		
A	% of period system pressurised =			100.0%	365.0	days	Cost of running system in period =						
CARL: CURRENT ANNUAL REAL LOSSES (when system is pressurised)					-0.30	MI/day							
Process Reliability Band	SYSTEM INFRASTRUCTURE AND PRESSURE DATA				Valid for UARL & ILI calc?	95% CLs as +/- %	ASSESSMENT OF UNAVOIDABLE REAL LOSSES, AND VOLUME AND COST OF POTENTIALLY RECOVERABLE REAL LOSSES						
	A	Lm: Mains Length, km			224.24	Yes	1.0%	Notes: If Lm and Lp are in km and pressure P is in metres					
	A	Nh: Number of Fire Hydrants			1080		1.0%	UBL in litres/hour = $(20 \times Lm + 1.25 \times Nh + 33 \times Lp) \times (p/50)^{1.5}$					
	A/B	Nb: Number of Separately Billed Properties			5306		2.0%	UARL in litres/day = $(18 \times Lm + 0.8 \times Nh + 25 \times Lp) \times P$					
	B	R: Ratio of billed Service Connections (Ns, main to property line) to Billed Props (Nb)			1.000		2.0%	COMPONENT OF REAL LOSSES					
	Ns: No. of billed Service Connections				5306		2.8%	MI per day	MI in period	\$C/m3 in period	95% CLs as +/- %		
	C	Nu: Number of Unbilled Service Connections			0			UBL: UNAVOIDABLE BACKGROUND LEAKAGE					
	Nt: Total Number of Service Conns (= Ns + Nu), mains to property line				5306	Yes	2.8%	UARL: UNAVOIDABLE ANNUAL REAL LOSSES					
	DC: Density of Connections/ km of mains = Ns/Lm				23.7		3.0%	CARL: CURRENT ANNUAL REAL LOSSES					
	B	Lp: Average pipe length, property line to meter (m)			8.5		25.0%	POTENTIALLY RECOVERABLE REAL LOSSES = CARL - UARL					
Lp: Total pipe length, property line to meter (km)				45.10		25.2%							
C	P: Average pressure when system pressurised (psi)			73.0	Yes	40.0%							
P: Average pressure when system pressurised (m)				51.6		40.0%							
IWA BEST PRACTICE PERFORMANCE INDICATOR				UNITS OF PERFORMANCE INDICATOR				Best estimate	95% CLs as +/- %	Lowest Estimate	Highest Estimate		
Non Revenue Water Basic (IWA Level 1, Fin26)				% of System Input by Volume				-1.3	475.2%	4.9	-7.5		
Non Revenue Water Basic (IWA Level 1, Fin27)				% of System Input by Value					475.2%				
Apparent Losses (IWA Op23)				% of Water Supplied (Distribution Systems)				0.9	30.0%	0.6	1.1		
Real Losses Basic (IWA Level 1, Op24)				% of System Input Volume (Bulk Supply Systems)				0.9	30.0%	0.6	1.1		
				Litres/service connection/day, when system pressurised				-56	185.1%	48	-160		
				m3/km of mains/day, when system pressurised				-1.3	185.1%	1.1	-3.8		
Real Losses Detailed (IWA Level 3, Op 25)				Infrastructure Leakage Index ILI (non-dimensional)				-0.61	189.4%	0.55	-1.77		
Comments:													
Water Supplied by Niagara Region from both Docew Falls system (SD5, SD6 & SD9) as well as Niagara Falls WTP (1D1, 1D2, 1D3, 1D4). Calibration reports provided as follows:													
SD5, SD6 - May 20, 2005													
SD9 - no report													
1D1, 1D2 - May 4, and October 13, 2005													
1D3 - August 10, and November 1, 2005													
1D4 - May 4 and October 13, 2005 - problematic meter at its highest accounted for 6% of overall supply.													
Process Reliability Bands:													
A - actual data													
B - calculated based on actual data													
C - calculated estimate													
D - no data / default													
Combinations, for example, B/C may be used to illustrate a calculated estimate based on partial data													
No costs for operating the system provided.													
Total length of watermain allow for 3 m per hydrant													

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'					Standard	Version 1a	2nd Dec 2005	Canada
Utility/Town of Niagara-on-the-Lake					01/01/2005	to 01/01/2006	365	days
System/Whole System								



'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE						
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'						
PIFastCalcs	Standard	Version 1a	2nd Dec 2005	Canada	Master.0000	Town of Niagara-on-the-Lake


THIS WORKSHEET COMPARES THE CALCULATED SYSTEM ILI WITH WORLD BANK INSTITUTE GUIDELINES

World Bank Institute (WBI) Guidelines

The World Bank Institute has recently introduced, into its NRW Training Modules, a target matrix for Real Losses management performance, based on real losses in volume/service connection/day for a range of average operating pressures, and classified into Bands A to D. The targets assume that customer meters are located at the property boundary, with an average connection density of around 40 per km mains. Bands A to D in the WBI target matrix can also be shown as an equivalent range of ILIs, which can be applied to a wider range of connection densities and customer meter locations, as shown below. Band limits in terms of ILIs, general descriptions of each Band, and appropriate recommended actions are as follows:

Developing Countries	Developed Countries	BAND	Calculated ILI for this System	General description of Real Loss Management Performance Categories for Developed and Developing Countries
ILI range	ILI range			
Less than 4	Less than 2	A	-0.6	Further loss reduction may be uneconomic unless there are shortages; careful analysis needed to identify cost-effective improvement
4 to < 8	2 to < 4	B		Potential for marked improvements; consider pressure management, better active leakage control practices, and better network maintenance
8 to < 16	4 to < 8	C		Poor leakage record; tolerable only if water is plentiful and cheap; even then, analyze level and nature of leakage and intensify leakage reduction efforts
16 or more	8 or more	D		Very inefficient use of resources; leakage reduction programs imperative and high priority

System ILI compared with WBI Bands for developed countries



WBI Recommendations for BANDS	A	B	C	D
Investigate pressure management options	Yes	Yes	Yes	
Investigate speed and quality of repairs	Yes	Yes	Yes	
Check economic intervention frequency	Yes	Yes		
Introduce/improve active leakage control		Yes	Yes	
Identify options for improved maintenance		Yes	Yes	
Assess Economic Leakage Level	Yes	Yes		
Review break frequencies		Yes	Yes	
Review asset management policy		Yes	Yes	Yes
Deal with deficiencies in manpower, training and communications			Yes	Yes
5-year plan to achieve next lowest band			Yes	Yes
Fundamental peer review of all activities				Yes

GUIDELINE 2: The AWWA Water Loss Committee general guidelines for setting a target ILI (in lieu of having a determination of a system-specific economic level of leakage). Source of information: Table 7 in the AWWA Water Loss Committee Report in the AWWA Journal, August 2003

Note: since this table was published, simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalcs software. This has allowed the development of the ELLCalcs software to calculate short-term ELL for an active leakage control policy of regular survey. Data from England & Wales (where many Water Companies are recognised as having achieved ELL) suggests that in developed countries, the ELL (in terms of ILI) is unlikely to exceed 3.0, even where water is plentiful and inexpensive.

Target ILI Range	This System ILI	Water Resources Considerations	Operational Considerations	Financial Considerations
1.0 - 3.0	-0.6	Available resources are greatly limited and are very difficult and/or environmentally unsound to develop	Operating with system leakage above this level would require expansion of existing infrastructure and/or additional water resources to meet the demand	Water resources are costly to develop or purchase; ability to increase revenues via water rates is greatly limited because of regulation or low ratepayer affordability
3.0 - 5.0		Water resources are believed to be sufficient to meet long-term needs, but demand management interventions (leakage management, water conservation) are included in the long-term planning	Existing water supply infrastructure capability is sufficient to meet long-term demand as long as reasonable leakage management controls are in place	Water resources can be developed or purchased at reasonable expense; periodic water rate increases can be feasibly imposed and are tolerated by the customer population
5.0 - 8.0		Water resources are plentiful, reliable, and easily abstracted	Superior reliability, capacity and integrity of the water supply infrastructure make it relatively immune to shortages	Cost to purchase or obtain/treat water is low, as are rates charged to customers
Greater than 8.0		Although operational and financial considerations may allow a long-term ILI greater than 8.0, such a level of leakage is not an effective utilization of water as a resource. Setting a target level greater than 8.0 - other than as an incremental goal to a smaller long-term target - is discouraged.		

Note: Simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalcs Standard software. This has allowed the development of the ELLCalcs standard software to calculate short-term Economic Leakage Level for an active leakage control policy of regular survey.

Important Footnote: the Infrastructure Leakage Index (ILI) provides guidance as to how well real losses are being managed (in terms of repairs, active leakage control and infrastructure management) at the current operating pressure. However, calculation of the ILI does not imply that pressure management in a system is optimal, or economic. If system pressures are excessive, or subject to surges, then pressure management may result in additional benefits for real losses management - in particular, a reduction in new burst frequency and annual repair costs, and a reduction in flow rates of existing leaks. So even if a low ILI is being achieved, there may still be opportunities to reduce annual real losses by improved pressure management. The PressCalcs Standard Software provides more detailed information on this topic.

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE							
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PiFastCalcs'				Standard	Version 1a	2nd Dec 2005	Canada
OPTIONAL DATA ENTRY SHEET FOR ANNUAL SYSTEM RUNNING COSTS				Data entry	Calculated Values	From another Worksheet	Master.0000
Utility	Town of Niagara-on-the-Lake	01/01/2005	to	1/1/2006	Number of Days in Period	365	days
System	Whole System	Calculation by		Steve Genser	Date of calculation =	12/4/2006	
Total running costs as calculated below =		0.0		\$Cx1000	Transfer this figure to Cell L30 of 'WaterBalance&Pis' Worksheet		
Note: The following definitions of annual system running costs should be considered as guidelines only. They are based on the 'Financial Definitions' in pages 19 and 20 of the IWA 'Manual of Best Practice Performance Indicators for Water Supply Services', (Alegre H, Hirner W, Baptista J.M. and Parena R, July 2000, ISBN 1 900222 27 2, IWA Publishing; this report should be consulted for further guidance as necessary.							
		Sub-total \$Cx1000	Group total \$Cx1000	INCLUDES			
Operational Costs	Raw water		0.0	BULK SUPPLY IMPORTS: total payments for imported raw water			
	Treated water			BULK SUPPLY IMPORTS: total payments for imported treated water			
Energy	Raw water		0.0	POWER: all energy costs for water supply electricity and fuel for motive machinery			
	Treatment						
	Transmission						
	Distribution						
External services: Outsourcing	Outsourcing		0.0	Outsourcing of technical or administrative services, such as consultants, contractors undertaking operational tasks, meter reading and accounting fees			
	Software licences and IT support			Licence fees on computer software and technical support by software companies			
	Associated Companies			Costs of associated companies that are not included in other items			
	Third party services			Operating costs of providing water services to third parties (other than the regulated water supply function) that are not included in other items			
Leasing and Rentals	Premises		0.0	Payments for leasing or renting premises			
	Vehicles			Payments for leasing or renting vehicles			
	Mobile Plant			Payments for leasing or renting mobile plant			
	Fixed Plant			Payments for leasing or renting fixed plant			
	Equipment			Payments for leasing or renting equipment			
Purchases	Water treatment chemicals		0.0	All water treatment chemicals for water supply that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems			
	Other than chemicals and energy			All materials and consumables other than energy and water treatment chemicals for water supply, that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems			
Taxes, levies and fees	All kinds		0.0	Any operating licences paid to a Government or municipal authority, abstraction charges, local authority rates			
Exceptional earnings and losses	All kinds		0.0	Any exceptional income or expenditure from donations, investment subsidies, compensations or adjustments related to sales/writing off of fixed assets			
Other Operating Expenditures	Other direct costs		0.0	Any other operating costs (but excluding interest and taxation, on an aggregated basis)			
	General and support expenditures			The aggregate direct cost of GENERAL AND SUPPORT ACTIVITIES (Manpower costs excluded)			
	Customer services			Costs directly associated with customer services that are not included in previous items, related to customer accounting, reading of meters, debt recovery, costs of disconnections, customers'enquiries and complaints handling.			
	Scientific services			Costs directly associated with scientific and laboratory services and with the monitoring of quality that are not included in previous items			
	Other business activities			Costs directly associated with other business activities that are not included in previous items, except for cost depreciation			
	Doubtful debts			Charge/credit to the profit and loss account for bad and doubtful debts			
Sum of Operational Costs	All the above operational costs		0.0				
Internal manpower costs	Employment costs		0.0	The sum of the total manpower costs of permanent and temporary personnel, including employment-related social costs and benefits paid by the employer			
Capitalised cost of self-constructed assets	Negative allocation		0.0	The summation of the amounts in each of the above cost categories that have been incurred in the construction of new or rehabilitated assets			
Total Running Costs	Sum of Operational costs and Internal Manpower Costs, minus capitalised cost of self-constructed assets		0.0				
Comments: <div style="border: 1px solid black; height: 100px; width: 100%; margin-top: 5px;"></div>							

Appendix K

PIFastCalc Output Pelham

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE												
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PiFastCalcs'						Standard	Version 1a	2nd Dec 2005	Canada			
ANNUAL WATER BALANCE CALCULATION IN IWA STANDARD FORMAT, WITH 95% CONFIDENCE LIMITS						Data entry	Defaults	Calculated Values	From another Worksheet			
Note: Calculations should be based on a 12-month period for all aspects of the worksheet to function correctly												
Utility	Town of Pelham		Bulk supply (B5) or Distribution System (D5)?	DS		Currency =	\$C	Volume units =	MI	and	m ³	
System	Whole System		Do most customers have storage tanks?	No		01/01/2005	to	01/01/2006	=	365	days	
						Calculation by	Steve Genser		Date	8-Feb-07		
Process Reliability Band	WATER BALANCE CALCULATIONS					Volume in period	95% Confidence Limit as +/- %	Variance	FINANCIAL PERFORMANCE INDICATORS FOR NON-REVENUE WATER			
	IWA Terminology								% of System Input Volume	Calculated Value of NRW as % of System Running Costs in Period		
	COMPONENTS OF WATER BALANCE					MI						
	WOS: Volume from Own Sources (corrected for known systematic errors)							0	0.0%			
	A WI: Water Imported (corrected for known systematic errors)					1722.2	3.0%	695	100.0%			
	SIV: SYSTEM INPUT VOLUME					1722.2	3.0%	695	100.0%			
	BACE: Water Exported							0	0.0%			
	WS: WATER SUPPLIED = SIV - BACE					1722.2	3.0%	695	100.0%			
	A/B BACM1: Billed Authorised Consumption: Metered					Total Billed	1440.4	1.5%	122	83.6%		
	BACM2: Billed Authorised Consumption: Metered							0	0.0%			
	BACM3: Billed Authorised Consumption: Metered							0	0.0%			
	A BACU: Billed Authorised Consumption: Unmetered							0	0.0%			
	NRW: NON-REVENUE WATER					281.8	19.9%	816	16.4%	0.4637	130.7	12.7%
	A UACM: Unbilled Authorised Consumption: Metered					0.00%	of WS	0	0.0%	0.4460	0.0	0.0%
	D UACU: Unbilled Authorised Consumption: Unmetered: Estimated as					1.250%	of WS	21.5	100.0%	121	1.3%	0.4460
WL: WATER LOSSES					260.3	23.1%	937	15.1%	0.4652	121.1	11.7%	
D UC: Unauthorised Consumption: Estimated as					0.250%	of WS	4.3	100.0%	5	0.3%	0.8300	
ALMUR1: Apparent Loss - meter under-registration:					Total Billed	0.60%	of BACM1	8.7	7.0%	0	0.5%	0.8300
ALMUR2: Apparent Loss - meter under-registration:							0.0	0.0%		0.0	0.0%	
ALMUR3: Apparent Loss - meter under-registration:							0.0	0.0%		0.0	0.0%	
ALDOD: Customer meter data handling errors							0	0.0%	0.8300	0.0	0.0%	
AL: Sum of APPARENT LOSSES					13.0	33.4%	5	0.8%	0.8300	10.8	1.0%	
RL: REAL LOSSES					247.3	24.3%	942	14.4%	0.4460	110.3	10.7%	
% of period system pressurized =					100.0%	365.0	days	Cost of running system in period =				
CARL: CURRENT ANNUAL REAL LOSSES (when system is pressurized)					0.68	MI/day	1031.7 \$Cx1000					

Process Reliability Band	SYSTEM INFRASTRUCTURE AND PRESSURE DATA		Valid for UARL & ILI calc?	95% CLs as +/- %
	A	Lm: Mains Length, km		
A	Nh: Number of Fire Hydrants	438		1.0%
A/B	Nb: Number of Separately Billed Properties	4237		2.0%
A/B	R: Ratio of billed Service Connections (Ns, main to property line) to Billed Props (Nb)	1.000		2.0%
	Ns: No. of billed Service Connections	4237		2.8%
C	Nu: Number of Unbilled Service Connections	4		25.0%
	Nt: Total Number of Service Conns (= Ns + Nu), mains to property line	4241	Yes	2.8%
	DC: Density of Connections/ km of mains = Nu/Lm	61.8		3.0%
B	Lp: Average pipe length, property line to meter (m)	10.2		2.4%
	Lp: Total pipe length, property line to meter (km)	43.22		3.7%
A/B	P: Average pressure when system pressurised (psl)	65.0	Yes	5.0%
	P: Average pressure when system pressurised (m)	48.8		5.0%

ASSESSMENT OF UNAVOIDABLE REAL LOSSES, AND VOLUME AND COST OF POTENTIALLY RECOVERABLE REAL LOSSES	
Notes: If Lm and Lp are in km and pressure P is in metres	
UBL in litres/hour = $(20 \times Lm + 1.25 \times Nh + 33 \times Lp) \times (P/50)^{1.5}$	
UARL in litres/day = $(18 \times Lm + 0.8 \times Nh + 25 \times Lp) \times P$	
COMPONENT OF REAL LOSSES	MI per day
UBL: UNAVOIDABLE BACKGROUND LEAKAGE	0.19
UARL: UNAVOIDABLE ANNUAL REAL LOSSES	0.28
CARL: CURRENT ANNUAL REAL LOSSES	0.68
POTENTIALLY RECOVERABLE REAL LOSSES = CARL - UARL	0.40

IWA BEST PRACTICE PERFORMANCE INDICATOR	UNITS OF PERFORMANCE INDICATOR	Best estimate	95% CLs as +/- %	Lowest Estimate	Highest Estimate
Non Revenue Water Basic (IWA Level 1, Fin36)	% of System Input by Volume	16.4	20.1%	13.1	19.7
Non Revenue Water Basic (IWA Level 1, Fin37)	% of System Input by Value	12.7	20.1%	10.1	15.2
Apparent Losses (IWA Op23)	% of Water Supplied (Distribution Systems)	0.8	33.6%	0.5	1.0
	% of System Input Volume (Bulk Supply Systems)	0.8	33.6%	0.5	1.0
Real Losses Basic (IWA Level 1, Op24)	Litres/service connection/day, when system pressurised	160	24.5%	121	199
	m3/km of mains/day, when system pressurised	9.9	24.3%	7.5	12.3
Real Losses Detailed (IWA Level 3, Op 25)	Infrastructure Leakage Index ILI (non-dimensional)	2.43	24.9%	1.93	3.04

Comments:

Region billing equation = 3D1 + 3D2

No Calibration Reports.









Process Reliability Bands:

A - actual data
B - calculated based on actual data
C - calculated estimate
D - no data / default

Combinations, for example, B/C may be used to illustrate a calculated estimate based on partial data

Total length of watermain allow for 3 m per hydrant

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'		Standard	Version 1a	2nd Dec 2005	Canada
Utility/Town of Pelham		01/01/2005 to 01/01/2006	365	days	
System/Whole System					



'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE						
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'						
PIFastCalcs	Standard	Version 1a	2nd Dec 2005	Canada	Master.0000	Town of Pelham


THIS WORKSHEET COMPARES THE CALCULATED SYSTEM ILI WITH WORLD BANK INSTITUTE GUIDELINES

World Bank Institute (WBI) Guidelines

The World Bank Institute has recently introduced, into its NRW Training Modules, a target matrix for Real Losses management performance, based on real losses in volume/service connection/day for a range of average operating pressures, and classified into Bands A to D. The targets assume that customer meters are located at the property boundary, with an average connection density of around 40 per km mains. Bands A to D in the WBI target matrix can also be shown as an equivalent range of ILIs, which can be applied to a wider range of connection densities and customer meter locations, as shown below. Band limits in terms of ILIs, general descriptions of each Band, and appropriate recommended actions are as follows:

Developing Countries	Developed Countries	BAND	Calculated ILI for this System	General description of Real Loss Management Performance Categories for Developed and Developing Countries
ILI range	ILI range			
Less than 4	Less than 2	A		Further loss reduction may be uneconomic unless there are shortages; careful analysis needed to identify cost-effective improvement
4 to < 8	2 to < 4	B	2.4	Potential for marked improvements; consider pressure management, better active leakage control practices, and better network maintenance
8 to < 16	4 to < 8	C		Poor leakage record; tolerable only if water is plentiful and cheap; even then, analyze level and nature of leakage and intensify leakage reduction efforts
16 or more	8 or more	D		Very inefficient use of resources; leakage reduction programs imperative and high priority

System ILI compared with WBI Bands for developed countries



WBI Recommendations for BANDS	A	B	C	D
Investigate pressure management options	Yes	Yes	Yes	
Investigate speed and quality of repairs	Yes	Yes	Yes	
Check economic intervention frequency	Yes	Yes		
Introduce/improve active leakage control		Yes	Yes	
Identify options for improved maintenance		Yes	Yes	
Assess Economic Leakage Level	Yes	Yes		
Review break frequencies		Yes	Yes	
Review asset management policy		Yes	Yes	Yes
Deal with deficiencies in manpower, training and communications			Yes	Yes
5-year plan to achieve next lowest band			Yes	Yes
Fundamental peer review of all activities				Yes

GUIDELINE 2: The AWWA Water Loss Committee general guidelines for setting a target ILI (in lieu of having a determination of a system-specific economic level of leakage). Source of information: Table 7 in the AWWA Water Loss Committee Report in the AWWA Journal, August 2003

Note: since this table was published, simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalcs software. This has allowed the development of the ELLCalcs software to calculate short-term ELL for an active leakage control policy of regular survey. Data from England & Wales (where many Water Companies are recognised as having achieved ELL) suggests that in developed countries, the ELL (in terms of ILI) is unlikely to exceed 3.0, even where water is plentiful and inexpensive.

Target ILI Range	This System ILI	Water Resources Considerations	Operational Considerations	Financial Considerations
1.0 - 3.0	2.4	Available resources are greatly limited and are very difficult and/or environmentally unsound to develop	Operating with system leakage above this level would require expansion of existing infrastructure and/or additional water resources to meet the demand	Water resources are costly to develop or purchase; ability to increase revenues via water rates is greatly limited because of regulation or low ratepayer affordability
3.0 - 5.0		Water resources are believed to be sufficient to meet long-term needs, but demand management interventions (leakage management, water conservation) are included in the long-term planning	Existing water supply infrastructure capability is sufficient to meet long-term demand as long as reasonable leakage management controls are in place	Water resources can be developed or purchased at reasonable expense; periodic water rate increases can be feasibly imposed and are tolerated by the customer population
5.0 - 8.0		Water resources are plentiful, reliable, and easily abstracted	Superior reliability, capacity and integrity of the water supply infrastructure make it relatively immune to shortages	Cost to purchase or obtain/treat water is low, as are rates charged to customers
Greater than 8.0		Although operational and financial considerations may allow a long-term ILI greater than 8.0, such a level of leakage is not an effective utilization of water as a resource. Setting a target level greater than 8.0 - other than as an incremental goal to a smaller long-term target - is discouraged.		

Note: Simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalcs Standard software. This has allowed the development of the ELLCalcs standard software to calculate short-term Economic Leakage Level for an active leakage control policy of regular survey.

Important Footnote: the Infrastructure Leakage Index (ILI) provides guidance as to how well real losses are being managed (in terms of repairs, active leakage control and infrastructure management) at the current operating pressure. However, calculation of the ILI does not imply that pressure management in a system is optimal, or economic. If system pressures are excessive, or subject to surges, then pressure management may result in additional benefits for real losses management - in particular, a reduction in new burst frequency and annual repair costs, and a reduction in flow rates of existing leaks. So even if a low ILI is being achieved, there may still be opportunities to reduce annual real losses by improved pressure management. The PressCalcs Standard Software provides more detailed information on this topic.

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE						
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'			Standard	Version 1a	2nd Dec 2005	Canada Master.0000
OPTIONAL DATA ENTRY SHEET FOR ANNUAL SYSTEM RUNNING COSTS			Data entry		Calculated Values	From another Worksheet
Utility	Town of Pelham	01/01/2005	to	1/1/2006	Number of Days in Period	365 days
System	Whole System	Calculation by		Steve Genser	Date of calculation =	7-Sep-06

Note: The following definitions of annual system running costs should be considered as guidelines only. They are based on the 'Financial Definitions' in pages 19 and 20 of the IWA 'Manual of Best Practice Performance Indicators for Water Supply Services', (Alegre H, Hirner W, Baptista J.M. and Parena R, July 2000, ISBN 1 900222 27 2, IWA Publishing; this report should be consulted for further guidance as necessary.

		Sub-total	Group total	
		\$Cx1000	\$Cx1000	INCLUDES
Operational Costs	Imported water		0.0	BULK SUPPLY IMPORTS: total payments for imported raw water
	Treated water			BULK SUPPLY IMPORTS: total payments for imported treated water
Energy	Raw water		0.0	POWER: all energy costs for water supply electricity and fuel for motive machinery
	Treatment			
	Transmission			
	Distribution			
External services: Outsourcing	Outsourcing		0.0	Outsourcing of technical or administrative services, such as consultants, contractors undertaking operational tasks, meter reading and accounting fees
	Software licences and IT support			Licence fees on computer software and technical support by software companies
	Associated Companies			Costs of associated companies that are not included in other items
	Third party services			Operating costs of providing water services to third parties (other than the regulated water supply function) that are not included in other items
Leasing and Rentals	Premises		0.0	Payments for leasing or renting premises
	Vehicles			Payments for leasing or renting vehicles
	Mobile Plant			Payments for leasing or renting mobile plant
	Fixed Plant			Payments for leasing or renting fixed plant
Purchases	Equipment			Payments for leasing or renting equipment
	Water treatment chemicals		0.0	All water treatment chemicals for water supply that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems
	Other than chemicals and energy			All materials and consumables other than energy and water treatment chemicals for water supply, that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems
Taxes, levies and fees	All kinds		0.0	Any operating licences paid to a Government or municipal authority, abstraction charges, local authority rates
Exceptional earnings and losses	All kinds		0.0	Any exceptional income or expenditure from donations, investment subsidies, compensations or adjustments related to sales/writing off of fixed assets
Other Operating Expenditures	Other direct costs		0.0	Any other operating costs (but excluding interest and taxation, on an aggregated basis)
	General and support expenditures			The aggregate direct cost of GENERAL AND SUPPORT ACTIVITIES (Manpower costs excluded)
	Customer services			Costs directly associated with customer services that are not included in previous items, related to customer accounting, reading of meters, debt recovery, costs of disconnections, customers'enquiries and complaints handling.
	Scientific services			Costs directly associated with scientific and laboratory services and with the monitoring of quality that are not included in previous items
	Other business activities			Costs directly associated with other business activities that are not included in previous items, except for cost depreciation
	Doubtful debts			Charge/credit to the profit and loss account for bad and doubtful debts
Sum of Operational Costs	All the above operational costs		0.0	
Internal manpower costs	Employment costs		0.0	The sum of the total manpower costs of permanent and temporary personnel, including employment-related social costs and benefits paid by the employer
Capitalised cost of self-constructed assets	Negative allocation		0.0	The summation of the amounts in each of the above cost categories that have been incurred in the construction of new or rehabilitated assets
Total Running Costs	Sum of Operational costs and Internal Manpower Costs, minus capitalised cost of self-constructed assets		0.0	

Comments:

Appendix L









PIFastCalc Output Port Colborne

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE													
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PiFastCalcs'										Standard	Version 1a	2nd Dec 2005	Canada
ANNUAL WATER BALANCE CALCULATION IN IWA STANDARD FORMAT, WITH 95% CONFIDENCE LIMITS										Data entry	Defaults	Calculated Values	From another Worksheet
Note: Calculations should be based on a 12-month period for all aspects of the worksheet to function correctly										Currency =	\$C	Volume units =	MI and m ³
Utility	Town of Port Colborne			Bulk supply (B5) or Distribution System (D5)?	DS	01/01/2005	to	01/01/2006	=	365	days		
System	Whole System			Do most customers have storage tanks?	No	Calculation by	Steve Genser		Date	4-Dec-06			
Process Reliability Band	WATER BALANCE CALCULATIONS					Volume in period	95% Confidence Limit as +/- %	Variance	FINANCIAL PERFORMANCE INDICATORS FOR NON-REVENUE WATER				
	IWA Terminology												
	COMPONENTS OF WATER BALANCE					MI			% of System Input Volume	Calculated Value of NRW as % of System Running Costs in Period			
	WOS: Volume from Own Sources (corrected for known systematic errors)							0	0.0%				
	A	WI: Water Imported (corrected for known systematic errors)				3909.0	3.0%	3580	100.0%				
	SIV: SYSTEM INPUT VOLUME					3909.0	3.0%	3580	100.0%				
	BACE: Water Exported							0	0.0%				
	WS: WATER SUPPLIED = SIV - BACE					3909.0	3.0%	3580	100.0%				
	A/B	BACM1: Billed Authorised Consumption: Metered Residential				1546.9	1.5%	140	39.6%				
	A	BACM2: Billed Authorised Consumption: Metered Large Users				922.9	1.5%	50	23.6%				
BACM3: Billed Authorised Consumption: Metered							0	0.0%					
BACU: Billed Authorised Consumption: Unmetered							0	0.0%					
NRW: NON-REVENUE WATER					1439.2	8.4%	3770	36.8%	0.4616	664.3	0.0%		
A	UACM: Unbilled Authorised Consumption: Metered				0.00%	of WS	0	0.0%	0.4460	0.0	0.0%		
B	UACU: Unbilled Authorised Consumption: Unmetered: Estimated as 6.700% of WS				261.9	50.0%	4464	6.7%	0.4460	116.8	0.0%		
WL: WATER LOSSES					1177.3	15.1%	8234	30.1%	0.4651	547.5	0.0%		
C	UC: Unauthorised Consumption: Estimated as 0.250% of WS				9.8	50.0%	6	0.3%	0.7560	7.4	0.0%		
B	ALMUR1: Apparent Loss - meter under-registration: Residential 0.50% of BACM1				7.8	7.0%	0	0.2%	1.5810	12.3	0.0%		
B	ALMUR2: Apparent Loss - meter under-registration: Large Users 1.00% of BACM2				9.3	7.0%	0	0.2%	1.5810	14.7	0.0%		
	ALMUR3: Apparent Loss - meter under-registration: of BACM3 and UACM				0.0		0	0.0%	1.5810	0.0	0.0%		
D	ALDCD: Customer meter data handling errors						0	0.0%	1.5810	0.0	0.0%		
AL: Sum of APPARENT LOSSES					26.9	18.5%	6	0.7%	1.2809	34.1	0.0%		
RL: REAL LOSSES					1150.4	15.5%	8240	29.4%	0.4460	513.1	0.0%		
% of period system pressurized = 100.0% 365.0 days							Cost of running system in period = \$Cx1000						
CARL: CURRENT ANNUAL REAL LOSSES (when system is pressurized)					3.15	MI/day							
Process Reliability Band	SYSTEM INFRASTRUCTURE AND PRESSURE DATA					Valid for UARL & ILI scale?	95% CLs as +/- %	ASSESSMENT OF UNAVOIDABLE REAL LOSSES, AND VOLUME AND COST OF POTENTIALLY RECOVERABLE REAL LOSSES					
	A	Lm: Mains Length, km 138.00				Yes	1.0%	Notes: If Lm and Lp are in km and pressure P is in metres					
	A	Nh: Number of Fire Hydrants 591					1.0%	UBL In litres/hour = (20 x Lm + 1.25 x Nh + 33 x Lp) x (P/950) ^{1.5}					
	A/B	Ns: Number of Separately Billed Properties 5807					2.0%	UARL In litres/day = (18 x Lm + 0.8 x Nh + 25 x Lp) x P					
	A/B	R: Ratio of billed Service Connections (Ns, main to property line) to Billed Props (Nb) 1.040					2.0%	COMPONENT OF REAL LOSSES					
	Nb: No. of billed Service Connections 6039					2.8%	per day in period in period 95% CLs as +/- %						
	B	Nu: Number of Unbilled Service Connections 28					10.0%	UBL: UNAVOIDABLE BACKGROUND LEAKAGE 0.22 91 36.0 3.4%					
	Nt: Total Number of Service Conns (= Ns + Nu), mains to property line 6067				Yes	2.8%	UARL: UNAVOIDABLE ANNUAL REAL LOSSES 0.36 133 59.3 2.6%						
	DC: Density of Connections/ km of mains = Ns/Lm 44.0					3.0%	CARL: CURRENT ANNUAL REAL LOSSES 3.15 1150 513.1 16.5%						
	B	Lp: Average pipe length, property line to meter (m) 10.2					2.4%	POTENTIALLY RECOVERABLE REAL LOSSES = CARL - UARL 2.79 1018 453.8 17.5%					
Lp: Total pipe length, property line to meter (km) 61.60					3.7%								
A	P: Average pressure when system pressurised (psi) 58.0				Yes	2.0%							
P: Average pressure when system pressurised (m) 41.0					2.0%								
IWA BEST PRACTICE PERFORMANCE INDICATOR					UNITS OF PERFORMANCE INDICATOR					Best estimate	95% CLs as +/- %	Lowest Estimate	Highest Estimate
Non Revenue Water Basic (IWA Level 1, Fin36)					% of System Input by Volume					36.8	8.9%	33.5	40.1
Non Revenue Water Basic (IWA Level 1, Fin37)					% of System Input by Value						8.9%		
Apparent Losses (IWA Op23)					% of Water Supplied (Distribution Systems)					0.7	18.7%	0.6	0.8
					% of System Input Volume (Bulk Supply Systems)					0.7	18.7%	0.6	0.8
Real Losses Basic (IWA Level 1, Op24)					Litres/service connection/day, when system pressurised					519	15.7%	438	601
					m3/km of mains/day, when system pressurised					22.8	15.5%	19.3	26.4
Real Losses Detailed (IWA Level 3, Op 25)					Infrastructure Leakage Index ILI (non-dimensional)					8.66	15.7%	7.30	10.02
Comments:													
Region billing equation = 4T1 + 4T2													
Loop Calibration Reports dated October 28, 2005 highlight the following errors:													
22.9 % of full scale = +26.7% error													
45.8 % of full scale = + 0.1% error													
76.4 % of full scale = no error													
91.6 % of full scale = no error													
Process Reliability Bands:													
A - actual data													
B - calculated based on actual data													
C - calculated estimate													
D - no data / default													
Combinations, for example, B/C may be used to illustrate a calculated estimate based on partial data													
Total length of watermain allow for 3 m per hydrant (i.e., 591 hydrants x 3m = 1.773 km)													

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE									
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'									
DETAILED CALCULATION OF COMPONENTS OF AUTHORISED AND UNAUTHORISED CONSUMPTION									
Utility/Town of Port Colborne		Data entry		Calculated Values		From another Worksheet			
System/Whole System		01/01/2005 to 01/01/2006		Calculation by Steve Genser		365 days		Date	
								04/12/2006	
Components of Authorised Consumption		Components in Ml				Additional information on sources of data and basis of estimates			
		Billed Metered	Unbilled Metered	Unbilled Unmetered	Total	E = estimated			
Residential		1546.89			1546.89	R = 4 month billing cycle			
Large Users									
PC General #52598		22.78			22.78	R = monthly meter reads			
PC General #52605		5.85			5.85	R = monthly meter reads			
PC General #52813		2.27			2.27	R = monthly meter reads			
Riocan Holdings #53679		1.41			1.41	R = monthly meter reads			
Riocan Holdings #53695		0.54			0.54	R = monthly meter reads			
City of PC #54396		1.00			1.00	R = monthly meter reads			
City of PC #54403		5.40			5.40	R = monthly meter reads			
City of PC #54586		0.64			0.64	R = monthly meter reads			
City of PC #54635		5.04			5.04	R = monthly meter reads			
Inco #54734		23.63			23.63	R = monthly meter reads			
Inco #54768		19.42			19.42	R = monthly meter reads			
Inco #63545		26.64			26.64	R = monthly meter reads			
Region #57291		1.02			1.02	R = monthly meter reads			
Region #64816		10.43			10.43	R = monthly meter reads			
Region #64874		2.16			2.16	R = monthly meter reads			
Robin Hood		36.08			36.08	R = monthly meter reads			
Mermaid Ent		52.10			52.10	R = monthly meter reads			
PC Poultry		284.53			284.53	R = monthly meter reads			
H2O #55435		0.11			0.11	R = monthly meter reads			
H2O #64501		0.11			0.11	R = monthly meter reads			
John Boys #55443		9.20			9.20	R = monthly meter reads			
John Boys #64501		3.81			3.81	R = monthly meter reads			
Sunshine Trucking #55451		7.62			7.62	R = monthly meter reads			
Sunshine Trucking #5500		22.27			22.27	R = monthly meter reads			
KNT Water Haulage #55477		36.64			36.64	R = monthly meter reads			
KNT Water Haulage		1.29			1.29	R = monthly meter reads			
Canada Starch #63694		38.60			38.60	R = monthly meter reads			
Canada Starch #63701		242.40			242.40	R = monthly meter reads			
Jim Buccione #64056		16.70			16.70	R = monthly meter reads			
Jim Buccione #64155		2.40			2.40	R = monthly meter reads			
Chamber Water Haul #64072		8.78			8.78	R = monthly meter reads			
Chamber Water Haul #64121		1.83			1.83	R = monthly meter reads			
JBL #64139		0.06			0.06	R = monthly meter reads			
JBL #64147		9.64			9.64	R = monthly meter reads			
Aqualine Water #64866		20.26			20.26	R = monthly meter reads			
Aqualine Water #65517		0.27			0.27	R = monthly meter reads			
Unbilled, Authorized, Consumption					0.00				
Hydrant Flushing					0.00				
Fire Fighting				0.01	0.01	E = estimated			
Watermain Breaks				0.04	0.04	E = estimated			
Frozen Services				0.77	0.77	E = estimated			
Water Quality				0.03	0.03	E = estimated			
Public Works				0.09	0.09	E = estimated			
Fares St. Water main				0.00	0.00	E = estimated			
				0.00	0.00	E = estimated			

[illegible]

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'				Standard	Version 1a	2nd Dec 2005	Canada
Utility/Town of Port Colborne				01/01/2005 to 01/01/2006	365	days	
System/Whole System							



WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'

ICS: _____
 f. Port Colborne

World Bank Institute (WBI) Guidelines

Developing	Developed		Calculated	
------------	-----------	--	------------	--

GUIDELINE 2: The AWWA Water Loss Committee general guidelines for setting a target ILI (in lieu of having a determination of a system-specific economic level of leakage). Source of information: Table 7 in the AWWA Water Loss Committee Report in the AWWA Journal, August 2003

Note: since this table was published, simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalc software. This has allowed the development of the ELLCalc software to calculate short-term ELL for an active leakage control policy of regular survey. Data from England & Wales (where many Water Companies are recognised as having achieved ELL) suggests that in developed countries, the ELL (in terms of ILI) is unlikely to exceed 3.0, even where water is plentiful and inexpensive.

Note: Simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the **ALCCalcs** Standard software. This has allowed the development of the **ELLCalcs** standard software to calculate short-term Economic Leakage Level for an active leakage control policy of regular survey.

Important Footnote: the Infrastructure Leakage Index (ILI) provides guidance as to how well real losses are being managed (in terms of repairs, active leakage control and infrastructure management) at the current operating pressure. However, calculation of the ILI does not imply that pressure management in a system is optimal, or economic. If system pressures are excessive, or subject to surges, then pressure management may result in additional benefits for real losses management - in particular, a reduction in new burst frequency and annual repair costs, and a reduction in flow rates of existing leaks. So even if a low ILI is being achieved, there may still be opportunities to reduce annual real losses by improved pressure management. The **PressCalc** Standard Software provides more detailed information on this topic.

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE									
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'					Standard	Version 1a	2nd Dec 2005	Canada	Master.0000
OPTIONAL DATA ENTRY SHEET FOR ANNUAL SYSTEM RUNNING COSTS					Data entry	Calculated Values	From another Worksheet		
Utility	Town of Port Colborne				01/01/2005	to	1/1/2006	Number of Days in Period	365 days
System	Whole System				Calculation by		Steve Genser	Date of calculation =	12/4/2006
Total running costs as calculated below =					0.0	\$Cx1000	Transfer this figure to Cell L30 of 'WaterBalance&Pis' Worksheet		
Note: The following definitions of annual system running costs should be considered as guidelines only. They are based on the 'Financial Definitions' in pages 19 and 20 of the IWA 'Manual of Best Practice Performance Indicators for Water Supply Services', (Alegre H, Hirner W, Baptista J.M. and Parena R, July 2000, ISBN 1 900222 27 2, IWA Publishing; this report should be consulted for further guidance as necessary.									
Operational Costs		Sub-total \$Cx1000	Group total \$Cx1000	INCLUDES					
Imported water	Raw water		0.0	BULK SUPPLY IMPORTS: total payments for imported raw water					
	Treated water			BULK SUPPLY IMPORTS: total payments for imported treated water					
Energy	Raw water		0.0	POWER: all energy costs for water supply electricity and fuel for motive machinery					
	Treatment								
	Transmission								
	Distribution								
External services: Outsourcing	Outsourcing		0.0	Outsourcing of technical or administrative services, such as consultants, contractors undertaking operational tasks, meter reading and accounting fees					
	Software licences and IT support			Licence fees on computer software and technical support by software companies					
	Associated Companies			Costs of associated companies that are not included in other items					
	Third party services			Operating costs of providing water services to third parties (other than the regulated water supply function) that are not included in other items					
Leasing and Rentals	Premises		0.0	Payments for leasing or renting premises					
	Vehicles			Payments for leasing or renting vehicles					
	Mobile Plant			Payments for leasing or renting mobile plant					
	Fixed Plant			Payments for leasing or renting fixed plant					
Purchases	Equipment		0.0	Payments for leasing or renting equipment					
	Water treatment chemicals			All water treatment chemicals for water supply that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems					
	Other than chemicals and energy			All materials and consumables other than energy and water treatment chemicals for water supply, that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems					
Taxes, levies and fees	All kinds		0.0	Any operating licences paid to a Government or municipal authority, abstraction charges, local authority rates					
Exceptional earnings and losses	All kinds		0.0	Any exceptional income or expenditure from donations, investment subsidies, compensations or adjustments related to sales/writing off of fixed assets					
Other Operating Expenditures	Other direct costs		0.0	Any other operating costs (but excluding interest and taxation, on an aggregated basis)					
	General and support expenditures			The aggregate direct cost of GENERAL AND SUPPORT ACTIVITIES (Manpower costs excluded)					
	Customer services			Costs directly associated with customer services that are not included in previous items, related to customer accounting, reading of meters, debt recovery, costs of disconnections, customers'enquiries and complaints handling.					
	Scientific services			Costs directly associated with scientific and laboratory services and with the monitoring of quality that are not included in previous items					
	Other business activities			Costs directly associated with other business activities that are not included in previous items, except for cost depreciation					
	Doubtful debts			Charge/credit to the profit and loss account for bad and doubtful debts					
Sum of Operational Costs	All the above operational costs		0.0						
Internal manpower costs	Employment costs		0.0	The sum of the total manpower costs of permanent and temporary personnel, including employment-related social costs and benefits paid by the employer					
Capitalised cost of self-constructed assets	Negative allocation		0.0	The summation of the amounts in each of the above cost categories that have been incurred in the construction of new or rehabilitated assets					
Total Running Costs	Sum of Operational costs and Internal Manpower Costs, minus capitalised cost of self-constructed assets		0.0						
Comments:									

Appendix M

PIFastCalc Output St. Catharines









'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE														
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PiFastCalcs'										Standard	Version 1a	2nd Dec 2005	Canada	
ANNUAL WATER BALANCE CALCULATION IN IWA STANDARD FORMAT, WITH 95% CONFIDENCE LIMITS										Data entry	Defaults	Calculated Values	From another Worksheet	
Note: Calculations should be based on a 12-month period for all aspects of the worksheet to function correctly										Currency =	\$C	Volume units =	MI and m ³	
Utility	City of St. Catharines			Bulk supply (BS) or Distribution System (DS)?	DS	01/01/2004	to	01/01/2005	=	365	days			
System	Whole System			Do most customers have storage tanks?	No	Calculation by	Steve Genser		Date	4-Dec-06				
Process Reliability Band	WATER BALANCE CALCULATIONS					Volume in period	95% Confidence Limit as +/- %	Variance	FINANCIAL PERFORMANCE INDICATORS FOR NON-REVENUE WATER					
	IWA Terminology					MI			% of System Input Volume	Calculated Value of NRW as % of System Running Costs in Period				
COMPONENTS OF WATER BALANCE														
WOS: Volume from Own Sources (corrected for known systematic errors)								0	0.0%					
A Wl: Water Imported (corrected for known systematic errors)						21823.7	3.0%	111590	100.0%					
SIV: SYSTEM INPUT VOLUME						21823.7	3.0%	111590	100.0%					
BACE: Water Exported								0	0.0%					
WS: WATER SUPPLIED = SIV - BACE						21823.7	3.0%	111590	100.0%					
A BACM1: Billed Authorised Consumption: Metered						Cycles	17067.9	1.5%	17062	78.2%				
A BACM2: Billed Authorised Consumption: Metered						Bulk Metering & Industrial	2409.6	1.5%	340	11.0%				
BACM3: Billed Authorised Consumption: Metered								0	0.0%					
BACU: Billed Authorised Consumption: Unmetered								0	0.0%					
NRW: NON-REVENUE WATER						2346.2	30.0%	128982	10.8%	\$C/m3	\$Cx1000	%		
A UACM: Unbilled Authorised Consumption: Metered						0.00%	0.0	0	0.0%	0.4626	1085.4	0.0%		
D UACU: Unbilled Authorised Consumption: Unmetered: Estimated as						1.250%	272.8	100.0%	19372	1.3%	0.4460	121.7	0.0%	
WL WATER LOSSES						2073.4	36.4%	148353	9.5%	0.4648	963.7	0.0%		
D UC: Unauthorised Consumption: Estimated as						0.250%	54.6	100.0%	775	0.3%	0.4460	24.3	0.0%	
B ALMUR1: Apparent Loss - meter under-registration:						Cycles	0.50%	95.8	7.0%	9	0.4%	0.8000	68.6	0.0%
B ALMUR2: Apparent Loss - meter under-registration:						Bulk Metering & Industrial	1.00%	24.3	7.0%	1	0.1%	0.8000	19.5	0.0%
ALMUR3: Apparent Loss - meter under-registration:								0.0	0	0.0%	0.8000	0.0	0.0%	
D ALDCD Customer meter data handling errors								0	0.0%	0.8000	0.0	0.0%		
AL: Sum of APPARENT LOSSES						164.7	33.3%	785	0.8%	0.6827	112.4	0.0%		
RL: REAL LOSSES						1909.7	38.7%	149138	8.7%	0.4460	851.3	0.0%		
A % of period system pressurized =						100.0%	365.0	days	Cost of running system in period =				\$Cx1000	
CARL: CURRENT ANNUAL REAL LOSSES (when system is pressurized)						5.23	MI/day							
Process Reliability Band	SYSTEM INFRASTRUCTURE AND PRESSURE DATA					Valid for UARL & ILI calc?	95% CLs as +/- %	ASSESSMENT OF UNAVOIDABLE REAL LOSSES, AND VOLUME AND COST OF POTENTIALLY RECOVERABLE REAL LOSSES						
								Notes: If Lm and Lp are in km and pressure P is in metres						
A Lm: Mains Length, km					541.40	Yes	1.0%	UBL in litres/hour = (20 x Lm + 1.25 x Nt + 33 x Lp) x (P/50) ^{1.5}						
A Nt: Number of Fire Hydrants					3803		1.0%	UARL in litres/day = (18 x Lm + 0.8 x Nt + 25 x Lp) x P						
B Np: Number of Separately Billed Properties					41210		2.0%	COMPONENT OF REAL LOSSES					95% CLs as +/- %	
B R: Ratio of billed Service Connections (Ns, main to property line) to Billed Props (Np)					1.000		2.0%	MI per day	MI in period	MI in period	\$Cx1000			
Ns: No. of billed Service Connections					41210		2.8%	UBL: UNAVOIDABLE BACKGROUND LEAKAGE						
C Nu: Number of Unbilled Service Connections					0			1.52	555	247.7	38.6%			
Nt: Total Number of Service Conns (= Ns + Nu), mains to property line					41210	Yes	2.8%	UARL: UNAVOIDABLE ANNUAL REAL LOSSES						
DC: Density of Connections/ km of mains = Ns/Lm					76.1		3.0%	2.29	837	373.5	26.1%			
B Lp: Average pipe length, property line to meter (m)					7.0		50.0%	CARL: CURRENT ANNUAL REAL LOSSES						
Lp: Total pipe length, property line to meter (km)					288.47		50.1%	5.23	1909	851.3	39.7%			
C P: Average pressure when system pressurised (psi)					65.0	Yes	25.0%	POTENTIALLY RECOVERABLE REAL LOSSES = CARL - UARL						
P: Average pressure when system pressurised (m)					46.0		25.0%	2.94	1071	477.8	73.5%			
IWA BEST PRACTICE PERFORMANCE INDICATOR						UNITS OF PERFORMANCE INDICATOR		Best estimate	95% CLs as +/- %	Lowest Estimate	Highest Estimate			
Non Revenue Water Basic (IWA Level 1, Fin36)						% of System Input by Volume		10.8	30.2%	7.5	14.0			
Non Revenue Water Basic (IWA Level 1, Fin37)						% of System Input by Value			30.2%					
Apparent Losses (IWA Op23)						Best Op23 PI >	% of Water Supplied (Distribution Systems)	0.8	33.5%	0.5	1.0			
							% of System Input Volume (Bulk Supply Systems)	0.8	33.5%	0.5	1.0			
Real Losses Basic (IWA Level 1, Op24)						Best Op24 PI >	Litres/service connection/day, when system pressurised	127	39.8%	76	177			
							m3/km of mains/day, when system pressurised	9.7	39.7%	5.8	13.5			
Real Losses Detailed (IWA Level 3, Op 25)							Infrastructure Leakage Index (ILI) (non-dimensional)	2.28	47.5%	1.20	3.36			
Comments:														
Region Billing Equation = (ST1+ST2+ST3+ST4+ST5)-SD1-SD2-SD3-SD4-SD5-SD6-SD7-SD8-SD9														
ST1, ST2, ST3 - June 30 & November 1, 2005														
ST4 - no report														
ST5 - June 30, 2005														
SD1, SD2, SD5, SD6 - May 20, 2005														
SD3 - May 24, 2005														
SD7 & SD8 - August 15 & November 2, 2005														
SD9 no report														
Process Reliability Bands:														
A - actual data														
B - calculated based on actual data														
C - calculated estimate														
D - no data / default														
Combinations, for example, B/C may be used to illustrate a calculated estimate based on partial data														
Allowance for 3m hydrant load for each hydrant built in to kilometers of water main.														

"LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'

[illegible]

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'				Standard	Version 1a	2nd Dec 2005	Canada
Utility City of St. Catharines				01/01/2004	to 01/01/2005	365	days
System Whole System							



'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE						
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'						
PIFastCalcs	Standard	Version 1a	2nd Dec 2005	Canada	Master.0000	City of St. Catharines


THIS WORKSHEET COMPARES THE CALCULATED SYSTEM ILI WITH WORLD BANK INSTITUTE GUIDELINES

World Bank Institute (WBI) Guidelines

The World Bank Institute has recently introduced, into its NRW Training Modules, a target matrix for Real Losses management performance, based on real losses in volume/service connection/day for a range of average operating pressures, and classified into Bands A to D. The targets assume that customer meters are located at the property boundary, with an average connection density of around 40 per km mains. Bands A to D in the WBI target matrix can also be shown as an equivalent range of ILIs, which can be applied to a wider range of connection densities and customer meter locations, as shown below. Band limits in terms of ILIs, general descriptions of each Band, and appropriate recommended actions are as follows:

Developing Countries	Developed Countries	BAND	Calculated ILI for this System	General description of Real Loss Management Performance Categories for Developed and Developing Countries
ILI range	ILI range			
Less than 4	Less than 2	A		Further loss reduction may be uneconomic unless there are shortages; careful analysis needed to identify cost-effective improvement
4 to < 8	2 to < 4	B	2.3	Potential for marked improvements; consider pressure management, better active leakage control practices, and better network maintenance
8 to < 16	4 to < 8	C		Poor leakage record; tolerable only if water is plentiful and cheap; even then, analyze level and nature of leakage and intensify leakage reduction efforts
16 or more	8 or more	D		Very inefficient use of resources; leakage reduction programs imperative and high priority

System ILI compared with WBI Bands for developed countries



WBI Recommendations for BANDS	A	B	C	D
Investigate pressure management options	Yes	Yes	Yes	
Investigate speed and quality of repairs	Yes	Yes	Yes	
Check economic intervention frequency	Yes	Yes		
Introduce/improve active leakage control		Yes	Yes	
Identify options for improved maintenance		Yes	Yes	
Assess Economic Leakage Level	Yes	Yes		
Review break frequencies		Yes	Yes	
Review asset management policy		Yes	Yes	Yes
Deal with deficiencies in manpower, training and communications			Yes	Yes
5-year plan to achieve next lowest band			Yes	Yes
Fundamental peer review of all activities				Yes

GUIDELINE 2: The AWWA Water Loss Committee general guidelines for setting a target ILI (in lieu of having a determination of a system-specific economic level of leakage). **Source of information:** Table 7 in the AWWA Water Loss Committee Report in the AWWA Journal, August 2003

Note: since this table was published, simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalcs software. This has allowed the development of the ELLCalcs software to calculate short-term ELL for an active leakage control policy of regular survey. Data from England & Wales (where many Water Companies are recognised as having achieved ELL) suggests that in developed countries, the ELL (in terms of ILI) is unlikely to exceed 3.0, even where water is plentiful and inexpensive.

Target ILI Range	This System ILI	Water Resources Considerations	Operational Considerations	Financial Considerations
1.0 - 3.0	2.3	Available resources are greatly limited and are very difficult and/or environmentally unsound to develop	Operating with system leakage above this level would require expansion of existing infrastructure and/or additional water resources to meet the demand	Water resources are costly to develop or purchase; ability to increase revenues via water rates is greatly limited because of regulation or low ratepayer affordability
3.0 - 5.0		Water resources are believed to be sufficient to meet long-term needs, but demand management interventions (leakage management, water conservation) are included in the long-term planning	Existing water supply infrastructure capability is sufficient to meet long-term demand as long as reasonable leakage management controls are in place	Water resources can be developed or purchased at reasonable expense; periodic water rate increases can be feasibly imposed and are tolerated by the customer population
5.0 - 8.0		Water resources are plentiful, reliable, and easily abstracted	Superior reliability, capacity and integrity of the water supply infrastructure make it relatively immune to shortages	Cost to purchase or obtain/treat water is low, as are rates charged to customers
Greater than 8.0		Although operational and financial considerations may allow a long-term ILI greater than 8.0, such a level of leakage is not an effective utilization of water as a resource. Setting a target level greater than 8.0 - other than as an incremental goal to a smaller long-term target - is discouraged.		

Note: Simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalcs Standard software. This has allowed the development of the ELLCalcs standard software to calculate short-term Economic Leakage Level for an active leakage control policy of regular survey.

Important Footnote: the Infrastructure Leakage Index (ILI) provides guidance as to how well real losses are being managed (in terms of repairs, active leakage control and infrastructure management) at the current operating pressure. However, calculation of the ILI does not imply that pressure management in a system is optimal, or economic. If system pressures are excessive, or subject to surges, then pressure management may result in additional benefits for real losses management - in particular, a reduction in new burst frequency and annual repair costs, and a reduction in flow rates of existing leaks. So even if a low ILI is being achieved, there may still be opportunities to reduce annual real losses by improved pressure management. The PressCalcs Standard Software provides more detailed information on this topic.

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE									
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'				Standard	Version 1a	2nd Dec 2005	Canada	Master.0000	
OPTIONAL DATA ENTRY SHEET FOR ANNUAL SYSTEM RUNNING COSTS				Data entry		Calculated Values	From another Worksheet		
Utility	City of St. Catharines		01/01/2004	to	1/1/2005	Number of Days in Period	365	days	
System	Whole System		Calculation by		Steve Genser	Date of calculation =	12/4/2006		
Total running costs as calculated below =				0.0	\$Cx1000	Transfer this figure to Cell L30 of 'WaterBalance&Pis' Worksheet			
Note: The following definitions of annual system running costs should be considered as guidelines only. They are based on the 'Financial Definitions' in pages 19 and 20 of the IWA 'Manual of Best Practice 'Performance Indicators for Water Supply Services', (Alegre H, Hirner W, Baptista J.M. and Parena R, July 2000, ISBN 1 900222 27 2, IWA Publishing; this report should be consulted for further guidance as necessary.									
		Sub-total	Group total						
		\$Cx1000	\$Cx1000						
Operational Costs				INCLUDES					
Imported water	Raw water		0.0	BULK SUPPLY IMPORTS: total payments for imported raw water					
	Treated water			BULK SUPPLY IMPORTS: total payments for imported treated water					
Energy	Raw water		0.0	POWER: all energy costs for water supply electricity and fuel for motive machinery					
	Treatment								
	Transmission								
	Distribution								
External services: Outsourcing	Outsourcing		0.0	Outsourcing of technical or administrative services, such as consultants, contractors undertaking operational tasks, meter reading and accounting fees					
	Software licences and IT support			Licence fees on computer software and technical support by software companies					
	Associated Companies			Costs of associated companies that are not included in other items					
	Third party services			Operating costs of providing water services to third parties (other than the regulated water supply function) that are not included in other items					
Leasing and Rentals	Premises		0.0	Payments for leasing or renting premises					
	Vehicles			Payments for leasing or renting vehicles					
	Mobile Plant			Payments for leasing or renting mobile plant					
	Fixed Plant			Payments for leasing or renting fixed plant					
Purchases	Equipment		0.0	Payments for leasing or renting equipment					
	Water treatment chemicals			All water treatment chemicals for water supply that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems					
	Other than chemicals and energy			All materials and consumables other than energy and water treatment chemicals for water supply, that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems					
Taxes, levies and fees	All kinds		0.0	Any operating licences paid to a Government or municipal authority, abstraction charges, local authority rates					
Exceptional earnings and losses	All kinds		0.0	Any exceptional income or expenditure from donations, investment subsidies, compensations or adjustments related to sales/writing off of fixed assets					
Other Operating Expenditures	Other direct costs		0.0	Any other operating costs (but excluding interest and taxation, on an aggregated basis)					
	General and support expenditures			The aggregate direct cost of GENERAL AND SUPPORT ACTIVITIES (Manpower costs excluded)					
	Customer services			Costs directly associated with customer services that are not included in previous items, related to customer accounting, reading of meters, debt recovery, costs of disconnections, customers'enquiries and complaints handling.					
	Scientific services			Costs directly associated with scientific and laboratory services and with the monitoring of quality that are not included in previous items					
	Other business activities			Costs directly associated with other business activities that are not included in previous items, except for cost depreciation					
	Doubtful debts			Charge/credit to the profit and loss account for bad and doubtful debts					
Sum of Operational Costs	All the above operational costs		0.0						
Internal manpower costs	Employment costs		0.0	The sum of the total manpower costs of permanent and temporary personnel, including employment-related social costs and benefits paid by the employer					
Capitalised cost of self-constructed assets	Negative allocation		0.0	The summation of the amounts in each of the above cost categories that have been incurred in the construction of new or rehabilitated assets					
Total Running Costs	Sum of Operational costs and Internal Manpower Costs, minus capitalised cost of self-constructed assets		0.0						
Comments:									

Appendix N

PIFastCalc Output Thorold

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE																		
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PiFastCalcs'										Standard		Version 1a		2nd Dec 2005		Canada		
ANNUAL WATER BALANCE CALCULATION IN IWA STANDARD FORMAT, WITH 95% CONFIDENCE LIMITS										Data entry		Defaults		Calculated Values		From another Worksheet		
Note: Calculations should be based on a 12-month period for all aspects of the worksheet to function correctly																		
Utility City of Thorold										Currency =		\$C		Volume units =		MI and m ³		
System Whole System										01/01/2005 to		01/01/2006		=		365 days		
Do most customers have storage tanks?										No		Calculation by		Steve Genser		Date 4-Dec-06		
Process Reliability Band	WATER BALANCE CALCULATIONS										Volume in period	95% Confidence Limit as +/- %	Variance	FINANCIAL PERFORMANCE INDICATORS FOR NON-REVENUE WATER				
	IWA Terminology													% of System Input Volume	Calculated Value of NRW as % of System Running Costs in Period	Assessed marginal cost of individual components of Non-Revenue Water	Assessed Unit Value of individual components of Non Revenue Water	% of cost of running system
	COMPONENTS OF WATER BALANCE																	
	WOS: Volume from Own Sources (corrected for known systematic errors)																	
	A W: Water Imported (corrected for known systematic errors)																	
	SIV: SYSTEM INPUT VOLUME																	
	A BACE: Water Exported																	
	WS: WATER SUPPLIED = SIV - BACE																	
	B/C BACM1: Billed Authorised Consumption: Metered Residential (~ 70%)																	
	B/C BACM2: Billed Authorised Consumption: Metered ICI (~ 30%)																	
BACM3: Billed Authorised Consumption: Metered																		
BACU: Billed Authorised Consumption: Unmetered																		
NRW: NON-REVENUE WATER										800.8	12.4%	2573	25.1%	0.4850	388.4	14.7%		
A UACM: Unbilled Authorised Consumption: Metered										0.00%	of WS	0	0.0%	0.4460	0.0	0.0%		
D UACU: Unbilled Authorised Consumption: Unmetered: Estimated as 1.250% of WS										39.8	100.0%	413	1.3%	0.4460	17.8	0.7%		
WIL WATER LOSSES										761.0	14.1%	2987	23.0%	0.4870	370.6	14.0%		
D UC: Unauthorised Consumption: Estimated as 0.250% of WS										8.0	100.0%	17	0.3%	1.7690	14.1	0.5%		
B/C ALMUR1: Apparent Loss - meter under-registration: Residential (~ 70%)										8.4	7.0%	0	0.3%	1.7690	14.8	0.6%		
B/C ALMUR2: Apparent Loss - meter under-registration: ICI (~ 30%)										7.2	7.0%	0	0.2%	1.7690	12.8	0.5%		
ALMUR3: Apparent Loss - meter under-registration:										0.0		0	0.0%	1.7690	0.0	0.0%		
D ALDCD Customer meter data handling errors										0		0	0.0%	1.7690	0.0	0.0%		
AL: Sum of APPARENT LOSSES										23.6	33.9%	17	0.7%	1.7690	41.7	1.6%		
RL: REAL LOSSES										737.4	14.6%	3003	23.1%	0.4460	328.9	12.4%		
A % of period system pressurised = 100.0% 365.0 days										Cost of running system in period = 2648.4 \$C x 1000								
CARL: CURRENT ANNUAL REAL LOSSES (when system is pressurised)										2.02 MI/day								
Process Reliability Band	SYSTEM INFRASTRUCTURE AND PRESSURE DATA										Valid for UARL & ILI calc?	95% CLs as +/- %	ASSESSMENT OF UNAVOIDABLE REAL LOSSES, AND VOLUME AND COST OF POTENTIALLY RECOVERABLE REAL LOSSES					
	A Lm: Mains Length, km 90.60 Yes 1.0%												Notes: If Lm and Lp are in km and pressure P is in metres					
	A Nh: Number of Fire Hydrants 600 1.0%												UBL in litres/hour = (20 x Lm + 1.25 x Nh + 33 x Lp) x (P/50) ^{1.5}					
	B Ns: Number of Separately Billed Properties 6269 2.0%												UARL in litres/day = (10 x Lm + 0.8 x Nh + 25 x Lp) x P					
	B R: Ratio of Billed Service Connections (Ns, main to property line) to Billed Props (Nb) 1.000 2.0%												COMPONENT OF REAL LOSSES					
	Ns: No. of billed Service Connections 6269 2.8%												MI MI \$C x 1000					
	B Nu: Number of Unbilled Service Connections 25 10.0%												per day in period in period 95% CLs as +/- %					
	Nt: Total Number of Service Conns (= Ns + Nu), mains to property line 6294 Yes 2.8%												UBL: UNAVOIDABLE BACKGROUND LEAKAGE 0.23 85 37.9 2.4%					
	DC: Density of Connections/ km of mains = Ns/Lm 69.5 3.0%												UARL: UNAVOIDABLE ANNUAL REAL LOSSES 0.36 132 59.0 2.1%					
	B Lp: Average pipe length, property line to meter (m) 10.2 2.4%												CARL: CURRENT ANNUAL REAL LOSSES 2.02 737 328.9 14.6%					
A P: Average pressure when system pressurised (psi) 62.0 1.0%										POTENTIALLY RECOVERABLE REAL LOSSES = CARL - UARL 1.66 605 269.9 17.8%								
P: Average pressure when system pressurised (m) 43.8 1.0%																		
IWA BEST PRACTICE PERFORMANCE INDICATOR										UNITS OF PERFORMANCE INDICATOR				Best estimate	95% CLs as +/- %	Lowest Estimate	Highest Estimate	
Non Revenue Water Basic (IWA Level 1, Fin36)										% of System Input by Volume				25.1	12.8%	21.9	28.3	
Non Revenue Water Basic (IWA Level 1, Fin37)										% of System Input by Value				14.7	12.8%	12.8	16.5	
Apparent Losses (IWA Op23)										% of Water Supplied (Distribution Systems)				0.7	34.1%	0.5	1.0	
Real Losses Basic (IWA Level 1, Op24)										% of System Input Volume (Bulk Supply Systems)				0.7	34.1%	0.5	1.0	
Real Losses Detailed (IWA Level 3, Op 25)										Litres/service connection/day, when system pressurised				321	14.8%	273	369	
										m3/km of mains/day, when system pressurised				22.3	14.6%	19.0	25.6	
										Infrastructure Leakage Index ILI (non-dimensional)				5.58	14.7%	4.76	6.40	
Comments:																		
Region billing equation = 1D4+5D1-5D2+5D3+5D4; Calibration reports as follows:																		
5D1 & 5D2 - May 20																		
5D3 - May 24																		
5D4 - No report																		
1D4 - calibration report for May 4 illustrates the meter was significantly under-registering and was repaired.																		
- calibration report on Oct. 13 illustrates the meter was again under-registering and was repaired.																		
Process Reliability Bands:																		
A - actual data																		
B - calculated based on actual data																		
C - calculated estimate																		
D - no data / default																		
Combinations, for example, B/C may be used to illustrate a calculated estimate based on partial data																		
Total length of watermain allow for 3 m per hydrant																		

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'

DETAILED CALCULATION OF COMPONENTS OF AUTHORISED AND UNAUTHORISED CONSUMPTION

DETAILED CALCULATION OF COMPONENTS OF AUTHORISED AND UNAUTHORISED CONSUMPTION				From another Worksheet	
Utility City of Theroild		Data entry	Calculated Values		
System Whole System		01/01/2005 to Calculation by	=	365 days	
					Date

	Data entry	Calculated Values	From another Worksheet
01/01/2005 to Calculation by	01/01/2006 =	365 days	Date

Date	
From another Worksheet	

Components of Authorised Consumption	Components in MI				Total	Additional information on sources of data and basis of estimates
	Billed Metered	Billed Unmetered	Unbilled Metered	Unbilled Unmetered		
						E = estimated
						R = Based on recordings









[illegible]

Authorised consumption sub-total	0.00	0.00	0.00	0.00	0.00	0.00
Authorised Unbilled Unmetered Consumption = 0.0000% of Water Supplied, transfer this figure to Cell E21 of 'WaterBalance & Billing' Worksheet						

Concentration of Inactivated Concentration	MM
100	100
50	50
25	25
12.5	12.5
6.25	6.25
3.125	3.125
1.5625	1.5625
0.78125	0.78125
0.390625	0.390625
0.1953125	0.1953125
0.09765625	0.09765625
0.048828125	0.048828125
0.0244140625	0.0244140625
0.01220703125	0.01220703125
0.006103515625	0.006103515625
0.0030517578125	0.0030517578125
0.00152587890625	0.00152587890625
0.000762939453125	0.000762939453125
0.0003814697265625	0.0003814697265625
0.00019073486328125	0.00019073486328125
0.000095367431640625	0.000095367431640625
0.0000476837158203125	0.0000476837158203125
0.00002384185791015625	0.00002384185791015625
0.000011920928955078125	0.000011920928955078125
0.0000059604644775390625	0.0000059604644775390625
0.00000298023223876953125	0.00000298023223876953125
0.000001490116119384765625	0.000001490116119384765625
0.0000007450580596923828125	0.0000007450580596923828125
0.00000037252902984619140625	0.00000037252902984619140625
0.000000186264514923095703125	0.000000186264514923095703125
0.0000000931322574615478515625	0.0000000931322574615478515625
0.00000004656612873077392578125	0.00000004656612873077392578125
0.000000023283064365386962890625	0.000000023283064365386962890625
0.0000000116415321826934814453125	0.0000000116415321826934814453125
0.00000000582076609134674072265625	0.00000000582076609134674072265625
0.000000002910383045673370361328125	0.000000002910383045673370361328125
0.0000000014551915228366851806640625	0.0000000014551915228366851806640625
0.00000000072759576141834259033203125	0.00000000072759576141834259033203125
0.000000000363797880709171295166015625	0.000000000363797880709171295166015625
0.0000000001818989403545856475830078125	0.0000000001818989403545856475830078125
0.00000000009094947017729282379150390625	0.00000000009094947017729282379150390625
0.000000000045474735088646411895751953125	0.000000000045474735088646411895751953125
0.0000000000227373675443232059478759765625	0.0000000000227373675443232059478759765625
0.00000000001136868377216160297393798828125	0.00000000001136868377216160297393798828125
0.000000000005684341886080801486968994140625	0.000000000005684341886080801486968994140625
0.0000000000028421709430404007434844970703125	0.0000000000028421709430404007434844970703125
0.00000000000142108547152020037174224853515625	0.00000000000142108547152020037174224853515625
0.000000000000710542735760100185871124267578125	0.000000000000710542735760100185871124267578125
0.0000000000003552713678800500929355621337890625	0.0000000000003552713678800500929355621337890625
0.00000000000017763568394002504646778106689453125	0.00000000000017763568394002504646778106689453125
0.000000000000088817841970012523233890533447265625	0.000000000000088817841970012523233890533447265625
0.0000000000000444089209850062616169452667236328125	0.0000000000000444089209850062616169452667236328125
0.00000000000002220446049250313080847263336181640625	0.00000000000002220446049250313080847263336181640625
0.000000000000011102230246251565404236316680908203125	0.000000000000011102230246251565404236316680908203125
0.0000000000000055511151231257827021181583340541015625	0.0000000000000055511151231257827021181583340541015625
0.000000000000002775557	

Components of Organized Consumption	Mil	Method of estimation

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'					Standard	Version 1a	2nd Dec 2005	Canada
Utility/City of Thorold					01/01/2005	to 01/01/2006	365	days
System/Whole System								



'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE									
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'				Standard	Version 1a	2nd Dec 2005	Canada	Master.0000	
OPTIONAL DATA ENTRY SHEET FOR ANNUAL SYSTEM RUNNING COSTS									
Utility	City of Thorold	01/01/2005	to	1/1/2006	Calculated Values	From another Worksheet			
System	Whole System	Calculation by			Steve Genser	Number of Days in Period	365	days	
					Date of calculation =	12/4/2006			
Total running costs as calculated below =		0.0			\$Cx1000	Transfer this figure to Cell L30 of 'WaterBalance&Pis' Worksheet			
Note: The following definitions of annual system running costs should be considered as guidelines only. They are based on the 'Financial Definitions' in pages 19 and 20 of the IWA 'Manual of Best Practice Performance Indicators for Water Supply Services', (Alegre H, Hirner W, Baptista J.M. and Parena R, July 2000, ISBN 1 900222 27 2, IWA Publishing; this report should be consulted for further guidance as necessary.									
		Sub-total	Group total						
		\$Cx1000	\$Cx1000	INCLUDES					
Operational Costs	Imported water		0.0	BULK SUPPLY IMPORTS: total payments for imported raw water					
	Treated water			BULK SUPPLY IMPORTS: total payments for imported treated water					
Energy	Raw water		0.0	POWER: all energy costs for water supply electricity and fuel for motive machinery					
	Treatment								
	Transmission								
	Distribution								
External services: Outsourcing	Outsourcing		0.0	Outsourcing of technical or administrative services, such as consultants, contractors undertaking operational tasks, meter reading and accounting fees					
	Software licences and IT support			Licence fees on computer software and technical support by software companies					
	Associated Companies			Costs of associated companies that are not included in other items					
	Third party services			Operating costs of providing water services to third parties (other than the regulated water supply function) that are not included in other items					
Leasing and Rentals	Premises		0.0	Payments for leasing or renting premises					
	Vehicles			Payments for leasing or renting vehicles					
	Mobile Plant			Payments for leasing or renting mobile plant					
	Fixed Plant			Payments for leasing or renting fixed plant					
Purchases	Equipment		0.0	Payments for leasing or renting equipment					
	Water treatment chemicals			All water treatment chemicals for water supply that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems					
	Other than chemicals and energy			All materials and consumables other than energy and water treatment chemicals for water supply, that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems					
Taxes, levies and fees	All kinds		0.0	Any operating licences paid to a Government or municipal authority, abstraction charges, local authority rates					
Exceptional earnings and losses	All kinds		0.0	Any exceptional income or expenditure from donations, investment subsidies, compensations or adjustments related to sales/writing off of fixed assets					
Other Operating Expenditures	Other direct costs		0.0	Any other operating costs (but excluding interest and taxation, on an aggregated basis)					
	General and support expenditures			The aggregate direct cost of GENERAL AND SUPPORT ACTIVITIES (Manpower costs excluded)					
	Customer services			Costs directly associated with customer services that are not included in previous items, related to customer accounting, reading of meters, debt recovery, costs of disconnections, customers'enquiries and complaints handling.					
	Scientific services			Costs directly associated with scientific and laboratory services and with the monitoring of quality that are not included in previous items					
	Other business activities			Costs directly associated with other business activities that are not included in previous items, except for cost depreciation					
	Doubtful debts			Charge/credit to the profit and loss account for bad and doubtful debts					
Sum of Operational Costs	All the above operational costs		0.0						
Internal manpower costs	Employment costs		0.0	The sum of the total manpower costs of permanent and temporary personnel, including employment-related social costs and benefits paid by the employer					
Capitalised cost of self-constructed assets	Negative allocation		0.0	The summation of the amounts in each of the above cost categories that have been incurred in the construction of new or rehabilitated assets					
Total Running Costs	Sum of Operational costs and Internal Manpower Costs, minus capitalised cost of self-constructed assets		0.0						
Comments:									

Appendix O

PIFastCalc Output West Lincoln

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE													
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PiFastCalcs'													
ANNUAL WATER BALANCE CALCULATION IN IWA STANDARD FORMAT, WITH 95% CONFIDENCE LIMITS													
Note: Calculations should be based on a 12-month period for all aspects of the worksheet to function correctly													
				Standard	Version 1a	2nd Dec 2005		Canada					
				Data entry	Defaults	Calculated Values		From another Worksheet					
				Currency =	\$C	Volume units =	ML	and	m ³				
Utility Township of West Lincoln				Bulk supply (BS) or Distribution System (DS)?	DS	01/01/2005	to	01/01/2006	=	365	days		
System Whole System				Do most customers have storage tanks?	No	Calculation by	Steve Genser	Date	4-Dec-06				
Process Reliability Band	WATER BALANCE CALCULATIONS					Volume in period	95% Confidence Limit as +/- %	Variance	FINANCIAL PERFORMANCE INDICATORS FOR NON-REVENUE WATER				
	IWA Terminology								% of System Input Volume	Calculated Value of NRW as % of System Running Costs in Period			
	COMPONENTS OF WATER BALANCE												
	WOS: Volume from Own Sources (corrected for known systematic errors)												
	A	Wi: Water Imported (corrected for known systematic errors)											
	SIV: SYSTEM INPUT VOLUME												
	BACE: Water Exported												
	WS: WATER SUPPLIED = SIV - BACE												
	A/B	BACM1: Billed Authorised Consumption: Metered Residential / ICI											
	A	BACM2: Billed Authorised Consumption: Metered Bulk metering											
BACM3: Billed Authorised Consumption: Metered													
BACU: Billed Authorised Consumption: Unmetered													
NRW: NON-REVENUE WATER					105.9	24.8%	180	12.8%	0.4598	48.7	13.1%		
A	UACM: Unbilled Authorised Consumption: Metered				0.00%	of WS							
D	UACU: Unbilled Authorised Consumption: Unmetered: Estimated as				1.250%	of WS	10.3	100.0%	28	1.3%	0.4460	4.6	1.2%
WL WATER LOSSES					95.6	29.6%	208	11.6%	0.4613	44.1	11.8%		
C	UC: Unauthorised Consumption: Estimated as				0.020%	of WS	0.2	50.0%	0	0.0%		0.0	0.0%
B/C	ALMUR1: Apparent Loss - meter under-registration: Residential / ICI				0.50%	of BACM1	2.8	7.0%	0	0.3%	0.7919	2.2	0.6%
ALMUR2: Apparent Loss - meter under-registration: Bulk metering				1.00%	of BACM2	1.6	7.0%	0	0.2%	0.7919	1.3	0.3%	
ALMUR3: Apparent Loss - meter under-registration:					of BACM3 and UACM	0.0		0	0.0%	0.7919	0.0	0.0%	
D	ALDOD Customer meter data handling errors						0	0.0%	0.7919	0.0	0.0%		
AL: Sum of APPARENT LOSSES					4.6	5.2%	0	0.6%	0.7635	3.5	0.9%		
RL: REAL LOSSES					91.0	31.1%	208	11.0%	0.4460	40.6	10.9%		
A	% of period system pressurised =				100.0%	365.0	days	Cost of running system in period =				372.8	\$C x 1000
CARL: CURRENT ANNUAL REAL LOSSES (when system is pressurised)					0.25	ML/day							

Process Reliability Band	SYSTEM INFRASTRUCTURE AND PRESSURE DATA			Valid for UARL ILI calc?	95% CLs as +/- %
A	Lm: Mains Length, km	28.53	No	1.0%	
A	Nh: Number of Fire Hydrants	175		1.0%	
B	Nb: Number of Separately Billed Properties	1755		2.0%	
B	R: Ratio of billed Service Connections (Ns, main to property line) to Billed Props (Nb)	1.000		2.0%	
B	Ns: No. of billed Service Connections	1755		2.8%	
B	Nu: Number of Unbilled Service Connections	6		16.0%	
	Nt: Total Number of Service Conns (= Ns + Nu), mains to property line	1761	No	2.8%	
	DC: Density of Connections/ km of mains = Ns/Lm	61.7		3.0%	
B	Lp: Average pipe length, property line to meter (m)	9.0		11.0%	
	Lp: Total pipe length, property line to meter (km)	15.80		11.4%	
B	P: Average pressure when system pressurised (psi)	62.0		16.0%	
	P: Average pressure when system pressurised (m)	43.8	Yes	10.0%	

ASSESSMENT OF UNAVOIDABLE REAL LOSSES, AND VOLUME AND COST OF POTENTIALLY RECOVERABLE REAL LOSSES					
Notes: If Lm and Lp are in km and pressure P is in metres					
UBL in litres/hour = $(20 \times Lm + 1.25 \times Nh + 33 \times Lp) \times (P/50)^{1.5}$					
UARL in litres/day = $(18 \times Lm + 0.8 \times Nh + 25 \times Lp) \times P$					
COMPONENT OF REAL LOSSES		MI per day	MI in period	\$C x 1000 in period	95% CLs as +/- %
UBL: UNAVOIDABLE BACKGROUND LEAKAGE		0.06	24	10.6	15.3%
UARL: UNAVOIDABLE ANNUAL REAL LOSSES		0.10	37	16.5	10.3%
CARL: CURRENT ANNUAL REAL LOSSES		0.25	91	40.6	31.1%
POTENTIALLY RECOVERABLE REAL LOSSES = CARL - UARL		0.15	54	24.0	52.9%

IWA BEST PRACTICE PERFORMANCE INDICATOR		UNITS OF PERFORMANCE INDICATOR		Best estimate	95% CLs as +/- %	Lowest Estimate	Highest Estimate
Non Revenue Water Basic (IWA Level 1, Fin36)		% of System Input by Volume		12.8	25.0%	9.6	16.0
Non Revenue Water Basic (IWA Level 1, Fin37)		% of System Input by Value		13.1	25.0%	9.8	16.3
Apparent Losses (IWA Op23)	Best Op23 PI >	% of Water Supplied (Distribution Systems)		0.6	6.0%	0.5	0.6
		% of System Input Volume (Bulk Supply Systems)		0.6	6.0%	0.5	0.6
Real Losses Basic (IWA Level 1, Op24)	Best Op24 PI >	Litres/service connection/day, when system pressurised		142	31.2%	97	186
		m3/km of mains/day, when system pressurised		8.7	31.1%	6.0	11.5
Real Losses Detailed (IWA Level 3, Op 25)		Infrastructure Leakage Index ILI (non-dimensional)		2.45	32.7%	1.65	3.26

Comments:

Water supplied via Regional Municipality of Niagara's Grimsby Water Treatment Plant via Mudstreet.

Meter (ID 6D2). Meter Calibration Report dated May 24, 2005.

AM Billing Data broken into Quantities Metered each month combines monthly reads and quarterly reads. Second category is Bulk Metering with monthly record.

Process Reliability Bands:

A - actual data
B - calculated based on actual data
C - calculated estimate
D - no data / default

Combinations, for example, B/C may be used to illustrate a calculated estimate based on partial data

Total length of watermain allow for 3 m per hydrant

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'









DETAILED CALCULATION OF COMPONENTS OF AUTHORISED AND UNAUTHORISED CONSUMPTION

Utility	Township of West Lincoln	System	Whole System	01/01/2005	to	01/01/2006	=	365	days	Calculated Values	From another Worksheet
				Calculation by		Steve Genser					Date
											2nd July 2005

Components of Authorised Consumption		Components in MI				Total	Additional information on sources of data and basis of estimates	
		Billed Metered	Billed Unmetered	Unbilled Metered	Unbilled Unmetered		E = estimated R = Based on recordings	
Quantities Metered						0.00		
January	0.113					0.11	R = Based on recordings	
February	0.148					0.15	R = Based on recordings	
March	139.669					139.67	R = Based on recordings	
April	0.175					0.18	R = Based on recordings	
May	0.239					0.24	R = Based on recordings	
June	137.622					137.62	R = Based on recordings	
July	0.202					0.20	R = Based on recordings	
August	0.862					0.86	R = Based on recordings	
September	172.256					172.26	R = Based on recordings	
October	0.209					0.21	R = Based on recordings	
November	0.402					0.40	R = Based on recordings	
December	106.889					106.89	R = Based on recordings	
Bulk Metering						0.00		
January	9.118					9.12	R = Based on recordings	
February	11.222					11.22	R = Based on recordings	
March	13.706					13.71	R = Based on recordings	
April	8.730					8.73	R = Based on recordings	
May	21.174					21.17	R = Based on recordings	
June	21.061					21.06	R = Based on recordings	
July	20.726					20.73	R = Based on recordings	
August	13.009					13.01	R = Based on recordings	
September	8.567					8.57	R = Based on recordings	
October	15.538					15.54	R = Based on recordings	
November	7.196					7.20	R = Based on recordings	
December	12.613					12.61	R = Based on recordings	
						0.00		
						0.00		
						0.00		
Authorised consumption sub-totals		721.45	0.00	0.00	0.00	721.45	MI	
Authorised Unbilled Unmetered Consumption =						0.000%	of Water Supplied. Transfer this figure to Cell E21 of 'Water Balance & Dis.' Worksheet	

[illegible]

WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'				Standard	Version 1a	2nd Dec 2005	Canada
Utility/Township of West Lincoln				01/01/2005 to 01/01/2006	365	days	
System/Whole System							



'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE						
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PIFastCalcs'						
PIFastCalcs	Standard	Version 1a	2nd Dec 2005	Canada	Master.0000	Township of West Lincoln


THIS WORKSHEET COMPARES THE CALCULATED SYSTEM ILI WITH WORLD BANK INSTITUTE GUIDELINES

World Bank Institute (WBI) Guidelines

The World Bank Institute has recently introduced, into its NRW Training Modules, a target matrix for Real Losses management performance, based on real losses in volume/service connection/day for a range of average operating pressures, and classified into Bands A to D. The targets assume that customer meters are located at the property boundary, with an average connection density of around 40 per km mains. Bands A to D in the WBI target matrix can also be shown as an equivalent range of ILIs, which can be applied to a wider range of connection densities and customer meter locations, as shown below. Band limits in terms of ILIs, general descriptions of each Band, and appropriate recommended actions are as follows:

Developing Countries	Developed Countries	BAND	Calculated ILI for this System	General description of Real Loss Management Performance Categories for Developed and Developing Countries
ILI range	ILI range			
Less than 4	Less than 2	A		Further loss reduction may be uneconomic unless there are shortages; careful analysis needed to identify cost-effective improvement
4 to < 8	2 to < 4	B	2.5	Potential for marked improvements; consider pressure management, better active leakage control practices, and better network maintenance
8 to < 16	4 to < 8	C		Poor leakage record; tolerable only if water is plentiful and cheap; even then, analyze level and nature of leakage and intensify leakage reduction efforts
16 or more	8 or more	D		Very inefficient use of resources; leakage reduction programs imperative and high priority

System ILI compared with WBI Bands for developed countries



WBI Recommendations for BANDS	A	B	C	D
Investigate pressure management options	Yes	Yes	Yes	
Investigate speed and quality of repairs	Yes	Yes	Yes	
Check economic intervention frequency	Yes	Yes		
Introduce/improve active leakage control		Yes	Yes	
Identify options for improved maintenance		Yes	Yes	
Assess Economic Leakage Level	Yes	Yes		
Review break frequencies		Yes	Yes	
Review asset management policy		Yes	Yes	Yes
Deal with deficiencies in manpower, training and communications			Yes	Yes
5-year plan to achieve next lowest band			Yes	Yes
Fundamental peer review of all activities				Yes

GUIDELINE 2: The AWWA Water Loss Committee general guidelines for setting a target ILI (in lieu of having a determination of a system-specific economic level of leakage). Source of information: Table 7 in the AWWA Water Loss Committee Report in the AWWA Journal, August 2003

Note: since this table was published, simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalcs software. This has allowed the development of the ELLCalcs software to calculate short-term ELL for an active leakage control policy of regular survey. Data from England & Wales (where many Water Companies are recognised as having achieved ELL) suggests that in developed countries, the ELL (in terms of ILI) is unlikely to exceed 3.0, even where water is plentiful and inexpensive.

Target ILI Range	This System ILI	Water Resources Considerations	Operational Considerations	Financial Considerations
1.0 - 3.0	2.5	Available resources are greatly limited and are very difficult and/or environmentally unsound to develop	Operating with system leakage above this level would require expansion of existing infrastructure and/or additional water resources to meet the demand	Water resources are costly to develop or purchase; ability to increase revenues via water rates is greatly limited because of regulation or low ratepayer affordability
3.0 - 5.0		Water resources are believed to be sufficient to meet long-term needs, but demand management interventions (leakage management, water conservation) are included in the long-term planning	Existing water supply infrastructure capability is sufficient to meet long-term demand as long as reasonable leakage management controls are in place	Water resources can be developed or purchased at reasonable expense; periodic water rate increases can be feasibly imposed and are tolerated by the customer population
5.0 - 8.0		Water resources are plentiful, reliable, and easily abstracted	Superior reliability, capacity and integrity of the water supply infrastructure make it relatively immune to shortages	Cost to purchase or obtain/treat water is low, as are rates charged to customers
Greater than 8.0		Although operational and financial considerations may allow a long-term ILI greater than 8.0, such a level of leakage is not an effective utilization of water as a resource. Setting a target level greater than 8.0 - other than as an incremental goal to a smaller long-term target - is discouraged.		

Note: Simplified methods of calculating an economic frequency of intervention for active leakage control by regular survey have been developed and are included in the ALCCalcs Standard software. This has allowed the development of the ELLCalcs standard software to calculate short-term Economic Leakage Level for an active leakage control policy of regular survey.

Important Footnote: the Infrastructure Leakage Index (ILI) provides guidance as to how well real losses are being managed (in terms of repairs, active leakage control and infrastructure management) at the current operating pressure. However, calculation of the ILI does not imply that pressure management in a system is optimal, or economic. If system pressures are excessive, or subject to surges, then pressure management may result in additional benefits for real losses management - in particular, a reduction in new burst frequency and annual repair costs, and a reduction in flow rates of existing leaks. So even if a low ILI is being achieved, there may still be opportunities to reduce annual real losses by improved pressure management. The PressCalcs Standard Software provides more detailed information on this topic.

'LEAKS' Suite of LEAKAGE EVALUATION and ASSESSMENT KNOW-HOW SOFTWARE							
WATER BALANCE AND PERFORMANCE INDICATORS PROGRAM 'PiFastCalcs'				Standard	Version 1a	2nd Dec 2005	Canada Master.0000
OPTIONAL DATA ENTRY SHEET FOR ANNUAL SYSTEM RUNNING COSTS				Data entry		Calculated Values	From another Worksheet
Utility	Township of West Lincoln		01/01/2005	to	1/1/2006	Number of Days in Period	365 days
System	Whole System		Calculation by		Steve Genser	Date of calculation =	12/4/2006

Note: The following definitions of annual system running costs should be considered as guidelines only. They are based on the 'Financial Definitions' in pages 19 and 20 of the IWA 'Manual of Best Practice 'Performance Indicators for Water Supply Services', (Alegre H, Hirner W, Baptista J.M. and Parena R, July 2000, ISBN 1 900222 27 2, IWA Publishing; this report should be consulted for further guidance as necessary.

		Sub-total \$Cx1000	Group total \$Cx1000	INCLUDES
Operational Costs	Imported water		0.0	BULK SUPPLY IMPORTS: total payments for imported raw water
	Treated water			BULK SUPPLY IMPORTS: total payments for imported treated water
Energy	Raw water		0.0	POWER: all energy costs for water supply electricity and fuel for motive machinery
	Treatment			
	Transmission			
	Distribution			
External services: Outsourcing	Outsourcing		0.0	Outsourcing of technical or administrative services, such as consultants, contractors undertaking operational tasks, meter reading and accounting fees
	Software licences and IT support			Licence fees on computer software and technical support by software companies
	Associated Companies			Costs of associated companies that are not included in other items
	Third party services			Operating costs of providing water services to third parties (other than the regulated water supply function) that are not included in other items
Leasing and Rentals	Premises		0.0	Payments for leasing or renting premises
	Vehicles			Payments for leasing or renting vehicles
	Mobile Plant			Payments for leasing or renting mobile plant
	Fixed Plant			Payments for leasing or renting fixed plant
Purchases	Equipment		0.0	Payments for leasing or renting equipment
	Water treatment chemicals			All water treatment chemicals for water supply that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems
	Other than chemicals and energy			All materials and consumables other than energy and water treatment chemicals for water supply, that are not in HIRED AND CONTRACTED SERVICES and which are required for operation of sources, treatment plants, transmission and distribution systems
Taxes, levies and fees	All kinds		0.0	Any operating licences paid to a Government or municipal authority, abstraction charges, local authority rates
Exceptional earnings and losses	All kinds		0.0	Any exceptional income or expenditure from donations, investment subsidies, compensations or adjustments related to sales/writing off of fixed assets
Other Operating Expenditures	Other direct costs		0.0	Any other operating costs (but excluding interest and taxation, on an aggregated basis)
	General and support expenditures			The aggregate direct cost of GENERAL AND SUPPORT ACTIVITIES (Manpower costs excluded)
	Customer services			Costs directly associated with customer services that are not included in previous items, related to customer accounting, reading of meters, debt recovery, costs of disconnections, customers'enquiries and complaints handling.
	Scientific services			Costs directly associated with scientific and laboratory services and with the monitoring of quality that are not included in previous items
	Other business activities			Costs directly associated with other business activities that are not included in previous items, except for cost depreciation
	Doubtful debts			Charge/credit to the profit and loss account for bad and doubtful debts
Sum of Operational Costs	All the above operational costs		0.0	
Internal manpower costs	Employment costs		0.0	The sum of the total manpower costs of permanent and temporary personnel, including employment-related social costs and benefits paid by the employer
Capitalised cost of self-constructed assets	Negative allocation		0.0	The summation of the amounts in each of the above cost categories that have been incurred in the construction of new or rehabilitated assets
Total Running Costs	Sum of Operational costs and Internal Manpower Costs, minus capitalised cost of self-constructed assets		0.0	

Comments: